**Aalborg Universitet** 



# **Discrete-Time LPV Current Control of an Induction Motor**

Bendtsen, Jan Dimon; Trangbæk, Klaus

Publication date: 2001

**Document Version** Også kaldet Forlagets PDF

Link to publication from Aalborg University

Citation for published version (APA): Bendtsen, J. D., & Trangbæk, K. (2001). Discrete-Time LPV Current Control of an Induction Motor.

#### **General rights**

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
   You may freely distribute the URL identifying the publication in the public portal -

#### Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

# Discrete-Time LPV Current Control of an Induction Motor

Jan Dimon Bendtsen, Klaus Trangbæk

Abstract-In this paper we apply a new method for gainscheduled output feedback control of nonlinear systems to current control of an induction motor. The method relies on recently developed controller synthesis results for linear parameter-varying (LPV) systems, where the controller synthesis is formulated as a set of linear matrix inequalities with full-block multipliers. A standard nonlinear model of the motor is then constructed and written on LPV form. We then show that, although originally developed in continuous time, the controller synthesis results can be applied to a discrete-time model as well without further complications. The synthesis method is applied to the model, yielding an LPV discrete-time controller. Finally, the efficiency of the control scheme is validated via simulations as well as experimentally on the actual induction motor, both in open-loop current control and when an outer speed control loop is closed around the current loop.

Index Terms—Induction Motors, LPV Control, Linear Fractional Transformations, Linear Matrix Inequalities

#### I. INTRODUCTION

Gain scheduling is a well-known and common approach to control of well-behaved nonlinear systems. The classical approach to gain-scheduling control has been to linearise the plant model in some set of operating points and design one or more linear, possibly robust, controllers for the system in said points. The gains of these individual linear controllers are then interpolated between the different operating points. This approach has been used in a multitude of applications and often works well as long as the scheduling variable, i.e., the variable according to which the controllers are interpolated, varies slowly. However, as pointed out in [17], the rate of change of the parameter variation imposes fundamental limitations on the achievable performance of classical gain scheduling controllers. Also, the classical gain scheduling methods are generally somewhat ad hoc.

More recent work on *linear parameter varying* (LPV) control has addressed these issues by devising rigorous methods in which it is possible to compensate for known, fast parameter variations directly in the control design [7], [12], [14], [16]. Linear parameter-varying systems are linear systems whose system matrices depend on some time-varying parameter vector that is either fully known or at least known to be contained in some known set. In LPV control design this knowledge is employed to provide systematic gain scheduling in which stability and performance of the closed loop can be guaranteed. The controller syn-

thesis is cast as a set of matrix inequalities based on the varying system matrices and the plant-controller interconnection, along with a set of multipliers, which must satisfy these matrix inequalities.

One problem with these types of approaches has so far been that it can be difficult to obtain non-conservative controllers for a given plant if the plant parameter variations are considerable and restrictions are placed on the controller synthesis in the form of pre-imposed structures in the aforementioned multipliers. In [2] a controller synthesis was achieved for parameter dependencies entering the system via a linear fractional transformation (LFT) description. The structural restrictions on the multipliers were dealt with in case of affine parameter dependencies in [3]. but it is only recently that it has been shown how they can be lifted in case of more general, rational parameter dependencies, i.e., in LFT descriptions, as well. The resulting synthesis matrix inequalities yielding the controllers can be solved by using the so-called full-block S-procedure [15], [16]. In essence, this results in an automated controller design method for nonlinear systems which permit an LPV description. To the best of our knowledge, this paper presents the first actual implementation of an LPV controller designed via the full-block S-procedure.

In this paper we will use this novel technique to design and test a rotor flux oriented current controller for an induction motor. Induction motors have been used in a wide range of industrial as well as everyday applications over a number of decades, but with their highly nonlinear, fast dynamics they remain a challenge to control. A number of different current control schemes for three-phase systems have been employed in order to deal with the problem, such as classical linear controllers, predictive control and schemes based on neural networks/fuzzy logic (see [10] and the references therein). Several continuous-time control schemes that take the induction motor dynamics into account have been applied, including simple Lyapunov-based approaches [19], minimum-time control [6], sliding mode control [18], as well as decoupling with special attention paid to robustness [8]. Recently, backstepping techniques have been applied to current and rotational speed control simultaneously [13].

A drawback of most of these methods is, however, that they require a considerable amount of tuning and engineering insight. In this paper we will demonstrate that the LPV controller synthesis can be applied to the problem and achieve satisfying performance basically without any ad hoc tuning. Another general problem with these schemes is that it is unclear whether or not they will work well when implemented in discrete time at a sampling frequency which is not considerably faster than the motor dy-

J. Bendtsen is with the Department of Control Engineering, Aalborg University, Fredrik Bajersvej 7C, DK-9220 Aalborg East, Denmark. Email: dimon@control.auc.dk.

K. Trangbaek is with Grundfos A/S, DK-8850 Bjerringbro, Denmark. Email: ktrangbaek@grundfos.com

namics. In this paper we show that the LPV controller synthesis can be carried out in discrete time. This is generally important in connection with practical implementations if there are limitations on the sample rate compared to the dynamics of the plant, since the accuracy of a continuoustime nonlinear design may not be sufficient if the sample rate cannot be chosen high enough. If the sample rate cannot be chosen freely, a continuous-time controller synthesis may result in discrete-time controllers with very high gains or unstable open-loop dynamics, which could result in the designed closed-loop behaviour not being preserved when the controller is implemented. Some examples of discretetime designs for induction motors can be found in [4] and [20].

The content of the paper is as follows. Section II briefly discusses the model of the induction motor on which the LPV control law is based. It is written as a complex-valued state space model which can easily be discretised. Next, in Section III we discuss the discrete-time formulation of the controller synthesis problem based on full-block multipliers and show that the problem can be solved basically without modifications compared to the continuous-time version. In Section IV the control synthesis result presented in Section III is applied to the induction motor model of Section II. Section V then demonstrates a few simulation results where it is seen that the controller performs as expected, and that the scheduling is required for stable control. Section VI shows some practical experiments. Finally, Section VII sums up the conclusions of the work.

Notation. Let  $C^* \in \mathbb{C}^{n \times m}$  denote the complex conjugated transpose of the complex-valued matrix  $C \in \mathbb{C}^{m \times n}$ , and let  $C^{\perp}$  denote any basis matrix for the null space of C, that is,  $CC^{\perp} \equiv 0$ . In the following, we will say that  $C \in \mathbb{C}^{n \times n}$  is Hermitian if  $C = C^*$ . In this case the eigenvalues of the matrix are real, and we will say that the matrix is positive definite, written C > 0, if all the eigenvalues are positive. The matrix is positive semidefinite, written  $C \geq 0$ , if all its eigenvalues are non-negative. Negative definiteness and semidefiniteness is defined analogously. A matrix inequality is an expression of the form

$$F(A, B, \ldots, X_1, X_2, \ldots) < 0,$$

where  $A, B, \ldots$  are known and  $X_1, X_2, \ldots$  are unknown matrices, and  $F(\cdot)$  is a Hermitian matrix function. The matrix inequality is *feasible* if all eigenvalues of  $F(\cdot)$  are less than 0 for some  $X_1, X_2, \ldots$ . If  $F(\cdot)$  is linear in the unknown matrices, it is called a *linear matrix inequality* (LMI). LMIs can be solved efficiently using standard software tools; refer to e.g. [5] for more information on LMIs in general. Finally, we will use the notation C(k) to describe a discrete-time dynamic system, while C is simply a matrix (or memoryless mapping).

#### II. LPV DESCRIPTION OF MOTOR MODEL

The induction motor setup we are considering in this paper is shown schematically in Figure 1. An inverter feeds three-phase alternating current  $(i_{sA}, i_{sB} \text{ and } i_{sC})$  to the motor based on the PWM voltages  $u_{sA}, u_{sB}$  and  $u_{sC}$ .

The three-phase voltages and currents are transformed from/into a single complex voltage and current representation in a rotating reference frame, respectively, according to the relations

$$u_{s} = u_{sd} + ju_{sq} = \frac{2}{3} \left( u_{sA} + u_{sB} e^{j\frac{2\pi}{3}} + u_{sC} e^{j\frac{4\pi}{3}} \right) e^{-j\rho}$$
$$i_{s} = i_{sd} + ji_{sq} = \frac{2}{3} \left( i_{sA} + i_{sB} e^{j\frac{2\pi}{3}} + i_{sC} e^{j\frac{4\pi}{3}} \right) e^{-j\rho}$$

where  $\rho$  is the angular position of the chosen reference frame.  $u_{sd} = \Re\{u_s\}, u_{sq} = \Im\{u_s\}, i_{sd} = \Re\{i_s\}$ , and  $i_{sq} = \Im\{i_s\}$  are all real-valued signals. The aim we will pursue in this paper is to design an inner current control loop which can be placed in a cascade coupling with an outer shaft speed control loop, as indicated in Figure 1.



Fig. 1. Schematic drawing of the induction motor setup.

With standard assumptions, the motor model is given by (see e.g. [11] or [13]):

$$\frac{di_s}{dt} = -\left(\frac{R_s + R'_r}{L'_s} + j\omega\right)i_s \\
+ \left(\frac{R'_r}{L'_s} - j\frac{L'_m}{L'_s}Z_p\omega_{mech}\right)i_m + \frac{u_s}{L'_s} \qquad (1)$$

$$\frac{di_m}{dt} = \frac{R'_r}{L'_m} i_s - \left(\frac{R'_r}{L'_m} + j(\omega - Z_p \omega_{mech})\right) i_m \quad (2)$$

in which  $u_s$  and  $i_s$  are the complex stator voltage and current, respectively, and  $i_m$  is the complex magnetising current associated with the rotor flux  $\Psi_r = L_m i_m$ . The equations above are given in a reference frame which rotates with the rotational speed  $\omega = \dot{\rho}$ .  $L_m$  is the magnetising inductance.  $R'_r = (L_m/L_r)^2 R_r, L'_s = L_s - L_m^2/L_r$ and  $L'_m = L_m^2/L_r$  are the referred parameters used in the model, found based on identified values of the stator and rotor resistances and inductances  $R_s, R_r, L_s$  and  $L_r$ .  $Z_p$  is the number of pole pairs, while  $\omega_{mech}$  is the motor shaft speed. The motor develops the following electromagnetic torque:

$$m_e = \Im\{\frac{3}{2}Z_p L'_m i_s i_m^*\}$$

while the load torque  $m_L$  acts as a disturbance via the mechanical relation

$$Jrac{d\omega_{mech}}{dt} = m_e - m_L$$

where J is the mechanical moment of inertia. We choose a reference frame rotating at the same angle as the magnetising current, since in this frame the steady-state signals are constant. Since, in reality, the magnetising current cannot be measured, we will use the following simple estimator. Let  $T_r = L'_m/R'_r$  and  $\omega_r = Z_p \omega_{mech}$  and compute the estimate of  $i_m$ ,  $\hat{i}_m$ , based on (2) as

$$\omega = \omega_r + i_{sq} / (T_r \hat{i}_{md}) \tag{3}$$

$$\frac{di_m}{dt} = \frac{1}{T_r} \left( i_s - (1 + j(\omega - \omega_r))\hat{i}_m \right).$$
(4)

In this reference frame,  $\hat{i}_m$  is real. We choose the complex state vector  $x = \begin{bmatrix} i_s^* & i_m^* \end{bmatrix}^*$  and insert (3) in (1)–(2) obtaining

$$\dot{x} = (A_0 + \delta_1 A_1 + \delta_2 A_2) x + B u_s, \quad i_s = C x \qquad (5)$$

in which

$$A_0 = \begin{bmatrix} -\frac{R_s + R'_r}{L'_s} & \frac{R'_r}{L'_s} \\ \frac{R'_r}{L'_m} & -\frac{R'_r}{L'_m} \end{bmatrix}, \ B = \begin{bmatrix} \frac{1}{L'_s} \\ 0 \end{bmatrix} \text{ and } C = \begin{bmatrix} 1 & 0 \end{bmatrix}$$

represent the nominal model, which is a linear time invariant system, and

$$A_{1} = \begin{bmatrix} -j & -j\frac{L'_{m}}{L'_{s}} \\ 0 & 0 \end{bmatrix} \text{ and } A_{2} = \begin{bmatrix} 0 & j\frac{L'_{m}}{T_{r}L_{s}} \\ 0 & -j\frac{1}{T_{r}} \end{bmatrix}$$

represent the effects of parameter variations in the linear system. These parameter variations symbolise the nonlinearities caused by  $\delta_1 = \omega$  and  $\delta_2 = i_{sq}/\hat{i}_{md}$ , where all signals vary with time and  $\hat{i}_{md} > 0 \ \forall t$ . This particular choice of parameterisation has the advantage over the other obvious choice,  $\delta_1 = \omega$  and  $\delta_2 = \omega_r$ , that  $\omega$  will typically be close to  $\omega_r$ ; the parameterisation chosen above is a straightforward way to exploit this knowledge. The system (5) can then be written on an LFT form and can be meaningfully discretised, for instance according to the method presented in [1]. By considering the parameter variations as being caused by external effects, we are able to employ the LPV control synthesis that will be described in the following section. It should be noted, as already mentioned in the introduction, that the main reason why we discretise the model at this point is to be able to address limitations on the sample rate already in the synthesis phase, before the actual implementation.

#### III. LPV CONTROLLER SYNTHESIS

In the synthesis, we consider the discrete-time system

$$\begin{bmatrix} x_{k+1} \\ z_{u,k} \\ z_{p,k} \\ y_k \end{bmatrix} = \begin{bmatrix} A & B_u & B_p & B \\ \hline C_u & D_{uu} & D_{up} & E_u \\ C_p & D_{pu} & D_{pp} & E_u \\ C & F_u & F_p & 0 \end{bmatrix} \begin{bmatrix} x_k \\ \hline w_{u,k} \\ w_{p,k} \\ u_k \end{bmatrix}$$
(6)

with  $x_k \in \mathbb{C}^n$ ,  $u_k \in \mathbb{C}^m$  and  $y_k \in \mathbb{C}^p$  representing states, inputs and outputs at sample instant k, respectively. All the matrices are assumed to be complex, constant and of appropriate dimensions.  $w_{p,k} \in \mathbb{C}^{p_w}$  and  $z_{p,k} \in \mathbb{C}^{p_z}$  are used to specify performance and  $w_{u,k} \in \mathbb{C}^{u_w}$  and  $z_{u,k} \in \mathbb{C}^{u_z}$  are channels which connect a set of residual gains collected in the mapping  $\Delta_k$  with the nominal linear system as follows:

$$w_{u,k} = \Delta_k z_{u,k}. \tag{7}$$

 $\Delta_k$  is a time-varying mapping that represents the nonlinearities in the system. We will assume that  $\Delta \in \mathbf{\Delta}$ , where  $\mathbf{\Delta}$  is a compact, path-connected set containing 0, and that the interconnection between the nominal system model M(k) and  $\Delta$  is *well-posed*, that is,  $I - \Delta D_{uu}$  is nonsingular for all  $\Delta \in \mathbf{\Delta}$ .



Fig. 2. The interconnection of the nominal system M(k), the residual gains  $\Delta$ , and the controller K(k).

We then consider the controller-system interconnection depicted in Figure 2. The controller is of the form

$$\begin{bmatrix} \frac{x_{c,k+1}}{u_k} \\ z_{c,k} \end{bmatrix} = \begin{bmatrix} \frac{A_c}{C_{c1}} & B_{c1} & B_{c2} \\ \hline C_{c1} & D_{c11} & D_{c12} \\ C_{c2} & D_{c21} & D_{c22} \end{bmatrix} \begin{bmatrix} \frac{x_{c,k}}{y_k} \\ w_{c,k} \end{bmatrix}$$
(8)

with  $w_{c,k} = \Delta_c(\Delta_k) z_{c,k}$  where  $\Delta_c$  is a nonlinear function of  $\Delta$ . If we interconnect the controller and the nominal system as depicted in the left part of Figure 2 we get the closed-loop LTI system  $M_c(k)$  described by

$$\begin{bmatrix} \chi_{k+1} \\ z_{u,k} \\ z_{c,k} \\ z_{p,k} \end{bmatrix} = \begin{bmatrix} \mathcal{A} & \mathcal{B}_u & \mathcal{B}_c & \mathcal{B}_p \\ \mathcal{C}_u & \mathcal{D}_{uu} & \mathcal{D}_{uc} & \mathcal{D}_{up} \\ \mathcal{C}_c & \mathcal{D}_{cu} & \mathcal{D}_{cc} & \mathcal{D}_{cp} \\ \mathcal{C}_p & \mathcal{D}_{pu} & \mathcal{D}_{pc} & \mathcal{D}_{pp} \end{bmatrix} \begin{bmatrix} \chi_k \\ w_{u,k} \\ w_{c,k} \\ w_{p,k} \end{bmatrix}$$
(9)

subject to the parameter dependency

$$\begin{bmatrix} w_u \\ w_c \end{bmatrix} = \begin{bmatrix} \Delta_k & 0 \\ 0 & \Delta_c (\Delta_k) \end{bmatrix} \begin{bmatrix} z_u \\ z_c \end{bmatrix}$$
(10)

and with the state vector  $\chi_k = \begin{bmatrix} x_k^* & x_{c,k}^* \end{bmatrix}^*$ .  $\Delta_c$  and the controller matrices must be chosen such that the interconnection with the system and controller is well-posed, i.e.,  $I - \begin{bmatrix} \Delta & 0 \\ 0 & \Delta_c \end{bmatrix} \begin{bmatrix} \mathcal{D}_{uu} & \mathcal{D}_{uc} \\ \mathcal{D}_{cu} & \mathcal{D}_{cc} \end{bmatrix}$  is nonsingular for all  $\Delta \in \boldsymbol{\Delta}$ . More

explicitly, the gains of  $M_c(k)$  in (9) are given by

$$M_{c} = \begin{bmatrix} A & B_{u} & B_{c} & B_{p} \\ C_{u} & D_{uu} & D_{uc} & D_{up} \\ C_{c} & D_{cu} & D_{cc} & D_{cp} \\ \hline C_{p} & D_{pu} & D_{pc} & D_{pp} \end{bmatrix}$$
$$= \begin{bmatrix} A & 0 & B_{u} & 0 & B_{p} \\ 0 & 0 & 0 & 0 & 0 \\ \hline C_{u} & 0 & D_{uu} & 0 & D_{up} \\ 0 & 0 & 0 & 0 & 0 \\ \hline C_{p} & 0 & D_{pu} & 0 & D_{pp} \end{bmatrix}$$
$$+ \begin{bmatrix} 0 & B & 0 \\ I & 0 & 0 \\ \hline 0 & E_{u} & 0 \\ 0 & 0 & I \\ \hline 0 & E_{p} & 0 \end{bmatrix} K \begin{bmatrix} 0 & I & 0 & 0 & 0 \\ C & 0 & F_{u} & 0 & F_{p} \\ 0 & 0 & 0 & I & 0 \end{bmatrix}$$
$$= \begin{bmatrix} A_{m} & B_{m1} & B_{m2} \\ \hline C_{m1} & D_{m11} & D_{m12} \\ \hline C_{m2} & D_{m21} & D_{m22} \end{bmatrix}$$

where K is the matrix of controller gains given by (8). It can be shown that the trajectories of (9) are identical to those of the nonlinear system [15]

$$\chi_{k+1} = \bar{\mathcal{A}}(\Delta_k)\chi_k + \bar{\mathcal{B}}(\Delta_k)w_{p,k}$$
  

$$z_{p,k} = \bar{\mathcal{C}}(\Delta_k)\chi_k + \bar{\mathcal{D}}(\Delta_k)w_{p,k}$$
(11)

where

$$\begin{bmatrix} \bar{\mathcal{A}}(\Delta_k) & \bar{\mathcal{B}}(\Delta_k) \\ \bar{\mathcal{C}}(\Delta_k) & \bar{\mathcal{D}}(\Delta_k) \end{bmatrix} = \begin{bmatrix} \mathcal{A}_m & \mathcal{B}_{m2} \\ \mathcal{C}_{m2} & \mathcal{D}_{m22} \end{bmatrix} + \\ \begin{bmatrix} \mathcal{B}_{m1} \\ \mathcal{D}_{m21} \end{bmatrix} \begin{bmatrix} \mathcal{D}_{uu} & \mathcal{D}_{uc} \\ \mathcal{D}_{cu} & \mathcal{D}_{cc} \end{bmatrix} \left( I - \begin{bmatrix} \Delta & 0 \\ 0 & \Delta_c \end{bmatrix} \begin{bmatrix} \mathcal{D}_{uu} & \mathcal{D}_{uc} \\ \mathcal{D}_{cu} & \mathcal{D}_{cc} \end{bmatrix} \right)^{-1} \begin{bmatrix} \mathcal{C}_{m1} & \mathcal{D}_{m12} \end{bmatrix}$$

The objective is, if possible, to find a gain-scheduled control law K(k) and a scheduling function  $\Delta_c(\Delta)$  such that the closed loop system (9) fulfills a robust quadratic performance specification (RQP), which is defined as follows.

• The interconnection of system and controller is wellposed.

• The unforced system is uniformly asymptotically stable, i.e., positive constants K and  $\alpha$  exist such that  $\|\chi_k\| \leq \|\chi_0\| K e^{-\alpha k}$  for  $k \geq 0$  and all  $\Delta \in \Delta$  if  $w_{p,k} \equiv 0$ .

• The following performance specification holds for  $\chi_0 = 0$ :

$$\exists \varepsilon > 0 : \sum_{k=0}^{\infty} \begin{bmatrix} w_{p,k} \\ z_{p,k} \end{bmatrix}^* P_p \begin{bmatrix} w_{p,k} \\ z_{p,k} \end{bmatrix} \le -\varepsilon \sum_{k=0}^{\infty} w_{p,k}^* w_{p,k} \quad (12)$$

for some  $P_p = \begin{bmatrix} Q_p & S_p \\ S_p^* & R_p \end{bmatrix}$ ,  $R_p \ge 0$ , specified a priori. As can be seen, this formulation is equivalent to the continuous-time formulation of the notion of RQP (see for instance [16]). The following result shows that the discrete-time version of the full-block S-procedure yields a synthesis procedure that will guarantee (discrete-time) RQP for (9).

Theorem 1: Robust quadratic performance is achieved for the system (9)-(10) if one of the following two equivalent properties holds.

1. (9)–(10) is well-posed and there exists a Hermitian  $\mathcal{X} > 0$  such that

$$\begin{bmatrix} * \\ * \\ * \\ * \\ * \end{bmatrix}^{*} \begin{bmatrix} -\mathcal{X} & 0 & 0 & 0 \\ 0 & \mathcal{X} & 0 & 0 \\ \hline 0 & 0 & Q_{p} & S_{p} \\ 0 & 0 & S_{p}^{*} & R_{p} \end{bmatrix} \begin{bmatrix} I & 0 \\ \bar{\mathcal{A}}(\Delta) & \bar{\mathcal{B}}(\Delta) \\ \hline 0 & I \\ \bar{\mathcal{C}}(\Delta) & \bar{\mathcal{D}}(\Delta) \end{bmatrix} < 0$$
(13)

for all  $\Delta \in \mathbf{\Delta}$ .

2. There exists a Hermitian multiplier

$$P_e = \begin{bmatrix} Q & S & Q_{12} & S_{12} \\ S^* & R & S_{21}^* & R_{12} \\ \hline Q_{12}^* & S_{21} & Q_2 & S_2 \\ S_{12}^* & R_{12}^* & S_2^* & R_2 \end{bmatrix}$$
(14)

which fulfills the matrix inequality

$$\begin{bmatrix} \Delta & 0\\ 0 & \Delta_c(\Delta)\\ \hline I & 0\\ 0 & I \end{bmatrix}^* P_e \begin{bmatrix} \Delta & 0\\ 0 & \Delta_c(\Delta)\\ \hline I & 0\\ 0 & I \end{bmatrix} > 0$$
(15)

for all  $\Delta \in \mathbf{\Delta}$  and a Lyapunov matrix  $\mathcal{X} > 0$  such that

$$\tau^{*} \begin{bmatrix} -\mathcal{X} & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & \mathcal{X} & 0 & 0 & 0 & 0 & 0 & 0 \\ \hline 0 & 0 & Q & S & Q_{12} & S_{12} & 0 & 0 \\ \hline 0 & 0 & S^{*} & R & S_{21}^{*} & R_{12} & 0 & 0 \\ \hline 0 & 0 & Q_{12}^{*} & S_{21} & Q_{2} & S_{2} & 0 & 0 \\ \hline 0 & 0 & 0 & 0 & 0 & 0 & Q_{p} & S_{p} \\ \hline 0 & 0 & 0 & 0 & 0 & 0 & 0 & S_{p}^{*} & R_{p} \end{bmatrix} \tau < 0$$
(16)

where

$$\tau = \begin{bmatrix} I & 0 & 0 & 0 \\ A & B_u & B_c & B_p \\ \hline 0 & I & 0 & 0 \\ \hline C_u & D_{uu} & D_{uc} & D_{up} \\ \hline 0 & 0 & I & 0 \\ \hline C_c & D_{cu} & D_{cc} & D_{cp} \\ \hline 0 & 0 & 0 & I \\ \hline C_p & D_{pu} & D_{pc} & D_{pp} \end{bmatrix}.$$
 (17)

*Proof:* Inspection reveals that the only difference between the continuous-time case and the discrete-time case is the upper left block in the central factors in (16) and (13). The equivalence between 1. and 2. hence follows from a direct application of the full-block S-procedure, Theorem 8 in [15].

We thus just need to show that requirement 1. yields RQP. Let  $w_{p,k} \equiv 0$  in (11) and choose  $\mathcal{V}_k = \chi_k^* \mathcal{X} \chi_k$ as a Lyapunov candidate for the unforced system. The difference from sample to sample is  $\mathcal{V}_{k+1} - \mathcal{V}_k =$  $\chi_k^* \bar{\mathcal{A}}(\Delta)^* \mathcal{X} \bar{\mathcal{A}}(\Delta) \chi_k - \chi_k^* \mathcal{X} \chi_k$ , which implies that the system is uniformly exponentially stable if  $\bar{\mathcal{A}}(\Delta)^* \mathcal{X} \bar{\mathcal{A}}(\Delta) <$  $\mathcal{X}$ . But this is immediately deduced from the upper left block in (13), which can be written as  $\bar{\mathcal{A}}(\Delta)^* \mathcal{X} \bar{\mathcal{A}}(\Delta) \mathcal{X} + \bar{\mathcal{D}}(\Delta)^* R_p \bar{\mathcal{D}}(\Delta) < 0$ . Since  $R_p \geq 0$  it is seen that if  $\mathcal{X}$  renders (13) satisfied, the unforced system is uniformly exponentially stable.

Furthermore, due to continuity and strictness of (13), we can add a small perturbation  $G = \begin{bmatrix} 0 & 0 \\ 0 & \varepsilon I \end{bmatrix}$  to the lefthand side of the inequality without rendering it unsatisfied. Multiplying from the left and right with  $\xi_k = \begin{bmatrix} \chi_k^* & w_{p,k}^* \end{bmatrix}^*$ then gives

$$\begin{aligned} \xi_{k}^{*} \begin{bmatrix} \bar{\mathcal{A}}(\Delta)^{*} \mathcal{X} \bar{\mathcal{A}}(\Delta) - \mathcal{X} & \bar{\mathcal{A}}(\Delta)^{*} \mathcal{X} \bar{\mathcal{B}}(\Delta) \\ \bar{\mathcal{B}}(\Delta)^{*} \mathcal{X} \bar{\mathcal{A}}(\Delta) & \bar{\mathcal{B}}(\Delta)^{*} \mathcal{X} \bar{\mathcal{B}}(\Delta) \end{bmatrix} \xi_{k} + \\ \xi_{k}^{*} \begin{bmatrix} 0 & I \\ \bar{\mathcal{C}}(\Delta) & \bar{\mathcal{D}}(\Delta) \end{bmatrix}^{*} P_{p} \begin{bmatrix} 0 & I \\ \bar{\mathcal{C}}(\Delta) & \bar{\mathcal{D}}(\Delta) \end{bmatrix} \xi_{k} + \xi_{k}^{*} G \xi_{k} \leq 0 \end{aligned}$$

which reduces to

$$(\chi_{k+1} - \chi_k)^* \mathcal{X} (\chi_{k+1} - \chi_k) + \begin{bmatrix} w_{p,k} \\ z_{p,k} \end{bmatrix}^* P_p \begin{bmatrix} w_{p,k} \\ z_{p,k} \end{bmatrix} + \varepsilon w_{p,k}^* w_{p,k} \le 0$$

Summing from k = 0 to  $k = \infty$  with  $\chi_0 = 0$  and  $\lim_{k\to\infty} \chi_k = 0$  then yields (12), and hence requirement 1. implies RQP.

It is observed that, as in the continuous-time case, (16) is an LMI in the unknowns  $\mathcal{X}$  and  $P_e$ . The discrete-time controller synthesis thus continues completely analoguously with the continuous-time synthesis in [15]. The extended multiplier  $P_e$  in (14) is constructed from multipliers P and  $\tilde{P}$  of lower dimension such that

$$P_e = \begin{bmatrix} P & * \\ * & * \end{bmatrix}, \quad P_e^{-1} = \begin{bmatrix} \tilde{P} & * \\ * & * \end{bmatrix}$$
(18)

where P and  $\tilde{P}$  must fulfill the following requirements:

$$P = \begin{bmatrix} Q & S \\ S^* & R \end{bmatrix}, \quad \begin{bmatrix} \Delta \\ I \end{bmatrix}^* P \begin{bmatrix} \Delta \\ I \end{bmatrix} > 0 \quad \forall \ \Delta \in \mathbf{\Delta}$$
(19)

 $\operatorname{and}$ 

$$\tilde{P} = \begin{bmatrix} \tilde{Q} & \tilde{S} \\ \tilde{S}^* & \tilde{R} \end{bmatrix}, \quad \begin{bmatrix} I \\ -\hat{\Delta}^* \end{bmatrix}^* \tilde{P} \begin{bmatrix} I \\ -\hat{\Delta}^* \end{bmatrix} < 0 \quad \forall \ \Delta \in \mathbf{\Delta}.$$
(20)

We will, due to a technicality in the controller construction, require  $\tilde{P}$  to have as many negative eigenvalues as the dimension of  $w_u$ . It is now possible to construct the extended multiplier as

$$P_e = \begin{bmatrix} P & U \\ U^* & N^{-1} \end{bmatrix}.$$
 (21)

where the matrix U is chosen such that its columns form an orthogonal basis of the image of  $P - \tilde{P}^{-1}$ , and such that

$$U^{*}(P - \tilde{P}^{-1})U = N = \begin{bmatrix} N_{-} & 0\\ 0 & N_{+} \end{bmatrix}$$
(22)

with  $N_{-} < 0$  and  $N_{+} > 0$ .

$$\begin{bmatrix} V_{-}(\Delta) & V_{+}(\Delta) \end{bmatrix} = \begin{bmatrix} \Delta^* & I \end{bmatrix} U$$
(23)

with  $V_{-}$  and  $V_{+}$  having dim $\{N_{-}\}$  and dim $\{N_{+}\}$  columns, respectively. We will then construct the scheduling function  $\Delta_{c}(\Delta)$  in the following way:

$$\Delta_{c}(\Delta) = N_{-}V_{-}(\Delta)^{*} \times \left( \begin{bmatrix} \Delta \\ I \end{bmatrix}^{*} P \begin{bmatrix} \Delta \\ I \end{bmatrix} - V_{-}(\Delta)N_{-}V_{-}(\Delta)^{*} \right)^{-1} V_{+}(\Delta).$$
(24)

The scheduling function can thus be constructed based on knowledge of the mapping  $\Delta$  and the multiplier submatrices P and  $\tilde{P}$ . These multipliers are found by solving the following three coupled LMIs:

$$\begin{bmatrix} X & I\\ I & Y \end{bmatrix} \ge 0 \tag{25}$$

$$\psi^{*} \begin{bmatrix} -X & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & X & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & Q & S & 0 & 0 & 0 \\ 0 & 0 & 0 & Q & S & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & Q_{p} & S_{p} & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & S_{p}^{*} & R_{p} \end{bmatrix} \psi < 0 \qquad (26)$$

$$\phi^{*} \begin{bmatrix} -Y & 0 & 0 & 0 & 0 & 0 & 0 & 0 \\ 0 & 0 & Q & \tilde{S} & 0 & 0 & 0 & 0 \\ 0 & 0 & Q & \tilde{S} & 0 & 0 & 0 & 0 \\ 0 & 0 & \tilde{S}^{*} & \tilde{R} & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & \tilde{S}_{p}^{*} & \tilde{S}_{p} & 0 & 0 & 0 \\ 0 & 0 & 0 & 0 & 0 & \tilde{S}_{p}^{*} & \tilde{R}_{p} \end{bmatrix} \phi > 0 \qquad (27)$$

where

$$\psi = \begin{bmatrix} I & 0 & 0 \\ A & B_u & B_p \\ \hline 0 & I & 0 \\ C_u & D_{uu} & D_{up} \\ \hline 0 & 0 & I \\ C_p & D_{pu} & D_{pp} \end{bmatrix} \begin{bmatrix} B^* & E_u^* & E_p^* \end{bmatrix}^{\perp}$$

 $\operatorname{and}$ 

$$\phi = \begin{bmatrix} -A^* & -C^*_u & -C^*_p \\ I & 0 & 0 \\ \hline -B^*_u & -D^*_{uu} & -D^*_{pu} \\ 0 & I & 0 \\ \hline -B^*_p & -D^*_{up} & -D^*_{pp} \\ 0 & 0 & I \end{bmatrix} \begin{bmatrix} C^* & F^*_u & F^*_p \end{bmatrix}^{\perp}$$

In the above,  $\tilde{P}_p = \begin{bmatrix} \bar{Q}_p & \bar{S}_p \\ \bar{S}_p^* & \bar{R}_p \end{bmatrix}$  denotes the inverse of the performance specification matrix  $P_p$ .

To sum up, the synthesis progresses as follows. Assuming that matrices X, Y, P, and  $\tilde{P}$  solving (25)–(27) have been found, it is possible to construct the extended multiplier  $P_e$  and the scheduling function  $\Delta_c$  as given in (21) and (24), respectively. If  $X - Y^{-1}$  is of full rank, the Lyapunov matrix  $\mathcal{X}$  can be calculated as

$$\mathcal{X} = \begin{bmatrix} X & I \\ I & (X - Y^{-1})^{-1} \end{bmatrix}.$$

in which case the controller will be of the same order as the system. If, on the other hand,  $X - Y^{-1}$  is close to losing rank, then  $\mathcal{X}$  can instead be constructed as

$$\mathcal{X} = \begin{bmatrix} X & Z \\ Z^* & (Z^*(X - Y^{-1})Z)^{-1} \end{bmatrix}$$

where the columns of Z form an orthonormal basis of the image of  $X - Y^{-1}$ . In this case the order of the controller will be reduced by a corresponding number of orders. (17) is a linear function of the controller matrices  $(A_c, B_c, C_c, D_c)$ , which means that (16) becomes a quadratic matrix inequality (QMI) in  $(A_c, B_c, C_c, D_c)$ . A solution method for the QMI problem (16) based on the number of positive and negative eigenvalues of the central factor, can for instance be found in [15].

#### IV. CONTROLLER SYNTHESIS

In this section we apply the synthesis method outlined in the previous section to the discrete-time motor model. The model (5) was employed, using the following parameter values previously identified from the actual motor setup:

$$A_0 = \begin{bmatrix} -320.7 & 140.0 \\ 10.5 & -10.5 \end{bmatrix}, \quad B = \begin{bmatrix} 42.0 \\ 0 \end{bmatrix}, \quad C = \begin{bmatrix} 1 & 0 \end{bmatrix}$$

 $\operatorname{and}$ 

$$A_1 = \begin{bmatrix} -j & -13.3j \\ 0 & 0 \end{bmatrix}, \quad A_2 = \begin{bmatrix} 0 & 140.0j \\ 0 & -10.5j \end{bmatrix}.$$

The contributions of the parameter variations to the state equation could be described by  $B_u w_u = \begin{bmatrix} A_1 & A_2 \end{bmatrix} \begin{bmatrix} \delta_1 I \\ \delta_2 I \end{bmatrix} z_u$ . However, since  $A_1$  and  $A_2$  have rank 1, we may write

$$A_{1} = U_{1}\Sigma_{1}V_{1}^{*} = \begin{bmatrix} u_{1}^{1} & u_{2}^{1} \end{bmatrix} \begin{bmatrix} \sigma_{1} & 0\\ 0 & 0 \end{bmatrix} \begin{bmatrix} (v_{1}^{1})^{*}\\ (v_{2}^{1})^{*} \end{bmatrix}$$

and

$$A_{2} = U_{2}\Sigma_{2}V_{2}^{*} = \begin{bmatrix} u_{1}^{2} & u_{2}^{2} \end{bmatrix} \begin{bmatrix} \sigma_{2} & 0 \\ 0 & 0 \end{bmatrix} \begin{bmatrix} (v_{1}^{2})^{*} \\ (v_{2}^{2})^{*} \end{bmatrix}$$

and let  $B_u = \begin{bmatrix} u_1^1 \sigma_1 & u_1^2 \sigma_2 \end{bmatrix}$ . It then follows that, with  $z_u = C_u x, C_u = \begin{bmatrix} v_1^1 & v_1^2 \end{bmatrix}^*$ , the parameter variation can be written as  $\delta_1 A_1 x + \delta_2 A_2 x = B_u \begin{bmatrix} \delta_1 & 0 \\ 0 & \delta_2 \end{bmatrix} z_u$ , which is advantageous in terms of implementation. The parameter variation channel  $z_u \to w_u$  was hence defined as follows:

$$w_u = \Delta z_u = \begin{bmatrix} \omega & 0 \\ 0 & i_{sq}/\hat{i}_{md} \end{bmatrix} z_u.$$

The performance and noise/reference channels were denoted  $z_p$  and  $w_p$ . The performance output

$$z_p = \begin{bmatrix} i_s - i_{s,ref} \\ \sigma_u u_s \end{bmatrix}$$

consisted of the control error and the control signal weighted by a factor  $\sigma_u$ . The performance input (or noise channel)

$$w_p = \begin{bmatrix} i_{s,ref} \\ \nu_m \end{bmatrix}$$

consisted of the stator current reference and measurement noise. Finally, the measurement y was defined as the control error corrupted by random measurement noise  $\nu_m \in [-\sigma_{\nu}; \sigma_{\nu}]$ , i.e.

$$y = i_s - i_{s,ref} + \nu_m.$$

The following nominal system could thus be constructed:

$$\begin{bmatrix} \dot{x} \\ z_u \\ z_p \\ y \end{bmatrix} = \begin{bmatrix} A_0 & B_u & 0 & B \\ \hline C_u & 0 & 0 & 0 \\ C_p & 0 & D_{pp} & E_p \\ C & 0 & F_p & 0 \end{bmatrix} \begin{bmatrix} x \\ w_u \\ w_p \\ u \end{bmatrix}.$$

The matrices  $C_p$ ,  $D_{pp}$  and  $E_p$  were used to define the weightings of the state, noise, reference, and control signal contributions to the performance and measurement output, respectively. Correspondingly,  $F_p$  accounted for the weightings of the noise and reference contribution to the measurement output. We chose  $\sigma_u = 10^{-6}$  and  $\sigma_{\nu} = 10^{-8}$ .

The control error part of the performance channel was augmented by a first-order filter that allowed frequency tuning of the controller; the pole was placed in s = -100. This system was then discretised with a sampling period of 600Hz, using the bilinear transformation as described in [1], yielding the discrete-time nominal system (6). As discussed earlier, this sampling frequency was imposed by the hardware setup. The eigenvalues of the discretised system matrix were located at z = 0.5815, z = 0.9903 and z = 0.9990.

The next step was to solve the LMIs (25)-(27) in order to compute a controller. The performance specification

$$P_p = \begin{bmatrix} -\gamma I & 0\\ 0 & \frac{1}{\gamma}I \end{bmatrix}$$
(28)

providing a bound  $\gamma$  on the induced 2-norm

$$\sup_{w_p\neq 0}\frac{\|z_p\|_2}{\|w_p\|_2}\leq \gamma$$

was chosen and a bisectional search for the smallest  $\gamma$  for which (25)–(27) were feasible could then be performed. We allowed  $\delta_1 = \omega$  and  $\delta_2 = \Im\{i_s\}/\Re\{\hat{i}_m\}$  to obtain values in the intervals [-800; 800] and [-10; 10], respectively. Under these circumstances, a performance of  $\gamma = 0.0011$ could be achieved and a controller on the form (8) could be obtained by solving the QMI (16). When solving the synthesis QMI, it was found that the controller order could be reduced by one, yielding a second-order controller with eigenvalues of  $A_c$  in z = 0.9990 and z = 0.8202.



Fig. 3. LPV current control, simulation. The top figure shows the real and imaginary components,  $u_{sd}$  and  $u_{sq}$ , of the control voltage generated by the controller. The middle figures show the real and imaginary components,  $i_{sd}$  and  $i_{sq}$ , of the controlled currents, plotted with full lines (—) along with their reference signals, plotted with dash-dotted lines  $(-\cdot -)$ . The bottom plot shows  $\delta_1$  (—) and  $\delta_2$   $(-\cdot -)$  scaled to the interval [-1; 1]. As can be seen, the tracking of the current reference satisfies the performance requirement except when the control voltage saturates (at around 4 sec).



Fig. 4. LPV current control, simulation without scheduling. The top figure shows the real and imaginary components,  $u_{sd}$  and  $u_{sq}$ , of the control voltage generated by the controller. The lower figure shows the real and imaginary components,  $i_{sd}$  and  $i_{sq}$ , of the controlled currents, plotted with full lines (—) along with their reference signals, plotted with dash-dotted lines (-·-). Without the gain scheduling the system becomes unstable.

#### V. SIMULATIONS

In the simulations the reference sequence was chosen as a series of steps, each with a duration of 250 samples. For each step, the reference for  $i_{sq}$  was allowed to take random values in the interval [-10; 10], while the reference for  $i_{sd}$  was chosen from the interval [1; 3]. The system was disturbed by a load torque  $m_L$ , which was a sequence of uniformly distributed white noise filtered through a firstorder filter with a time constant of 1/2 second. Subject to these external signals, the nonlinear model generated the  $\delta_1$ and  $\delta_2$  sequences based on which the controller scheduling function was calculated. Motivated by limitations of the



Fig. 5. LPV current control, experimental results. The top figures show the real and imaginary components,  $u_{sd}$  and  $u_{sq}$ , of the control voltage generated by the implemented LPV controller. The lower figures show the controlled current  $i_{sq}$ . The reference signals are shown with dash-dotted lines  $(-\cdot -)$ , while the measurements are shown with full lines  $(-\cdot)$ . The left figures are without load, while the right figures are recorded with a load torque of  $m_L = 4Nm$ .

hardware of the experimental setup, the control voltage  $u_s$  was made to saturate at 600V.

Figure 3 shows a simulation of the closed loop system. It is seen that the control loop achieves good tracking, in accordance with the performance value achieved for all values of the parameter variations, except when the control signal saturates. The parameter variations are shown in the bottom plot in Figure 3, scaled to the interval [-1; 1]. It is noted that the generated stator voltage compensates for the parameter variations throughout the allowed range. This scheduling is crucial to successful control; Figure 4 shows a simulation carried out under similar circumstances, but with the scheduling signal set to  $w_u \equiv 0$  (only voltage and current are shown). As can clearly be seen, the system becomes unstable in certain regions of the operating range if the gain scheduling is switched off.

## VI. PRACTICAL EXPERIMENTS

The controller presented above was implemented in C without modifications on a standard PC. The power device is a voltage-sourced inverter controlled directly from the PC. The induction motor is a 1.5kW, two pole-pair motor with a rated torque of 10Nm. The first two experiments were open-loop current control experiments where the aim was to keep the magnetising current constant and make the imaginary part of the stator current follow a series of steps. The first experiment was conducted without load, while in the second experiment the motor shaft was subjected to a load torque of 4Nm. The results are shown in Figure 5, where it is observed that the current tracks the reference steps adequately well. Looking at the stator



Fig. 6. LPV current control in cascade with rotational speed controller, experimental results. The top figure shows the real and imaginary components,  $u_{sd}$  and  $u_{sq}$ , of the control voltage generated by the implemented LPV controller. The middle and lower figures show the controlled current  $i_{sq}$  and the rotational speed  $\omega_r$ , respectively. The reference signals are shown with dashdotted lines  $(-\cdot -)$ , while the measurements are shown with full lines (-). The current reference signal was generated by an outer loop speed controller.

voltage, it is noted that the imaginary part of the voltage is significantly different between the two experiments. This is due to the two different disturbance load torques, which cause the scheduling controller to yield significantly different control signals. Some variation can be noted in the real part of the voltage as well, caused by cross couplings between the stator and magnetising currents.

In the third experiment the shaft speed loop was closed using an outer PI-controller. In this case the stator current reference signals were thus generated by the PI-controller, and the LPV controller had to track these signals. The results of this experiment is shown in Figure 6. As can be seen, the control loop performs satisfactorily.

### VII. CONCLUDING REMARKS

In this paper a recently developed procedure for LPV controller synthesis, the so-called full-block S-procedure, has been applied to stator current control of an induction motor, which is a highly nonlinear dynamical system. This method required the model to be written on a linear fractional form, where the nonlinearities entered the model as parameter variations. Due to hardware limitations on the sample rate, it was chosen to discretise the system model. Hereafter, it was demonstrated that the controller synthesis can be formulated in discrete time as well.

A controller was constructed such that its dynamics depended on a scheduling function calculated from the parameter variation part of the model. The synthesis of the controller and scheduling function was then achieved by solving a set of linear matrix inequalities constructed from the model parameters. It was found via simulations that the gain-scheduled closed-loop system fulfilled a robust quadratic performance specification throughout the operating range, but that it would become unstable if the scheduling was switched off. The gain-scheduling is thus an integral part of the controller. The main contribution of this paper was then to show that a systematic nonconservative control design with more than one scheduling parameter could be implemented on a real-life system with fast dynamics.

Finally, some suggestions for further research could be to construct an entirely LPV-based controller from speed reference to measured speed, as well as to try to include robustness with respect to poorly known parameters such as the rotor resistance and inductance.

#### References

- [1] P. Apkarian, "On the Discretization of LMI-synthesized Linear Parameter-Varying Controllers," Automatica Vol. 33, 4:655-661, 1997
  - [2] P. Apkarian, P. Gahinet, "A Convex Characterization of Gain-Scheduled  $H_{\infty}$  Controllers," *IEEE Transactions on Automatic Control*, Vol. 40, 5:853-864, 1995
  - [3] P. Apkarian, P. Gahinet, G. Becker, "Self-scheduled  $H_{\infty}$  control of linear parameter-varying systems: a design example" Automatica, Vol. 31, 9:1251–1262, 1995
  - [4] F. Blaabjerg, J. K. Pedersen, M. P. Kazmierkowski, "DSP-based Current Regulated PWM Inverter-fed Induction Motor Drive Without Speed Sensor," in Proc. of the IEEE International Symposium on Industrial Electronics, 659-664, 1996
  - [5] S. Boyd, L. El Ghaoui, E. Feron, V. Balakrishnan, "Linear Matrix Inequalities in System and Control Theory," Philadelphia, PN: SIAM, 1994
  - [6] J. W. Choi, S. K. Sul, "Generalized solution of minimum time current control in three-phase balanced systems," *IEEE Trans*actions on Industrial Electronics Vol. 45, 5:738-744, 1998
  - [7] A. Helmersson, "Methods for Robust Gain Scheduling," Ph.D. thesis, Linköping University, 1995
  - [8] J. Jung, S. Lim, K. Nam, "PI-type Decoupling Control Scheme for Highspeed Operation of Induction Motors," in Proc. of the 28th Annual IEEE Power Electronics Specialists Conference, 1082-1085, 1997
  - [9] Y. H. Liu, C. L. Chen, R. J. Tue, "A Novel Space-vector Current Regulation Scheme for a Field-oriented-controlled Induction Motor Drive," *IEEE Transactions on Industrial Electronics* Vol. 45, 5:730-737, 1998
  - [10] M. P. Kazmierkowski, M. A. Dzieniakowski, "Review of Current Regulators for Three-Phase PWM Inverters," in Proc. of the 20th International Conference on Industrial Electronics, Control and Instrumentation, 567-575, 1994
  - [11] R. F. F. Koning, C. T. Chou, M. H. G. Verhaegen, J. B. Klaassens, J. R. Uittenbogaart, "A Novel Approach on Parameter Identification for Inverter Driven Induction Machines," *IEEE Transactions on Control Systems Technology* Vol. 8, 6:873-882, 2000
  - [12] A. Packard, "Gain Scheduling via Linear Fractional Transformations," Systems and Control Letters Vol. 22, 79–92, 1994
  - [13] H. Rasmussen, P. Vadstrup, H. Børsting, "Nonlinear Field Oriented Control of Induction Motors using the Backstepping Method," in Proc. of the Sixth International Conference on Control, Automation, Robotics and Vision, 2000
  - [14] W. Rugh, J. S. Shamma, "Research on Gain Scheduling," Automatica Vol. 36, 1401–1425, 2000
  - [15] C. W. Scherer, "LPV Control and Full Block Multipliers," Automatica Vol. 37, 361–375 2001
  - [16] C. W. Scherer, "Robust Mixed Control and LPV Control and Full Block Scalings," in L. El Ghaoui, S. Niculescu, Recent Advances in LMI Methods in Control, SIAM, 1999
  - [17] J. S. Shamma, M. Athans, "Gain Scheduling: Potential Hazards and Possible Remedies," *IEEE Control Systems Magazine* Vol. 12, 101–107, 1992
  - [18] L. G. Shiau, J. L. Lin, "Stability of Sliding-mode Current Control for High Performance Induction Motor Position Drives," IEE

Proceedings on Electric Power Applications Vol. 148, 1:69-75,

- 2001
  [19] K. K. Shyu, H. J. Shieh, "Variable Structure Current Control for Induction Motor Drives by Space Voltage Vector PWM," *IEEE Transactions on Control Systems Technology* Vol. 42, 6:572–578, 1907 1995
- [20] S. M. Yang, C. H. Lee, "A Current Control Technique for Voltage-fed Induction Motor Drives," in Proc. of the 25th Annual Conference IEEE Industrial Electronics Society, 1380-1385, 1999