Aalborg Universitet



Transfer of Emission Test Data from Small Scale to Full Scale

Jensen, Gunnar P.; Nielsen, Peter V.

Publication date: 1995

Document Version Publisher's PDF, also known as Version of record

Link to publication from Aalborg University

Citation for published version (APA):

Jensen, G. P., & Nielsen, P. V. (1995). *Transfer of Emission Test Data from Small Scale to Full Scale*. Dept. of Building Technology and Structural Engineering. Indoor Environmental Technology Vol. R9537 No. 50

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
 You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

INSTITUTTET FOR BYGNINGSTEKNIK DEPT. OF BUILDING TECHNOLOGY AND STRUCTURAL ENGINEERING AALBORG UNIVERSITET • AUC • AALBORG • DANMARK



INDOOR ENVIRONMENTAL TECHNOLOGY PAPER NO. 50

Presented at Healthy Buildings '95 Milano, Italy, September 1995

GUNNAR P. JENSEN & PETER V. NIELSEN TRANSFER OF EMISSION TEST DATA FROM SMALL SCALE TO FULL SCALE DECEMBER 1995 ISSN 1395-7953 R9537 The papers on INDOOR ENVIRONMENTAL TECHNOLOGY are issued for early dissemination of research results from the Indoor Environmental Technology Group at the University of Aalborg. These papers are generally submitted to scientific meetings, conferences or journals and should therefore not be widely distributed. Whenever possible reference should be given to the final publications (proceedings, journals, etc.) and not to the paper in this series.

Printed at Aalborg University

INSTITUTTET FOR BYGNINGSTEKNIK DEPT. OF BUILDING TECHNOLOGY AND STRUCTURAL ENGINEERING AALBORG UNIVERSITET • AUC • AALBORG • DANMARK

INDOOR ENVIRONMENTAL TECHNOLOGY PAPER NO. 50

Presented at Healthy Buildings '95 Milano, Italy, September 1995

GUNNAR P. JENSEN & PETER V. NIELSEN TRANSFER OF EMISSION TEST DATA FROM SMALL SCALE TO FULL SCALE DECEMBER 1995 ISSN 1395-7953 R9537

TRANSFER OF EMISSION TEST DATA FROM SMALL SCALE TO FULL SCALE

Gunnar P. Jensen and Peter V. Nielsen

Department of Building Technology and Structural Engineering Aalborg University, Sohngaardsholmsvej 57, 9000 Aalborg, Denmark Tel. +45 98158522 ext. 6601

INTRODUCTION

Emission testing of building materials is often carried out in small-scale test chamber. A method to transfer results from these tests to full scale is presented. A difference in scale can lead to a difference between the emission rate of a given pollutant measured in a smallscale test chamber and the one that is found in a full-scale ventilated room. The discrepancy is noticeable when the emission is dependent on environmental parameters such as room temperature, pollutant concentration, humidity and air flow pattern. Testing conditions are usually chosen to reflect the situation experienced in full scale, i.e. Test conditions such as temperature, relative humidity, and air velocities are chosen within the range that are found in ventilated rooms. However, the difference in scale can lead to some problems and misconception of the size of the actual emission rate for a building material. This paper highlights some of these problems and introduce an approach on how to overcome them and produce useful results. The paper concentrates on describing situations where the air velocity field near the source influence the emission rate.

Emission of volatile organic compounds (VOC) from drying paint can be regarded as limited by diffusion through the boundary layer (Kornum, 1980). Emission of VOC can then be described by Fick's law

$$E = -D \frac{\partial c}{\partial y}$$

where $E[mg/m^2s]$ is the emission rate, $D[m^2/s]$ is the molecular diffusion coefficient, $c[mg/m^3]$ is the concentration and y[m] is distance. The emission rate can also be described in terms of a mass transfer coefficient $k_c[m/s]$.

$$E = -k_c (c - c_s)$$

where k_c is the ratio (D/ δ), δ [m] is the boundary layer thickness (Figure 1) and c_s is the vapour pressure at the surface expressed as concentration.

The boundary layer thickness is dependant on flow near the source, and the influence of turbulence is very important. Some models of emission in test chambers include the effect of the air flow field near the emitting surface. This is done by including the boundary layer thickness as a parameter in the calculation of the emission (Tichenor et al., 1993). The next step is to link these models to full scale conditions. In this paper, a method is introduced which can handle turbulent and laminar flow, and varying boundary layer thickness. The method can be used both to decide under which conditions test chamber tests should be done, and to decide the emission rate in a given case.

METHODS

Room air flows are often simulated by using a k- ε turbulence model, where k is turbulent kinetic energy and ε is energy dissipation. The k- ε model is based on the assumption that the flow is fully turbulent, this is not true in the near wall region where a laminar layer persists. Turbulent boundary layer flows have a laminar sublayer adjacent to the wall, where there is a linear relation between the velocity and the distance from the wall (Figure 1). At some distance from the wall we have fully turbulent flow, between the two layers there is a buffer zone. Near the wall velocity fluctuations are damped and the molecular viscosity is dominating.



Figure 1: Velocity and concentration profiles for fully turbulent boundary layer flow near a wall. δ_u is the velocity boundary layer thickness and δ_D is the diffusion boundary layer thickness.

Traditionally the problem with low Reynolds numbers in the near wall region has been handled by applying the so-called universal law-of-the-wall. For solving practical engineering problems the method is very useful, but it has some shortcomings for example if the flow is not fully turbulent, if free convection is present or if wall jets are present.

Many problems in modelling flows in ventilated room are due to Low Reynolds Number (LRN) effects. To simulate this, LRN versions of the k- ε model have been developed. These models account for LRN effects by damping the turbulence near the wall. Patel et al. (1985) reviewed a number of LRN-models and found that the Launder-Sharma model (Launder and Sharma, 1974) was one of the better ones. In this study the Launder-Sharma model is used to overcome scaling problems, which occur when small scale test chamber emission data is transferred to full scale. An example on how to deal with the transfer of emission data is demonstrated. A typical test chamber and a typical full-scale room are chosen. LRN-models are expensive in terms of computer time, because a high resolution of the boundary layer is needed. To reduce usage of computer time all simulations are done in two dimensions.

The geometry of the full-scale room is chosen similar to the room used in the IEA annex 20 programme, (Figure 2). The geometry is well-tested both in terms of measurements and simulations (Nielsen, 1990 and IEA, 1991).



Figure 2. Dimensions of the two dimensional full scale room (IEA, annex 20, Nielsen 1990).

Emissions from ceiling and floor are tested. An area 3 m from the inlet at the ceiling and 3 m from the outlet are not emitting because local conditions influence the emission in these regions. The emission is simulated for air exchange rates from 1 to 10 h^{-1} .





The test chamber is chosen as two emitting surfaces with the length 0.8 m in the direction of the flow and a spacing between the plates of 0.02 m (Figure 3). In both cases a hypothetical set of agent and material is used. The surface concentration is set at $c_s = 1000 \text{ mg/m}^3$ and the diffusion coefficient of $D = 1.51 \cdot 10^{-5} \text{ m}^2/\text{s}$.

RESULTS

The computer simulations were performed for the two geometries mentioned above. Figure 4 shows velocity profiles near the ceiling and the floor. At the floor the velocity boundary layer was thicker than at the ceiling. To compare the variation of emission rate with velocity a reference velocity is needed. For the full-scale room the local maximum velocity parellel to the surface u_m is used (Figure 4).



Figure 4. Velocity profiles corresponding to an air exchange rate of 10 h⁻¹.

In the laminar layer near the wall, molecular diffusion is dominating, and the concentration gradient is controlling the mass transport. Two typical profiles are shown in figure 5. The high velocities at the ceiling result in a high concentration gradient.



Figure 5. Concentration profiles for the air exchange rate equal to 10 h⁻¹.

Figure 6 shows how the mass transfer coefficient k_c varies as a function of the velocity. For the test chamber the average velocity of a cross section is used as the reference velocity.



Figure 6. Mass transfer coefficient in full scale and test chamber.

The figure can be used to transfer the emission test data obtained in a small test chamber to full-scale conditions. For example: $u_m = 0.05$ m/s is expected at the floor. Then the mass transfer coefficient found from experiment at 0.21 m/s should be used in predicting the emission to the room air. Curves that are made by using a hypothetical agent can be used for other agents which have similar diffusion coefficients.

DISCUSSION

The results serve as an example on how to use the method. They show that similar velocities can give large differences in emission rates for different geometries. Factors such as the turbulence intensity and the velocity profile near the source are important. Because of the differences, the 'translation' of results is important. The method also provides us with a tool to compare emission test data from different test chamber designs.

It must be noted that for all simulations it is assumed that the emission is controlled by diffusion through a boundary layer near the surface. But the method is general applicable to the study of other limiting processes and environmental parameters influencing the emission rate. To use the method, processes of interest must be included in the simulations, ie. If diffusion within the source material is limiting for the emission, mass transfer within the material must be included in the model. Next step in developing the method will be to validate with experiments. And possible to improve the turbulence model, because it must be recognised that the LRN-model is based on empirical data, and that some flow phenomena are not accounted for.

ACKNOWLEDGEMENT

This research was supported financially by the Danish Technical Research Council (STVF) as part of the research programme "Healthy Buildings", 1993 - 1997.

REFERENCES

- International Energy Agency, IEA, 1991, Air flow patterns within building, Annex 20 of the IEA programme for Energy Conservation in Buildings and Community Systems, Annex 20: Air Flow Patterns within Buildings. Room Air and Contaminant Flow, Evaluation of Computational Methods. Subtask-1 Summary Report First Draft.
- Kornum L.O., 1980, Evaporation and Water-dilutable Coatings. Journal of Oil and Color Chemist's Association, 63, pp. 103-123..
- Launder, B.E. and Sharma, B.I., 1974, Application of the Energy-Dissipation Model of Turbulence to the Calculation of Turbulence to the Calculation of Flow Near a Spinning Disc. Letters in Heat and Mass Transfer, Vol. 1, pp. 131-138.
- Nielsen P.V., 1990, Specification of a Two-Dimensional Test Case. Internal report for the International Energy Agency, Annex 20. Aalborg University, Denmark. ISSN 0902-7513 R9040.
- Patel V.C., Rodi W. and Scheuerer G., 1985, Turbulence Models for Near-Wall and Low Reynolds Number Flows: A Review. AIAA Journal., Vol. 23, pp. 1308-1320.
- Tichenor B.A., Guo Z. and Sparks L.E., 1993, Fundamental mass transfer model for indoor air emissions from surface coatings. Indoor Air, 3: 263-268.

PAPERS ON INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 23: P. Kofoed, P. V. Nielsen: Auftriebsströmungen verschiedener Wärmequellen - Einfluss der umgebenden Wände auf den geförderten Volumenstrom. ISSN 0902-7513 R9151.

PAPER NO. 24: P. Heiselberg: Concentration Distribution in a Ventilated Room under Isothermal Conditions. ISSN 0902-7513 R9152.

PAPER NO. 25: P. V. Nielsen: Air Distribution Systems - Room Air Movement and Ventilation Effectiveness. ISSN 0902-7513 R9250.

PAPER NO. 26: P. V. Nielsen: Description of Supply Openings in Numerical Models for Room Air Distribution ISSN 0902-7513 R9251.

PAPER NO. 27: P. V. Nielsen: Velocity Distribution in the Flow from a Wallmounted Diffuser in Rooms with Displacement Ventilation. ISSN 0902-7513 R9252.

PAPER NO. 28: T. V. Jacobsen & P. V. Nielsen: Velocity and Temperature Distribution in Flow from an Inlet Device in Rooms with Displacement Ventilation. ISSN 0902-7513 R9253.

PAPER NO. 29: P. Heiselberg: Dispersion of Contaminants in Indoor Climate. ISSN 0902-7513 R9254.

PAPER NO. 30: P. Heiselberg & N. C. Bergsøe: Measurements of Contaminant Dispersion in Ventilated Rooms by a Passive Tracer Gas Technique. ISSN 0902-7513 R9255.

PAPER NO. 31: K. S. Christensen: Numerical Prediction of Airflow in a Room with Ceiling-Mounted Obstacles. ISSN 0902-7513 R9256.

PAPER NO. 32: S. G. Fox & P. V. Nielsen: Model Experiments in 1990 and On-Site Validation in 1992 of the Air Movement in the Danish Pavilion in Seville. ISSN 0902-7513 R9335.

PAPER NO. 33: U. Madsen, N. O. Breum & P. V. Nielsen: Local Exhaust Ventilation - a Numerical and Experimental Study of Capture Efficiency. ISSN 0902-7513 R9336.

PAPER NO. 34: T. V. Jacobsen, P. V. Nielsen: Numerical Modelling of Thermal Environment in a Displacement-Ventilated Room. ISSN 0902-7513 R9337.

PAPER NO. 35: P. Heiselberg: Draught Risk from Cold Vertical Surfaces. ISSN 0902-7513 R9338.

PAPER NO. 36: P. V. Nielsen: Model Experiments for the Determination of Airflow in Large Spaces. ISSN 0902-7513 R9339.

PAPER NO. 37: K. Svidt: Numerical Prediction of Buoyant Air Flow in Livestock Buildings. ISSN 0902-7513 R9351.

PAPER NO. 38: K. Svidt: Investigation of Inlet Boundary Conditions Numerical Prediction of Air Flow in Livestock Buildings. ISSN 0902-7513 R9407.

PAPERS ON INDOOR ENVIRONMENTAL TECHNOLOGY

PAPER NO. 39: C. E. Hyldgaard: Humans as a Source of Heat and Air Pollution. ISSN 0902-7513 R9414.

PAPER NO. 40: H. Brohus, P. V. Nielsen: Contaminant Distribution around Persons in Rooms Ventilated by Displacement Ventilation. ISSN 0902-7513 R9415.

PAPER NO. 41: P. V. Nielsen: Air Distribution in Rooms - Research and Design Methods. ISSN 0902-7513 R9416.

PAPER NO. 42: H. Overby: Measurement and Calculation of Vertical Temperature Gradients in Rooms with Convective Flows. ISSN 0902-7513 R9417.

PAPER NO. 43: H. Brohus, P. V. Nielsen: Personal Exposure in a Ventilated Room with Concentration Gradients. ISSN 0902-7513 R9424.

PAPER NO. 44: P. Heiselberg: Interaction between Flow Elements in Large Enclosures. ISSN 0902-7513 R9427.

PAPER NO. 45: P. V. Nielsen: Prospects for Computational Fluid Dynamics in Room Air Contaminant Control. ISSN 0902-7513 R9446.

PAPER NO. 46: P. Heiselberg, H. Overby, & E. Bjørn: The Effect of Obstacles on the Boundary Layer Flow at a Vertical Surface. ISSN 0902-7513 R9454.

PAPER NO. 47: U. Madsen, G. Aubertin, N. O. Breum, J. R. Fontaine & P. V. Nielsen: Tracer Gas Technique versus a Control Box Method for Estimating Direct Capture Efficiency of Exhaust Systems. ISSN 0902-7513 R9457.

PAPER NO. 48: Peter V. Nielsen: Vertical Temperature Distribution in a Room with Displacement Ventilation. ISSN 0902-7513 R9509.

PAPER NO. 49: Kjeld Svidt & Per Heiselberg: CFD Calculations of the Air Flow along a Cold Vertical Wall with an Obstacle. ISSN 0902-7513 R9510.

PAPER NO. 50: Gunnar P. Jensen & Peter V. Nielsen: Transfer of Emission Test Data from Small Scale to Full Scale. ISSN 1395-7953 R9537.

PAPER NO. 51: Peter V. Nielsen: Healthy Buildings and Air Distribution in Rooms. ISSN 1395-7953 R9538.

PAPER NO. 52: Lars Davidson & Peter V. Nielsen: Calculation of the Two-Dimensional Airflow in Facial Regions and Nasal Cavity using an Unstructured Finite Volume Solver. ISSN 1395-7953 R9539.

PAPER NO. 53: Henrik Brohus & Peter V. Nielsen: Personal Exposure to Contaminant Sources in a Uniform Velocity Field. ISSN 1395-7953 R9540.

PAPER NO. 54: Erik Bjørn & Peter V. Nielsen: Merging Thermal Plumes in the Indoor Environment. ISSN 1395-7953 R9541.

Department of Building Technology and Structural Engineering Aalborg University, Sohngaardsholmsvej 57. DK 9000 Aalborg Telephone: +45 98 15 85 22 Telefax: +45 98 14 82 43