



AALBORG UNIVERSITY
DENMARK

Aalborg Universitet

Harmonic currents Compensator Grid-Connected Inverter at the Microgrid

Asuhaimi Mohd Zin, A.; Naderipour, A. ; Habibuddin, M.H.; Zapata, Josep Maria Guerrero

Published in:
Electronics Letters

DOI (link to publication from Publisher):
[10.1049/el.2016.1890](https://doi.org/10.1049/el.2016.1890)

Publication date:
2016

Document Version
Early version, also known as pre-print

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Asuhaimi Mohd Zin, A., Naderipour, A., Habibuddin, M. H., & Guerrero, J. M. (2016). Harmonic currents Compensator Grid-Connected Inverter at the Microgrid. *Electronics Letters*, 52(20), 1714 - 1715.
<https://doi.org/10.1049/el.2016.1890>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- ? Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- ? You may not further distribute the material or use it for any profit-making activity or commercial gain
- ? You may freely distribute the URL identifying the publication in the public portal ?

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.




Fig. 2 PLL structure of the three-phase

The dq rotating frame converts back to abc stationary frame uses inverse Park's transformation Eq. 7, 8 and 9, by extracting reference signal.

$$i_{sa}^* = i_d^* \sin(\omega t) + \cos(\omega t) \quad (7)$$

$$i_{sb}^* = i_d^* \sin\left(\omega t - \frac{2\pi}{3}\right) + \cos\left(\omega t - \frac{2\pi}{3}\right) \quad (8)$$

$$i_{sc}^* = i_d^* \sin\left(\omega t + \frac{2\pi}{3}\right) + \cos\left(\omega t + \frac{2\pi}{3}\right) \quad (9)$$

The unit of control compensation of harmonic currents uses DC quantities. The design compensation current is injected by appropriate gate plus for inverter which is transferred by gate driver controller to extract reference signal.

Simulation results: The basic MG in this letter includes the MT, the fuel cell, wind turbine and PV array which are connected to the grid by the interface inverter. The proposed control methods is applied to the PV. Furthermore, a fuel cell has an output of 50 kW and a grid-connected PV array has an output of 100 kW and also a 9 MW wind farm and 25MW MT are connected to the grid by AC/DA/AC converter. Another side of this system consists of two non-linear loads, which produced the distorted waveform. In the grid and MG the voltage is assumed sinusoidal. In the simulation, two case study are taken into account.

A. Case study I

The resulting system waveforms consist of grid, PV currents are shown in Figure 3 without any compensation devices.




Fig. 3 System, DG units current waveforms without any compensation: (a) System currents; (b) PV currents

B. Case study II

This case study has an improved power quality with the absence of compensation devices such as passive, active and LCL filters in the MG. Figures 4 (a) and (b) show the effective compensation values of the harmonic current for the grid and the PV. When all of the loads and DGs are connected, the Total Harmonic Distortion (THD) current without any compensation was 13.5%. As shown in Figure 4 (a), THD is reduced to 1.69% in the system with the proposed control method. The Current and THD value of study system is given in Tables 1.




Fig. 4 System and DG unit current waveforms with propose control method; (a) System currents; (b) PV currents

Table 1: Current and THD Result

	Before Compensation		After Propose Control Method	
	Current (A)	THD %	Current (A)	THD %
System	207.6	13.55	1175	1.69
PV	250	11.43	339.6	0.55

Conclusion: This Letter proposes a new control strategy for harmonic current compensation for photovoltaic inverter between PCC and MG and also is responsible for controlling the power injection to the grid, and compensating unbalanced load. The presented simulation results show that the PCC harmonic currents due to unbalanced load, NLL and DGs are compensated to the desired value. This strategy can be used for single-phase and three-phase systems.

Acknowledgments: This work supported by Malaysian Ministry of Education (MOE) under vote 10H58.

A. Asuhaimi Mohd Zin, A. Naderipour, M. H. Habibuddin (*Faculty of Electrical Engineering, Universiti Teknologi Malaysia, Johor, Malaysia*)
E-mail: asuhaimi@utm.my
Josep M. Guerrero (*Department of Energy Technology, Aalborg University, DK-9220 Aalborg East, Denmark*)

References

- Chen, Z., Blaabjerg, F., Pedersen, JK.; 'Hybrid compensation arrangement in dispersed generation systems', *Power Deliv IEEE Trans. IEEE*, 2005, **20**, (2), pp. 1719–27
- Panda, SK., Chitti Babu, B.; 'Improved phase detection technique for grid synchronization of DG systems during grid abnormalities', In: *Engineering and Systems (SCES), 2013 Students Conference on. IEEE*, 2013, pp. 1–6
- Hui, P., Zi-ping, L., Ling, L., Chun-ming, P.; 'Hybrid compensation for harmonic, reactive power and unbalance under dq0 coordinates', In: *Electrical Machines and Systems, ICEMS 2008 International Conference on. IEEE*, 2008, pp. 2004–7.