



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

Mathematical Models for Room Air Distribution - Addendum

Nielsen, Peter V.

Published in:
System Simulation in Buildings

Publication date:
1982

Document Version
Accepted author manuscript, peer reviewed version

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Nielsen, P. V. (1982). Mathematical Models for Room Air Distribution - Addendum. In *System Simulation in Buildings: Proceedings of the International Conference held in Liège (Belgium) on 6-8 December 1982* (1 ed., Vol. 1, pp. 455-470). Commission of the European Communities, COMAC - BME.

General rights


Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy


If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

COMMISSION
OF THE EUROPEAN COMMUNITIES



SYSTEM SIMULATION IN BUILDINGS

*Proceedings of the International Conference
held in Liège (Belgium) on 6-8 December 1982*



COMMISSION
OF THE EUROPEAN COMMUNITIES

SYSTEM SIMULATION IN BUILDINGS

*Proceedings of the International Conference
held in Liège (Belgium) on 6-8 December 1982*

A D D E N D U M

A room air temperature model for HVAC simulation

Most dynamics simulation models for buildings operate with a single grid point for the air temperature in the individual rooms. Refinements of the models, such as a high number of capacities in the floor, wall and ceiling elements, give a detailed description of the dynamics of those elements, and it may be reasonable to follow up such improvements with more advanced models for the room temperature distribution.

Vertical temperature gradients in radiator-heated rooms

It is well known that vertical temperature gradients are established in heated rooms, see /1/ and /2/. Thus calculation of the heat flow through ceilings and floors based on a single temperature point in the individual rooms may contain errors in both numerical size and direction, see /3/.

Fig. 1 shows the temperature difference ΔT between ceiling and floor regions in a test room with radiator heating /2/. It is obvious that this temperature difference is a function of the load and it is also a function of the location of the radiator in relation to the window.

The vertical temperature distribution is a rather linear function of the height in static conditions, see /1/, /2/ and /4/. Unsteady conditions may result in a redistribution of the vertical temperature gradients. Fig. 2 shows some experiments in a radiator-heated room where a window is open for a period of 10 minutes. Three measuring points at different heights show the redistribution in the temperature gradients during the cooling period and partly during the heating period /5/.

A model for temperature distribution in radiator-heated rooms

It is reasonable to describe the vertical temperature gradient $\Delta T/\Delta y$ as a function of the load Q and the location of the radiator. Fig. 3 shows $\Delta T/\Delta y$ in steady conditions at different heat loads from different

experiments where the radiator is placed below the window. It is obvious that a model of the type $\Delta T/\Delta y = \text{const.} \cdot Q$ is a better description than $\Delta T/\Delta y = 0$ as used in the single point description. This could be extended with terms which take into consideration the location of the radiator and other geometrical parameters. Models of the same type may be evaluated for ceiling-heated systems and warm air systems.

References

- 1 Hannay, J., L. Laret, J. Lebrun, D. Marret and P. Nussgens, Thermal comfort and energy consumption in winter conditions - a new experimental approach, ASHRAE transactions, volume 84, part 1, 1978.
- 2 Olesen, B.W. and J. Thorshauge, Differences in comfort sensations in spaces heated by different methods, from Fanger, P.O and O. Valbjørn (eds.), Indoor Climate, Danish Building Research Institute, Copenhagen, 1979.
- 3 Petersen, F., Temperature gradients with different heating systems (in Swedish), Technical information No. 65, Inst. f. Heating and Ventilation, KTH, Stockholm, 1975.
- 4 Internal report, Danfoss A/S.
- 5 Internal report, Danfoss A/S, 1981.

Peter V. Nielsen
Danfoss A/S
DK-6430 Nordborg
Denmark




Fig. 1. Temperature difference between the height $y = 1.8$ m and $y = 0.05$ m at different loads and locations of radiator. From /2/.

$T [^{\circ}\text{C}]$




Fig. 2. Temperature distribution during a 10-minute ventilation period from open windows. $Q = 440$ W. From /5/.

$\Delta T / \Delta y [^{\circ}\text{C}/\text{m}]$




Fig. 3. $\Delta T / \Delta y$ as a function of load from different experiments with radiator heating. The radiator is placed below the window.