



## The Influence of Draught on a Seat with Integrated Personalized Ventilation

Nielsen, Peter V.; Barszcz, Ewa; Czarnota, Tomasz; Dymalski, Dariusz P.; Jasienski, Michal A.; Nowotka, Artur; Mozer, Agata; Wiankowska, Sylwia M.; Jensen, Rasmus Lund

*Published in:*  
Indoor Air 2008

*Publication date:*  
2008

*Document Version*  
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*  
Nielsen, P. V., Barszcz, E., Czarnota, T., Dymalski, D. P., Jasienski, M. A., Nowotka, A., Mozer, A., Wiankowska, S. M., & Jensen, R. L. (2008). The Influence of Draught on a Seat with Integrated Personalized Ventilation. In *Indoor Air 2008: The 11th International Conference on Indoor Air Quality and Climate, 17th August to 22nd August 2008*. Technical University of Denmark (DTU).

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

### Take down policy

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# The Influence of Draught on a Seat with Integrated Personalized Ventilation

Peter V. Nielsen, Ewa Barszcz, Tomasz Czarnota, Dariusz P. Dymalski, Michal A. Jasienski, Artur Nowotka, Agata Mozer, Sylwia M. Wiankowska and Rasmus L. Jensen.

Aalborg University  
Denmark

## Abstract

Normally we protect ourselves from cross infection by supplying fresh air to a room by a diffuser, and this air is distributed in the room according to different principles such as: mixing ventilation, displacement ventilation, vertical ventilation, etc. Often this air distribution has the consequence that it is necessary to supply a very large amount of air to the whole room to obtain a sufficient dilution of the airborne infections.

However, there is a possibility to supply air direct to the breathing zone when people are located in fixed positions as in aircrafts, concert halls etc, and therefore to supply a much smaller amount of air. This principle, called “Personalized Ventilation” has shown to be very efficient in the protection of people from cross infection.

A personalized ventilation devise has been developed in the form of a headrest, a pillow, a blanket or as a chair with a supply surface. The air is supplied to the free convection boundary layer of the person, and the boundary layer then transports the air to the breathing zone. The velocities in this process are very small and draught may be able to disturb the process. Therefore this research work deals with the effectiveness of the system with different levels and directions of draught, as well as with and without a breathing function.

The measurements are made with a full-scale manikin in a wind channel, and CFD predictions are made as a supplement to the measurements. The results show that the boundary layer and the process in the breathing zone are rather independent of the draught at velocities up to 0.2 m/s.