



AALBORG UNIVERSITY
DENMARK

Aalborg Universitet

Variable fractional power-least mean square based control algorithm with optimized PI gains for the operation of dynamic voltage restorer

Naidu, Talada Appala; Arya, Sabha Raj; Maurya, Rakesh; Sanjeevikumar, P.

Published in:
IET Power Electronics

DOI (link to publication from Publisher):
[10.1049/pel2.12067](https://doi.org/10.1049/pel2.12067)

Creative Commons License
CC BY 4.0

Publication date:
2020

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Naidu, T. A., Arya, S. R., Maurya, R., & Sanjeevikumar, P. (2020). Variable fractional power-least mean square based control algorithm with optimized PI gains for the operation of dynamic voltage restorer. *IET Power Electronics*. <https://doi.org/10.1049/pel2.12067>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Variable fractional power-least mean square based control algorithm with optimized PI gains for the operation of dynamic voltage restorer

Talada Appala Naidu¹  | Sabha Raj Arya¹ | Rakesh Maurya¹ | P. Sanjeevikumar Fellow IET² 

¹ Department of Electrical Engineering, Sardar Vallabhbhai National Institute of Technology, Surat 395007, India

² Department of Energy Technology, Aalborg University, Esbjerg 6700, Denmark

Correspondence

Sabha Raj Arya, Department of Electrical Engineering, Sardar Vallabhbhai National Institute of Technology, Dumas Road, Surat, 395007, India. Email: sabharaj79@gmail.com

Funding information

Science and Engineering Research Board, Grant/Award Number: SB/S3/EECE/030/2016

Abstract

The operation of Dynamic Voltage Restorer has been studied for the mitigation of supply voltage disturbances like sag, swell, distortions, and unbalances. A Dynamic Voltage Restorer with three single-phase Voltage Source Converters has been implemented for this purpose. Dynamic Voltage Restorer's compensation capability has been evaluated while introducing the above-said voltage related disturbances in the supply by different means. A control algorithm named Variable Fractional Power-Least Mean Square has been proposed for generating the load reference voltage for Dynamic Voltage Restorer. Variable Fractional Power-Least Mean Square extracts the fundamental active and reactive component out of non-ideal supply voltage and is thus, used in generating reference load voltage. This algorithm is more robust with respect to disturbance due to variable step size and is computationally less expensive. In addition, an optimization-based approach has been proposed to estimate the approximate values of PI control gains. For this reason, a population-based optimization method known as Sine Cosine Optimization has been used. The added feature of the optimization method is the reduction of computational time as compared to conventional PI controller tuning. A model of Dynamic Voltage Restorer using Variable Fractional Power-Least Mean Square control algorithm with Sine Cosine Optimization tuned PI gains has been built in MATLAB Simulink as well as a reduced scale experimental prototype and their results have been presented with discussion.

KEYWORDS

Distortions and imbalances, dynamic voltage restorer (DVR), fundamental components, sine cosine optimization (SCO), variable fractional power-least mean square (VFP-LMS)

1 | INTRODUCTION

Power distribution companies as well as consumers are more concerned about the quality of the power due to heavy use of non-linear and time varying devices [1]. The more often disturbances in the power system are short-term disturbances occurring due to different causes. Automatic reclosing systems are the main reasons for short duration voltage disturbances [2]. The authors in [3, 4] have listed out some flexible ac transmission system devices which have been used for mitigating

the voltage and current related disturbances. Series filters are the most used for the compensation of harmonics and other voltage quality issues in the supply system [5]. Series connected device as a Dynamic Voltage Restorer (DVR) has been introduced particularly for voltage related disturbances like sag, swell, distortion etc. [6]. It is used to re-establish the bus voltage at load end with the help of Voltage Source Converter (VSC) [7]. Kangarlu *et al.* [8] have discussed a review on various topologies of DVR, operating range, control algorithm, and its applications. This paper has also illustrated fast voltage compensator

This is an open access article under the terms of the [Creative Commons Attribution](https://creativecommons.org/licenses/by/4.0/) License, which permits use, distribution and reproduction in any medium, provided the original work is properly cited.

© 2020 The Authors. *IET Power Electronics* published by John Wiley & Sons Ltd on behalf of The Institution of Engineering and Technology

such as Static Series Compensator (SSC) and sag corrector etc. as DVR. A split-capacitor voltage source based VSC has been implemented for the DVR operation using flux-charge model feedback algorithm for limiting the fault ride through elimination [9]. Jimichi *et al.* [10, 11] have discussed the configuration of DVR with series and shunt converters connected back to back and have given the difference in DC capacitor rating in different topologies. A capacitor split battery supported DVR configuration has been built and tested for an unbalance compensation using transformation-based control algorithm in [12]. The authors in [13] have developed a cascaded multilevel inverter-based DVR configuration without using injection transformer at medium voltage level. It is based on self-supported DC bus capacitor where control of DC bus voltage and its balancing is the main challenge. Kim *et al.* [14] have developed a direct PWM cascaded multilevel converter with switching cell structure with coupled inductor, which can avoid the damage due to faults. The authors in [15], have reported the incorporation of DVR in micro-grid application to improve the power transmission capability to the upstream power grid.

Different control algorithms have been proposed since the introduction of DVR in the area of power quality (PQ) [16–20]. Jayaprakash *et al.* [16] have implemented control of battery-based DVR. This control has reduced the rating of voltage source converter. Moreover, it needs the conversion of voltage from abc to d-q axis. The authors in [17] have implemented the control algorithm based on third order sinusoidal signal integral based phase locked loop for DVR to compensate the distortions and supply voltage imbalance. Leon *et al.* in [18] have developed a positive and negative sequence-based control algorithm for DVR under the unbalance condition. The authors in [19] have implemented the instantaneous symmetric component theory-based control algorithm, which uses a Fourier transform to estimate the fundamental component for DVR in compensating unbalances and distortions. A control algorithm has been designed such that the sag or swell in the supply voltage can be compensated using the power measured in the same phase or other two phases [20]. Torres *et al.* in [21] have presented a control algorithm based on stationary reference frame based on two-degree freedom for mitigating balanced as well as unbalanced sag using DVR. The authors in [22] have used a phase-angle control scheme for mitigating the voltage sag, swell, and reactive power compensation utilizing synchronous reference frame-PLL (SRF-PLL) to synchronize the system. Kwong and Johnston [23] have proposed variable learning-based control algorithm where variation of step size depends upon the variation in mean square error. This phenomenon allows tracking of system and with smallest steady state error. In the literature, [24] has reported a variant of variable learning method based on gradient weighted average. Low mis-adjustment error and fast convergence is the main feature of this algorithm. It is useful for system identification in case of low signal to noise ratio. Ahmad *et al.* [25] proposed a variable power with Fractional Least Mean Square (FLMS) to achieve lower steady state error with higher convergence rate. The concept of variable power fraction has been dynamically adapted from the variable step size, which has been implemented in

the channel estimation and system identification. It is working in adaptive framework. Due to the discussed characteristics of this algorithm, it is also effective in the area of power quality, specially to control custom power devices. Another integrated part of system control algorithm is PI controller to maintain system parameters at their reference levels. General practice for PI controller tuning is trial–error (manually) method at initial stage, then by conventional methods which are all time taking and relatively complex in computation [26]. Optimization is one of the useful areas for the analysis of the problem, tuning of gains, another constant factor etc. [27]. It needs the modeling of the search problem based on conventional or meta-heuristics concepts. Sine Cosine Optimization (SCO) algorithm, a population-based optimization technique, uses sine and cosine function in developing the technique [28]. The SCO algorithm is split into two phases for exploration and exploitation to simplify the optimization process and produce the fastest solution.

The combination of the Variable Fractional Power-LMS (VFP-LMS) control along with SCO optimized PI gains estimation has been proposed for DVR to mitigate different voltage-based power quality disturbances. The lower steady state error with higher convergence rate is the main feature of this algorithm. It is more robust with respect to disturbance due to variable step size and it adapts the fractional power dynamically. Added advantages of VFP-LMS and SCO algorithm together have been utilized in this manuscript. Since the estimation of fundamental components from the non-ideal input signals can be done by VFP-LMS based control algorithm, this control is implemented for reference voltage generation in DVR control. In addition, the SCO algorithm has been implemented for DC bus PI controller and AC PI controller to maintain them at reference levels. With the gains estimated using SCO algorithm, the VFP-LMS control algorithm has produced the gate pulses by generating the reference load voltage of DVR. The results showing the performance of SCO algorithm and control algorithm have been presented in this paper. At the same time, the compensation capability of DVR has been evaluated by presenting the simulation and experimental results of the above-said issues in the supply voltage.

2 | SYSTEM CONFIGURATION

Three single-phase configurations of DVR that are VSC based has been built as shown in Figure 1. The network topology includes the three-phase non-ideal AC grid. It saves the supply system from different types of voltage-based disturbances. The critical or sensitive load is secured from the supply side disturbances. The DVR configuration also consists of energy storage system i.e. capacitor (C_{DC}), three single-phase VSC, interfacing inductor (L_i), filtering unit (R_f, C_f), and injection transformers (T/F_{inj}) as shown in the Figure 1. The capacitor (C_{DC}) is so designed that, it should be capable of supporting voltage dynamics. The 6-leg VSC is chosen over conventional VSC due to its requirement of low value of capacitor for the same application. VSC works bi-directionally and whenever the system is stable, the VSC is ideal in operation and when the dynamics




FIGURE 1 Three single-phase VSCs based DVR configuration

occurs in the supply due to various reasons, VSC converts the required amount of DC voltage to AC and works dynamically. The converted AC voltage then is passed through interfacing inductor (L_i) and filter unit (R_f, C_f) for ensuring the filtering of the switching harmonics produced from the VSC. The filtered voltage then is injected into three phase lines through three single injection transformers (T/F_{ijj}) as shown in Figure 1. The three-phase supply voltage (v_s) has been measured at the point of common coupling (PCC) where the different types of voltage disturbances can be experienced. The source impedance (R_s, L_s) has been considered for the effect of the line impedance. Three-phase load voltages (v_L) and load currents (i_L) have been measured at the load bus as shown in Figure 1. The three-phase reference load voltage is generated through the proposed control algorithm. Further, these three-phase reference load voltages are used for the generation of gate pulses. A detail of the control algorithm is explained in the next section of this paper.

3 | CONTROL ALGORITHM

The Variable Fractional Power-Least Mean Square (VFP-LMS) has been developed for controlling the DVR system, which has been discussed in Section 2. Figure 2 gives the information of the complete control algorithm in which VFP-LMS has been used for the extraction of fundamental components of input disturbed voltage. The average of three-phase fundamental components have been fed back to their computation block. Figure 2 also consists of three-phase reference load voltage (v_L^*) generation with which the actual load voltages have

been compared and the gate pulses have been generated. A block diagram that generates the unit templates, which are useful in the reference, load voltage generation. The clear explanation of the control algorithm has been presented as follows.

3.1 | Mathematical description of VFP-LMS

The mathematical description of fundamental active component estimation, which is useful in generating load reference voltage, has been considered for phase 'a' and analogously for phase 'b' and phase 'c'. The update equation for Fractional-LMS for phase 'a' is as shown in Equation (1) [24, 25].

$$Z_a(n+1) = Z_a(n) - \lambda \frac{\partial J_a(n)}{\partial Z_a(n)} - \lambda_f \left(\frac{\partial}{\partial Z_a(n)} \right)^n J_a(n) \quad (1)$$

where ' λ ', ' λ_f ' are the step sizes, ' n ' is the fractional power derivative, and $Z_a(n)$ is the weight update. $J_a(n)$ is the cost function which is defined as Equation (2). The error component can be estimated as shown in Equation (3).

The derivative parts of Equation (1), $\frac{\partial J_a(n)}{\partial Z_a(n)}$ and $\left(\frac{\partial}{\partial Z_a(n)} \right)^n J_a(n)$ are further simplified into Equations (4) and (5).

$$J_a(n) = \frac{1}{2} e_a(n)^2 \quad (2)$$

$$e_a(n) = d_a(n) - y_a(n) \quad (3)$$

$$\frac{\partial J_a(n)}{\partial Z_a(n)} = \frac{\partial J_a(n)}{\partial e_a(n)} \times \frac{\partial e_a(n)}{\partial y_a(n)} \times \frac{\partial y_a(n)}{\partial Z_a(n)} \quad (4)$$

$$\left(\frac{\partial}{\partial Z_a(n)} \right)^n J_a(n) = \frac{\partial J_a(n)}{\partial e_a(n)} \times \frac{\partial e_a(n)}{\partial y_a(n)} \times \left(\frac{\partial}{\partial Z_a(n)} \right)^n y_a(n) \quad (5)$$

$$\frac{\partial J_a(n)}{\partial Z_a(n)} = -e_a(n) \times t_a(n) \quad (6)$$

$$\left(\frac{\partial}{\partial Z_a(n)} \right)^n J_a(n) = -e_a(n) \times t_a(n) \times \frac{Z_a^{1-n}(n)}{\Gamma(2-n)} \quad (7)$$

By the fractional derivative method named after Riemann-Liouville, Equation (4) has been simplified as Equation (6) and similarly Equation (5) as Equation (7) [25]. After substitution of Equations (6) and (7) in Equation (1), Equation (1) can be rewritten as Equation (8) as given below.

$$Z_a(n+1) = Z_a(n) + \lambda \times e_a(n) \times t_a(n) + \lambda_f \times e_a(n) \times t_a(n) \times \frac{Z_a^{1-n}(n)}{\Gamma(2-n)} \quad (8)$$

For obtaining the variable fractional power, Equation (8) can be modified into Equation (9) which gives the active

$$u_a(n+1) = \alpha \times u_a(n) + \beta \times a^2(n) \quad (20)$$

$$a(n+1) = \gamma \times a(n) + (1 - \gamma) \times e_a(n) \times e_a(n-1) \quad (21)$$

$$Z_{qb}(n+1) = Z_{qb}(n) + \lambda \times e_{qb}(n) \times t_{qb}(n) + \lambda_f \times e_{qb}(n) \times t_{qb}(n) \times \frac{Z_{qb}^{1-u_b(n)}(n)}{\Gamma(2-u_b(n))} \quad (22)$$

$$u_b(n+1) = \alpha \times u_b(n) + \beta \times a^2(n) \quad (23)$$

$$a(n+1) = \gamma \times a(n) + (1 - \gamma) \times e_b(n) \times e_b(n-1) \quad (24)$$

$$Z_{qc}(n+1) = Z_{qc}(n) + \lambda \times e_{qc}(n) \times t_{qc}(n) + \lambda_f \times e_{qc}(n) \times t_{qc}(n) \times \frac{Z_{qc}^{1-u_c(n)}(n)}{\Gamma(2-u_c(n))} \quad (25)$$

$$u_c(n+1) = \alpha \times u_c(n) + \beta \times a^2(n) \quad (26)$$

$$a(n+1) = \gamma \times a(n) + (1 - \gamma) \times e_c(n) \times e_c(n-1) \quad (27)$$

The average fundamental reactive component ‘ Z_q ’ of three phases has been computed using Equation (28).

$$Z_q = \frac{Z_{qa} + Z_{qb} + Z_{qc}}{3} \quad (28)$$

$$\left. \begin{aligned} t_{pa} &= \frac{i_{La}}{I_{LA}}; t_{pb} = \frac{i_{Lb}}{I_{LA}}; t_{pc} = \frac{i_{Lc}}{I_{LA}} \\ t_{qa} &= 0.577 \times (t_{pc} - t_{pb}); t_{qb} = 0.289 \times (3t_{pc} + t_{pb} - t_{pc}); t_{qc} \\ &= 0.289 \times (-3t_{pc} + t_{pb} - t_{pc}) \end{aligned} \right\} \quad (29)$$

$$I_{LA} = \sqrt{0.667 \times (i_{La}^2 + i_{Lb}^2 + i_{Lc}^2)} \quad (30)$$

In-phase and quadrature unit templates have been computed using three-phase load currents (i_L) as shown in Equation (29) where (i_{LA}) is the magnitude of the three-phase currents calculated using Equation (30). The error (V_{DCd}) is obtained between actual DC-bus voltage (V_{DC}) and that of reference (V_{DC}^*). The output (V_{dPI}) of DC-PI controller has been subtracted from the average of three-phase active fundamental component (Z_p) to get (v_{pd}), as shown in Equation (31).

$$v_{pd} = Z_p - V_{DPI} \quad (31)$$

The load terminal voltage (V_{LA}) is calculated using Equation (32) and compared with its reference value, and the error has been processed through the PI controller. The output (V_{LPI}) of terminal voltage PI controller has been added to the average

fundamental reactive component (Z_q) to get (v_{ql}), as shown in Equation (33).

$$V_{LA} = \sqrt{0.667 \times (v_{La}^2 + v_{Lb}^2 + v_{Lc}^2)} \quad (32)$$

$$v_{ql} = Z_q + V_{LPI} \quad (33)$$

Three-phase active component of reference voltage (v_p^*) has been obtained by multiplying (v_{pd}) with the unit in-phase templates (t_p), as given in Equation (34). Similarly, three-phase reactive component of reference voltage (v_q^*) has been obtained by multiplying (v_{ql}) with the unit quadrature templates (t_{qa}, t_{qb}, t_{qc}), as given in Equation (35).

$$v_{pa}^* = v_{pd} \times t_{pa}; v_{pb}^* = v_{pd} \times t_{pb}; v_{pc}^* = v_{pd} \times t_{pc} \quad (34)$$

$$v_{qa}^* = v_{ql} \times t_{qa}; v_{qb}^* = v_{ql} \times t_{qb}; v_{qc}^* = v_{ql} \times t_{qc} \quad (35)$$

The three-phase load reference voltage (v_{Labc}^*) has been generated by adding the active (v_{pabc}^*) and reactive (v_{qabc}^*) component reference voltages, as given in Equation (36).

$$v_{La}^* = v_{pa}^* + v_{qa}^*; v_{Lb}^* = v_{pb}^* + v_{qb}^*; v_{Lc}^* = v_{pc}^* + v_{qc}^* \quad (36)$$

These generated three load reference voltages (v_{Labc}^*) are compared with the actual three-phase load voltages (v_{Labc}). After comparing, the estimated three-phase errors have been processed through high frequency carrier based triangular waveform and the gate pulses have been generated for the power semiconductor switches used in three single-phase VSCs [6].

3.2 | Description of SCO approach for PI controller tuning

As a contribution of this paper, PI controllers have been tuned using an optimization technique, which tunes the PI controller's gains automatically without any manual effort. A population-based optimization technique named after SCO algorithm has been implemented for the PI gains approximation. The common practice in population-based optimization techniques is to divide the optimization process into two phases called exploration and exploitation. Exploration decides the wide range search space region by combining the random solutions whereas exploitation guarantees the reduction in randomness in solution compared to that of exploration. Equations (37) and (38) have been proposed for exploration and exploitation, respectively, based on sine and cosine functions [28].

$$x_d^{n+1} = x_d^n + r_1 \times \sin(r_2) \times \text{abs}(r_3 \times X_d^n - x_d^n) \quad (37)$$

$$x_d^{n+1} = x_d^n + r_1 \times \cos(r_2) \times \text{abs}(r_3 \times X_d^n - x_d^n) \quad (38)$$

where ‘ x_d^n ’ is the current position of the solution and ‘ X_d^n ’ is the position of the destination solution. The other parameters which decide the optimization process are listed

as: $r_1 = (1 - \frac{n}{N}) \times 2$; $r_2 = 2 \times pi \times rand()$; $r_3 = 2 \times rand()$ where ‘ n ’ is the present iteration number, ‘ d ’ is the dimension of the search variable, and ‘ N ’ is the maximum number of iterations considered for the optimization process. Equations (37) and (38) have been grouped together for equal sharing of exploration and exploitation using random number ‘ $r_4 = rand()$ ’ which varies in between 0 and 1, which are as given in Equation (39).

$$x_d^{n+1} = \begin{cases} x_d^n + r_1 \times \sin(r_2) \times \text{abs}(r_3 \times X_d^n - x_d^n) \dots \text{if } \dots r_4 < 0.5 \\ x_d^n + r_1 \times \cos(r_2) \times \text{abs}(r_3 \times X_d^n - x_d^n) \dots \text{if } \dots r_4 \geq 0.5 \end{cases} \quad (39)$$

During the continuous process of optimizing solutions by SCO algorithm, it has been considered that this algorithm is used for the tuning of PI controller gains by adapting an objective function (f_o), as shown in Equation (40).

$$f_o = \int (t \times e^2) dt \quad (40)$$

where, ‘ e ’ is an error between the reference level and the actual quantity that is maintained at reference level, ‘ t ’ is the time. Equation (40) describes that, the Error measure has to be squared, then multiplied with time, and then integrated, which has been referred to as integral time square error (ITSE) in short, which is one of the performance indexes. The actual estimation of PI gains using SCO optimization algorithm is presented in the next section.

3.3 | Estimation of PI controller gains using SCO

As discussed in the previous sub-section, detailed explanation of the process of SCO algorithm for PI controller gains estimation in VPF-LMS control algorithm for DVR has been presented here. After a number of trials of implementation, the required parameters for SCO algorithm have been chosen as follows. The maximum number of iterations (N) is 20, 10 number of search agents, and dimension of search agents (d) is set to be 4 as the number parameters to be estimated are four (i.e. Gains of DC and AC-PI controllers). Figure 3(a)–(c) illustrates the performance obtained during the optimization process for estimation of PI controllers’ gains. It includes the convergence curve and the gains of variation curves with respect to iterations.

The convergence curve of SCO algorithm while gains of PI controllers’ estimation has been given in Figure 3(a) from which it can be seen that the SCO algorithm has been converged to a minimum value of 101.5875 by the iteration number 8. This shows that at least eight iterations are required to get final values of all four gains by SCO algorithm as shown in Figure 3(b) and (c). Figure 3(b) illustrates the variation of k_p and k_i of DC-PI controller with respect to iterations, in which k_p has been settled to a value of 14.635 by fourth iteration and k_i to the

value 0.3199 by eighth iteration. Similarly, Figure 3(c) illustrates the variation of k_p and k_i of AC-PI controller with respect to iterations, in which proportional gain (k_p) has been settled to a value of 31.684 by fourth iteration and integral gain (k_i) to the value 0.004 by eighth iteration. Therefore, the minimum number of iterations that SCO algorithm has taken to estimate the gains of both DC as well as AC-PI controllers is eight.

4 | SIMULATION STUDY

The simulation platform, MATLAB has been utilized for simulating the three single-phase VSC based DVR. The simulation configuration ode-3 has been chosen with the sample time of 20 μ s. The gate pulses generated with 5 kHz frequency using VPF-LMS control are processed to the VSC, to work as DVR for the compensation of different disturbances in the supply. The three-phase system is considered as having the voltage related issues in the supply side. Voltage sag, swell, voltage distortions, and imbalances in the voltages have been included in the supply side with a duration of three cycles each. The performance of the VPF-LMS control as well as of the DVR have been studied and presented in this section as follows. The parameters considered for simulation work have been presented in Appendix Table A1.

4.1 | Load reference voltage generation using VPF-LMS based control algorithm

As discussed in the previous section, the load reference voltage generation plays a vital role in the working of DVR; the signals extracted in process of reference voltage generation have been presented here. Figure 4(a) gives the information of all the internal signals of VPF-PLL based control algorithm, which shows the disturbed three-phase supply voltage (v_i) until the three-phase load reference voltage (v_{Labc}^*) generation. Subplot (1) of Figure 4(a) shows the three supply voltages with four different types of voltage related disturbances e.g. voltage sag, swell, voltage distortions, and voltage imbalances having a duration of three cycles each. Subplots (2 and 3) in this figure, are the in-phase (t_p) and quadrature (t_q) templates generated from three-phase load currents (i_L) using Equation (29). The average fundamental active (Z_p) and reactive (Z_q) components of input supply voltage have been presented in subplots (4 and 5) of Figure 4(a). Subplots (6 and 7) of Figure 4(a) show (V_{DPI}) and (V_{LPI}), the outputs of DC-PI controller and terminal voltage PI controller, respectively. Subplots (8 and 9) of Figure 4(a) represent (v_{pd}) and (v_{qi}) which have been computed using Equations (31) and (33), respectively. Fundamental active (v_p^*) and reactive (v_q^*) components of load reference voltage have been shown in subplots (10 and 11) of Figure 4. Finally, the load reference voltage (v_L^*) computed using Equation (36) and the actual sensed load voltage (v_L) have been presented in subplots (12 and 13) of Figure 4(a) for comparison. The generated error between reference and actual load voltage is passed through a high-speed PWM pulse generator as shown in Figure 2 to get gate pulses for three single-phase VSCs.




FIGURE 3 (a) Convergence curve of SCO algorithm while tuning PI controllers. (b) Variation in value of PI gains (k_p , k_i) for DC bus. (c) Variation in value of PI gains (k_p , k_i) for AC bus with respect to number of iterations

4.2 | Voltage disturbance compensation capability of DVR using VFP-LMS based algorithm

Figure 4(b) shows the overall performance analysis of DVR in presence of the mentioned issues in supply voltage. The gate

pulses generated using VFP-LMS based control algorithm have been produced and given to the VSC, and the DVR performance has been evaluated during different type's disturbances and is presented in Figure 4(a). The subplot (1) of Figure 4(b) depicts the supply voltage (v_s) having voltage sag, swell, distortions, and unbalances in it. Subplots (2–4) of Figure 4(b) show




FIGURE 5 Response of DVR in case of unbalanced voltage compensation with (a) basic LMS based control algorithm with constant learning rate ($\mu = 0.45$), (b) basic LMS based control algorithm with constant learning rate ($\mu = 0.6$), and (c) VFP-LMS (μ is variable, as well as power fractional) based control algorithm




FIGURE 6 Harmonics study of DVR during distortions in supply voltage (a) supply voltage (v_{sa}) of phase 'a' and its THD, (b) load voltage (v_{La}) of phase 'a' and its THD, and (c) load current (i_{La}) of phase 'a' and its THD

Distortions (THD) of the waveforms during the distortion. Figure 6(a)–(c) represents the waveforms of supply voltage (v_{sa}), load voltage (v_{La}), and the current flow at phase 'a' load side (i_{La}), respectively, during distortions and their THD spectrum.

Figure 6(a) shows that the supply voltage (v_{sa}) is having 341 V with 7.18% THD during the distortions in it. After distortions were compensated, the load voltage (v_{La}) can be found to be 358.9 V with 3.74 % THD as shown in Figure 6(b). Figure 6(c) represents the load current (i_{La}) having value of 22.12 A with




FIGURE 7 Dynamic voltage restorer hardware setup

0.98 % THD as it is linear load. From this figure, it has been concluded that the distortions in load voltage after compensation with VFP-LMS control has come under 5% as per standard limits of IEEE-519-2014.

5 | EXPERIMENTAL STUDY

The proposed control algorithm has also been tested on a scaled down prototype of DVR with d-SPACE made Micro Lab Box processor at the sampling time of $30 \mu\text{s}$. The sampling time used for simulation work and experimental work is different due to the limitation of used processors. In experimental work, Micro Lab Box processor NXP (Free scale), QorlQP5020, dual core, 2 GHz is used. Moreover, Intel core i5-3470, 3.2 GHz is used for simulation work in side DELL personal computer. A photograph of the experimental setup is shown in Figure 7. It includes non-ideal AC mains, Micro Lab Box processor, load section, sensing circuits, injection transformer, and voltage source converters. Voltage and current sensors have been made using LEM made LV-25P and LA-55P, respectively.

DVR's dynamic execution in all the cases such as voltage sag, swell, distortions, unbalances in supply voltage has been recorded using a four channel DSO-X-2004A. The performance of DVR in steady state is conducted for unbalance in voltage and distortions in the supply using a Fluke-43B made Power Quality analyzer. This single-phase power quality analyzer is able to capture waveform distortion and transient down to 40 ns and able to catch and save 40 transients up to 20 screens at a time. It is required for fast capturing of power quality disturbances. This instrument includes power quality analyzer, oscilloscope, multi-meter, and recorder within one set. The system parameters used in implementation of DVR as shown in Figure 7 are listed in the Appendix Table A2.

5.1 | Voltage sag and swell compensation with DVR having control algorithm based on VPSLMS

DVR's dynamic execution during voltage sag and swell has been reported in Figure 8. Figure 8(a) shows the sag voltage at supply side supply (v_{sab}), compensated potential difference (v_{ca}), com-

pensated potential difference at load (v_{Lab}), and the phase 'a' current at the load. Similarly, Figure 8(c) shows the swell voltage at supply side (v_{sab}), compensated potential difference at load (v_{Lab}), and current flow at the load (i_{La}). Figure 8(b) and (d) shows DC-link voltage which remained at 30 V even during the sag and swell in supply voltage, respectively, to support the load voltage.

5.2 | Compensation of distortions and unbalances using DVR with VFP-LMS based control algorithm


The compensation of distortions and unbalances in supply voltage using DVR can be observed in Figure 9. A level of distortion in the supply system has been injected by connecting a diode rectifier with RC-load at the Point of Common Coupling (PCC) as shown in Figure 7. As a result, distortions are created in the supply voltage up to 7.5 % THD. Figure 9(a) shows the supply voltage (v_{sabc}) which contains the sudden addition of distortions in it and the load current of phase 'a'. So, after compensation of these distortions, the load voltage can be seen free from distortions in it, as seen in Figure 9(b). The compensation of unbalances in supply voltage using DVR can be seen in Figure 9(c) and (d). Unbalances in the supply voltage have been created by connecting resistive load between two lines at the Point of Common Coupling (PCC). Figure 9(c) shows the supply voltage (v_{sabc}) which contains the sudden change with unbalances in it and the load current. So, after compensation of these unbalances, the load voltage can be seen free from distortions in it, as seen in Figure 9(d). After observing Figures 8 and 9, it is understood that said disturbances in the supply voltage have been compensated using DVR with the proposed control algorithm.

5.3 | Steady state performance of DVR during distortions in supply voltage


Figure 10 represents the performance of DVR in steady state when the supply voltage is distorted. The supply voltage ' v_{sab} ' has voltage magnitude 54.7 V, as shown in Figure 10(a), and their THD is at 7.4 %, as seen in Figure 10(b). However, the load voltage ' v_{Lab} ' has voltage magnitude 59.9 V, as shown in Figure 10(c), and its THD at 4.7 %, as seen in Figure 10(d). It is to be noted that steady state results are shown for phase 'a' only, as other two phases are analogous and found satisfactory. The steady state results shown in these figures ensure that DVR with the proposed control algorithm produced the results with THD under the standard limits. The summarized experimental performance of three single DVR with VFP-LMS based control is given in Table 2 under dynamic and steady state conditions.

6 | CONCLUSION


This paper illustrates the implementation of VFP-LMS control with SCO optimized PI gains for DVR control. The DVR compensation capability has been evaluated during the voltage sag,




(a) X-axis- 20 μ .sec/div, Y-axis Ch-1, 3: 100V/div, Ch-2: 50V/div, Ch-4: 5A/div.



(c) X-axis- 50 μ sec/div, Y-axis Ch-1,3: 100V/div, Ch-2: 50V/div, Ch-4: 5A/div.



(b) X-axis- 20 μ sec/div, Y-axis Ch-1,3: 100V/div, Ch-2: 50V/div, Ch-4: 5A/div.



(d) X-axis- 50 μ sec/div, Y-axis Ch-1,3: 100V/div, Ch-2: 50V/div, Ch-4: 5A/div.

FIGURE 8 Compensation of voltage sag: (a) Supply voltage (v_{sab}), compensating voltage (v_{ca}), load voltage (v_{Lab}), load current (i_{La}) and (b) supply voltage (v_{sab}), DC-link voltage (V_{dc}), load voltage (v_{Lab}), load current (i_{La}). Voltage swell compensation: (c) Supply voltage (v_{sab}), compensating voltage (v_{ca}), voltage (v_{Lab}), load current (i_{La}) and (d) supply voltage (v_{sab}), DC-link voltage (V_{dc}), load voltage (v_{Lab}), load current (i_{La})

TABLE 2 Test results of DVR with VFP-LMS based control algorithm

Parameter	Dynamic performance				Steady state performance (including % THD)	
	Sag	Swell	Distortions	Unbalance	Distortions	Unbalance
Supply voltage (v_{sab})	54.23 V	66.15 V	55.1 V	54.6 V	55.1 V, 7.4 %	54.6 V, 1.8 %
Supply voltage (v_{sab})	54.10 V	66.54 V	55.4 V	59.6 V	55.4 V, 7.4 %	59.6 V, 1.8 %
Supply voltage (v_{sab})	53.98 V	66.32	54.35 V	54.3 V	54.35 V, 7.5 %	54.3 V, 1.8 %
Load voltage (v_{Lab})	59.8 V	59.9 V	59.6 V	60.3 V	59.6 V, 4.7 %	60.3 V, 4.8 %
Load voltage (v_{Lab})	60.1 V	60.1 V	60.7 V	60.4 V	60.7 V, 4.6 %	60.4 V, 4.8 %
Load voltage (v_{Lab})	60.4 V	60.2 V	60.3 V	59.8 V	60.3 V, 4.8 %	59.8 V, 4.8 %
Load current (i_{La})	1.26 A	1.27 A	1.25 A	1.29 A	1.25 A, 2.7 %	1.29 A, 1.9 %
DC-link (V_{dc})	30 V	30 V	30 V	30 V	30 V	30 V

swell, distortions, and imbalances in the supply voltage with the three single-phase VSC based DVR configuration for compensation of mentioned voltage related disturbances. The proposed VFP-LMS control has successfully extracted the fundamental frequency components of non-ideal supplied voltage. Further,

extracted fundamental components of AC main are used for generating the load reference voltage. As discussed, implementation of SCO algorithm for PI controllers' gains tuning reduced the computational burden of overall control. The estimated PI controller gains of DC-PI and AC-PI are found to be 14.635,




FIGURE 9 Voltage distortions compensation: (a) Supply voltage (v_{sab}) along with load current of phase 'a' (i_{La}) and (b) load voltage (v_{Lab}) after compensation of distortions along with load current (i_{La}). Voltage imbalance compensation: (c) Supply voltage (v_{sab}) along with load current (i_{La}) and (d) load voltage (v_{Lab}) after in balance compensation along with load current (i_{La})




FIGURE 10 Steady state performance during distortions (a) supply voltage (v_{sa}) of phase 'a' (b) THD of (v_{sa}) (c) load voltage (v_{La}) of phase 'a', and (d) THD of (v_{La})

0.3199 and 31.684, 0.004, respectively, at eighth iterations. The dynamic and steady state performance of DVR is evaluated and it is discussed in this paper. The discussed performance has been organized in such a way that the understanding has become simple in the capability of the proposed control algorithm for DVR. The effective time response of DVR has been studied during unbalanced supply, from which it is found that DVR is having the capacity to compensate the unbalances effectively within half of the cycle, as shown in Figure 5. It has been also observed that DVR using VFP-LMS control with optimization-based PI tuning has produced the expected performance in all the cases of voltage disturbances in both simulation and experimental analysis.

List of Symbols

d	Dimension of variables to be tuned
$J_a()$	Cost function
N	Number of iterations
Symbol	Meaning
t	Unit templates
μ	Fractional power derivative
Z	Weight update
α, β, γ	Constant parameters
λ, λ_f	Step sizes
Γ	Gamma function

ACKNOWLEDGEMENTS

Authors are very much thankful to DST, SERB, Govt. of India for the grant of project under Science and Engineering Research Board -New Delhi Project (Scheme), Grant No. No.SB/S3/EECE/030/2016, DATED 17/08/2016.

ORCID

Talada Appala Naidu  <https://orcid.org/0000-0002-2199-8258>

P. Sanjeevikumar  <https://orcid.org/0000-0003-3212-2750>

REFERENCES

- Jain, S.: Power quality: An introduction. In *Modeling and Control of Power Electronics Converter System for Power Quality Improvements*, pp. 1–29. Academic Press, Cambridge, MA (2018)
- Bayliss, C.R., et al.: *Transmission and Distribution Electrical Engineering*. Elsevier, USA (2012)
- Padiyar, K.R.: *FACTS Controllers in Power Transmission and Distribution*, 1st ed., New Age International, New Delhi (2007)
- Liao, H., Milanovic, J.V.: On capability of different FACTS devices to mitigate a range of power quality phenomena. *IET Gener. Transm. Distrib.* 11(5), 1202–1211, (2016).
- Mihail Hristov, A.: Classical and recent aspects of active power filters for power quality improvement. In *Classical and Recent Aspects of Power System Optimization*, pp. 219–254. Academic Press, Cambridge, MA (2018)
- Singh, B., et al.: *Power Quality: Problems and Mitigation Techniques*. John Wiley & Sons, United Kingdom (2014)
- Pandya, R., Bhavsar, F.: Study on compensation of voltage sag and voltage swell by using DVR (Dynamic Voltage Restorer). In: *Proceedings of the IEEE International Conference on Current Trends towards Converging Technologies (ICCTCT)*, Coimbatore, 1–4 (2018)
- Kangarlu, M.F., et al.: A comprehensive review of dynamic voltage restorers. *Int. J. Electr. Power Energy Syst.* 92, 136–155 (2017)
- Li, Y.W., et al.: A dual-functional medium voltage level DVR to limit downstream fault currents. *IEEE Trans. Power Electron.* 22(4), 1330–1340 (2007)
- Jimichi, T., et al.: Design and experimentation of a dynamic voltage restorer capable of significantly reducing an energy-storage element. *IEEE Trans. Ind. Appl.* 44(3), 817–825 (2008)
- Jimichi, T., et al.: A dynamic voltage restorer equipped with a high-frequency isolated DC–DC converter. *IEEE Trans. Ind. Appl.* 47(1), 169–175 (Jan. 2011)
- Omar, R., Rahim, N.A.: Voltage unbalanced compensation using dynamic voltage restorer based on super capacitor. *Int. J. Electr. Power Energy Syst.* 43(1), 573–581 (2012)
- Galeshi, S., Eini, H.I.: Dynamic voltage restorer employing multilevel cascaded H-bridge inverter. *IET Power Electron.* 9(11), 2196–2204 (2016)
- Kim, S., et al.: Dynamic voltage restorer using switching cell structured multilevel AC-AC converter. *IEEE Trans. Power Electron.* 32(11), 8406–8418 (2017)
- Jirdehi, M.A., et al.: Multi objective stochastic microgrid scheduling incorporating dynamic voltage restorer. *Int. J. Electr. Power Energy Syst.* 93, 316–327 (2017)
- Jayaprakash, P., et al.: Control of reduced-rating dynamic voltage restorer with a battery energy storage system. *IEEE Trans. Ind. Appl.* 50(2), 1295–1303 (2014)
- Naidu, T.A., et al.: Phase locked loop based on third order SSI for compensation of voltage-related power quality issues using DVR. *J. Electr. Power Compon. Syst.* 47(4–5), 329–344 (2019)
- Leon, A.E., et al.: Control strategy of a DVR to improve stability in wind farms using squirrel-cage induction generators. *IEEE Trans. Power Syst.* 26(3), 1609–1617 (2011)
- Jothibasu, S., Mishra, M.K.: A control scheme for storage-less DVR based on characterization of voltage sags. *IEEE Trans. Power Deliv.* 29(5), 2261–2269 (2014)
- Abdul Rahman, S., et al.: Voltage sag and swell mitigation based on modulated carrier PWM. *Int. J. Electr. Power Energy Syst.* 66, 78–85 (2015)
- Torres, A.P., et al.: A two degrees of freedom resonant control scheme for voltage-sag compensation in dynamic voltage restorers. *IEEE Trans. Power Electron.* 33(6), 4852–4867 (2018)
- Priyavarthini, S., et al.: An improved control for simultaneous sag/swell mitigation and reactive power support in a grid-connected wind farm with DVR. *Int. J. Electr. Power Energy Syst.* 101, 38–49 (2018)

- Kwong, R.H., Johnston, E.W.: A variable step size LMS algorithm. *IEEE Trans. Signal Process.* 40(7), 1633–1642 (1992)
- Hwang, J.K., Li, Y.-P.: Variable step-size LMS algorithm with a gradient-based weighted average. *IEEE Signal Process Lett.* 16(12), 1043–1046 (2009)
- Ahmad, J., et al.: RVP-FLMS: A robust variable power fractional LMS algorithm. In: *Proceedings of the 6th IEEE International Conference on Control System, Computing and Engineering (ICCSCE)*, 494–497 (2016)
- Goodwin, G.C., et al.: *Control System Design*. Pearson Indian Education, Noida (2016)
- Du, K.-L., Swamy, M.N.S.: *Search and Optimization by Metaheuristics: Techniques and Algorithms Inspired by Nature*. Springer International, Switzerland (2016)
- Mirjalili, S.: SCA: A sine cosine algorithm for solving optimization problems. *J. Knowl.-Based Syst.* 96, 120–133 (2016)

How to cite this article: Naidu TA, Arya SR, Maurya R, Sanjeevikumar P. Variable fractional power-least mean square based control algorithm with optimized PI gains for the operation of dynamic voltage restorer. *IET Power Electronics*. 2020;1–14.
<https://doi.org/10.1049/pel2.12067>

APPENDIX

TABLE A1 System data used for simulation work

Sr. No	Parameter	Value
1.	AC grid (non-ideal)	440 V, 50 Hz
2.	Linear inductive Load	10 kVA, 0.8 p.f.
3.	Voltage at DC bus	300 V
4.	Injection transformer ratings	3 kVA, 2:1
5.	Filter (R_f , C_f)	2 Ω , 30 μF
6.	Interfacing inductor (L_i)	1.2 mH
7.	Value of capacitance at DC bus in μF	1200 μF
8.	Switching frequency of three leg voltage source converter	5 kHz
9.	VFP-LMS control algorithm parameters	$\lambda = 0.005$, $\lambda_f = 10e-6$, $\alpha = 0.9$, $\beta = 0.99$, and $\gamma = 0.5$

TABLE A2 System data used for experimental work

Sr. No	Parameter	Value
1.	AC grid (non-ideal)	60 V, 50 Hz
2.	Load current	1.25 A
3.	Voltage at DC bus	30 V
4.	Injection transformer ratings	4 kVA, 35:35
5.	Filter (R_f , C_f)	12 Ω , 100 μF
6.	Interfacing inductor (L_i)	1 mH
7.	Value of capacitance at DC bus in μF	4700 μF
8.	Sampling time	30 μs