



AALBORG UNIVERSITY
DENMARK

Aalborg Universitet

EnergyPLAN – Advanced Analysis of Smart Energy Systems

Lund, Henrik; Thellufsen, Jakob Zinck; Østergaard, Poul Alberg; Sorknæs, Peter; Skov, Iva
Ridjan; Mathiesen, Brian Vad

Published in:
Smart Energy

DOI (link to publication from Publisher):
[10.1016/j.segy.2021.100007](https://doi.org/10.1016/j.segy.2021.100007)

Creative Commons License
CC BY-NC-ND 4.0

Publication date:
2021

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Lund, H., Thellufsen, J. Z., Østergaard, P. A., Sorknæs, P., Skov, I. R., & Mathiesen, B. V. (2021). EnergyPLAN – Advanced Analysis of Smart Energy Systems. *Smart Energy*, 1, Article 100007. Advance online publication. <https://doi.org/10.1016/j.segy.2021.100007>


General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.



EnergyPLAN – Advanced analysis of smart energy systems

Henrik Lund^{a,*}, Jakob Zinck Thellufsen^a, Poul Alberg Østergaard^a, Peter Sorknæs^a,
Iva Ridjan Skov^b, Brian Vad Mathiesen^b

^a Aalborg University, Department of Planning, Rendsburggade 14, 9000, Aalborg, Denmark

^b Aalborg University, Department of Planning, A.C. Meyers Vænge 15, 2450, Copenhagen, Denmark



ARTICLE INFO

Article history:

Received 6 November 2020

Received in revised form

8 February 2021

Accepted 13 February 2021

Available online 2 March 2021

Keywords:

EnergyPLAN

Model description

Smart energy systems

Energy systems analysis

Energy modelling

ABSTRACT

EnergyPLAN is an energy system analysis tool created for the study and research in the design of future sustainable energy solutions with a special focus on energy systems with high shares of renewable energy sources. It has been under development since 1999 and has formed the basis for a substantial number of PhD theses and several hundreds of research papers. EnergyPLAN is designed to exploit the synergies enabled from including the whole energy system, as expressed in the smart energy system concept. Thus, with EnergyPLAN, the user can take a holistic approach focusing on the analysis of the cross-sectoral interaction. Traditionally disparate demand sectors, such as buildings, industry and transport, are linked with supply technologies through electricity, gas, district heating and cooling grids. In this way, EnergyPLAN enables the analysis of the conversion of renewable electricity into other energy carriers, such as heat, hydrogen, green gases and electrofuels, as well as the implementation of energy efficiency improvements and energy conservation. This article describes the overall structure of EnergyPLAN and the essential algorithms and computational structure.

© 2021 The Author(s). Published by Elsevier Ltd. This is an open access article under the CC BY-NC-ND license (<http://creativecommons.org/licenses/by-nc-nd/4.0/>).

1. Introduction

To minimise carbon dioxide emissions and thereby meet the Paris Agreement targets [1], energy systems must transition away from being predominantly fossil fuel-based to being based on renewable energy sources (RES). This is a transition away from freely dispatchable production units towards units employing resources that are frequently of a fluctuating and possibly use-it-or-lose-it nature. The robust planning and decision-making of such a transition and the study of the implications of different choices call for advanced tools to handle the increasingly complex nature of the energy system.

Currently, a wide range of computer tools allow users to model and analyse energy systems at the national and regional levels to help design transition pathways [2]. These models are often very different from one another [3], and therefore decision makers and researchers should choose the most suitable energy system modelling tool depending on the specific purpose and objectives of their analysis [4].

The three most common methodological approaches to energy

system modelling are optimisation, simulation and equilibrium tools or models. Optimisation tools include endogenous system design optimisation; simulation tools simulate exogenously defined energy systems, and equilibrium tools include a larger econometric model of the society.

Each approach has strengths as indicated by the main characteristic but also weaknesses. Thus, while optimisation tools are dominant within energy systems analysis [5], their complexity can cause difficulties in interpreting the results and can influence their accuracy [6]. In their systematic analysis investigating power system optimisation models, Priesmann and co-authors even found that the higher model complexity does not guarantee higher accuracy [7].

Likewise, it has been highlighted that uncertainties and variations in inputs for simulation models for low-carbon energy systems can have significant impact on the energy system performance [8].

Lastly, top-down equilibrium models have shown significant sensitivity when analysing the integration of RES and potentially need to be enhanced or be used as a part of integrated mixed models [9].

One example of a widely used simulation tool is the freeware EnergyPLAN. This is one of the most commonly used tools for the evaluation of energy systems with high shares of RES [10]. Some authors consider it the most suitable tool to identify a feasible RES

* Corresponding author.

E-mail address: lund@plan.aau.dk (H. Lund).

Abbreviations

BEV	Battery Electric Vehicle
CAES	Compressed Air Energy Storage
CEEP	Critical Excess Electricity Production
CSP	Concentrated Solar Power
EEEP	Exportable Excess Electricity Production
HP	Heat Pump
PP	Power Plant
PV	Photo Voltaic
PtX	Power-to-X
RES	Renewable Energy Source
V2G	Vehicle to Grid
VRES	Variable Renewable Energy Source

integration within an energy system, e.g., in China [11], Denmark [12] and Ireland [13].

Different aspects of EnergyPLAN have been described and communicated in the scientific literature as integrated sections of the many published articles employing it. However, due to the nature and complexity of EnergyPLAN, the individual papers have found neither the space nor the necessity to describe the overall structure and details of the tool, but have typically focused on the parts pertinent to the analyses at hand.

For a simulation tool as widely applied as EnergyPLAN, it is a significant gap in the scientific literature that there is no standard reference article describing it. Therefore, the aim of this paper is to provide this description in the hope that it will ease the writing and publication of studies applying EnergyPLAN in the future. More specifically, the goal of the paper is to demonstrate the core principles of EnergyPLAN and to document how it identifies the optimal operation of the units of the energy systems. This is based on both technical and economic simulation strategies.

The paper first describes the purpose and guiding principles behind the tool along with general characteristics; then it relates the tool to the context and approach of smart energy systems. Subsequently, the structure and essential equations and procedures of its simulation approach are documented and, finally, the main conclusions are drawn.

2. General characteristics and applications

This section presents the main purpose and characteristics of EnergyPLAN along with an overview of typical applications.

2.1. Purpose of EnergyPLAN

The main purpose of EnergyPLAN is to assist in the design of national energy planning strategies with technical and economic analyses of the consequences of different choices and investments. As further explained in Ref. [14], the purpose of EnergyPLAN is not to provide the basis for prescribing or predicting the future energy system, but rather to form a basis for an informed, transparent and conscious deliberation of potential development pathways for the energy system.

While the main motive for the development of EnergyPLAN was the national-scale energy systems, many other geographical scales have set the frame for EnergyPLAN analyses [10].

2.2. Guiding principles

The overarching guiding principle for the development and use

of EnergyPLAN is the establishment of alternatives; it was important to create a tool which would enable the consistent comparison of various alternative development strategies of the energy system. This is founded on the idea of *choice* [15], where an energy transition pathway is developed in a process with a conscious and transparent evaluation of the consequences of alternative strategies.

As a result, EnergyPLAN is developed with the capability for the user to consider alternative energy system combinations in mind, and as a consequence, also with speed, user friendliness and ease of implementing changes in mind.

Specifically regarding the establishment of scenarios, the guiding principle resulted in the following objectives [16]:

- **Character of technological change**

EnergyPLAN should enable the user to analyse the type of technological change which is required when transitioning to 100% renewable energy systems. To accommodate this, EnergyPLAN includes a variety of new technologies such as wave power, district heating and cooling, tidal power, concentrated solar power, thermal storage, biogas production, biomass gasification, and various Power-to-X technologies.

- **Multiple alternatives**

EnergyPLAN should enable the transparent and consistent comparison of multiple transition alternatives. Thus, EnergyPLAN is designed to quantify the impacts of many different alternatives, instead of producing just a single optimal solution through endogenous energy system design optimisation. It is often difficult to define one ideal metric to measure the benefits of energy systems [17]. For example, an inexpensive energy system that relies on a high proportion of energy imports may be less desirable than a more expensive energy system that utilises primarily domestic resources. Therefore, if an energy system is designed based on the optimal solution that produces the lowest cost, then other issues may be overlooked. Furthermore, long-term projections of, e.g., energy prices have shown to be prone to large uncertainties [18], making endogenous system designs equally uncertain. A scenario simulation can be completed in less than 10 s in EnergyPLAN with the implication that users can demonstrate the impacts of various alternatives in a relatively short period of time.

- **Free of institutional inertia**

Alternatives designed and analysed in EnergyPLAN should not be limited by existing institutional and market frameworks. This is particularly an issue within the electricity system, where some models are constructed based on the design of the day-ahead markets in current electricity markets. However, in the future energy system, the current design of electricity markets may not be suitable for 100% renewable energy systems, especially since renewable electricity technologies often have zero marginal production costs. To overcome this, EnergyPLAN has various operation strategies, including a market simulation strategy, which is based on the design of existing European electricity markets, and a technical simulation strategy. The technical simulation strategy is independent of market designs and temporal market prices and operates the energy system in order to minimise the consumption of fuels.

Under these objectives, EnergyPLAN has been developed and expanded on a continuous basis since 1999 by the Sustainable Energy Planning Research Group at Aalborg University.

2.3. Geographical scope and resolution

EnergyPLAN is primarily designed for national energy system analysis, and thus has been used to investigate energy systems and energy transitions in countries such as Germany [19], Denmark [20,21], Ireland [13], Norway [22], Hungary [23], Romania [24], Portugal [25], Singapore [26], Hong Kong [27] Jordan [28], Chile [29] and China [30]. However, to a large extent, it has also been applied to other geographical settings, such as islands like Gran Canaria [31], Pico and Faial [32] and Favignana Island [33] and cities like Aalborg [34] and Bozen-Bolzano [35]. Regions like Beijing-Hebei-Tianjin [36] and Inland Norway [37] as well as continents like Europe [38] have also been focal points of analyses.

Within the system (country, region or island) described in the model, EnergyPLAN simulates the electricity and the gas supplies with no spatial representation of supply and demand. The connection to the outside world is modelled as a single transmission line. However, by use of add-ons, one can build individual models of a number of countries or regions and analyse the electric transmission lines between them.

2.4. Type of applications

Besides forming the modelling basis for energy transition strategies, EnergyPLAN is also frequently applied in analyses covering the role of certain technologies or technological systems. This includes, but is not limited to: the role of Compressed Energy Storage [39] and hydro power in the energy system [22]; the role of biogas and biomass in the energy system [40,41]; the role of district heating [30,42] as well as heating infrastructures [43] in the energy system; heat pumps [44] and V2G [45] in the energy system; the energy system value of flexible electricity demands [46], future energy market prices [21,47,48] and market designs [49], as well as buildings and energy efficiency [50,51] and the comparison of integrated and non-integrated energy systems [52,53]. In general, the versatility of EnergyPLAN has led to a wide range of applications [54].

2.5. Sectorial aggregation

In the interest of speed – computational as well as in the setting up of models – EnergyPLAN is aggregated in its system description instead of modelling each individual station and component. District heating systems are, e.g., aggregated and defined as three principal technology groups and RES technologies are likewise aggregated into, e.g., one stock of wind turbines with a set of common characteristics. The same applies to, e.g., power stations and waste incineration plants as well as to all demands.

District heating is given particular attention; thus, three different types of district heating system may be modelled as they show different behaviours in the district heating system. These are:

1. District heating systems based on fuel boilers
2. District heating systems based on backpressure CHP plants
3. District heating systems based on extraction CHP plants

These three typologies are referred to as district heating Groups 1–3.

2.6. Fundamental modelling approach

EnergyPLAN uses what we denote “analytical programming”. Rather than establishing a series of balance equations that are solved numerically as in optimisation and equilibrium models, EnergyPLAN is based on a series of endogenous priorities within, e.g., power and heat production and pre-defined procedures for

simulating the operation of units that are freely dispatchable. The approach is purely deterministic with no stochastic elements.

As noted, EnergyPLAN simulates user-defined systems and does not make endogenous system optimisation. Various simulation strategies (see Section 3) determine the concrete optimisation criterion applied in an EnergyPLAN simulation (primary energy consumption, energy system balance, operational expenditure); however, in the design of scenarios, users can apply any of the outputs of EnergyPLAN or derivatives thereof. Thus, users have employed total system costs, renewable energy shares, employment generation, emissions and many more [10] in exogenous system optimisation.

Some users have combined EnergyPLAN with other tools for exogenous scenario design based on various objectives, e.g. Refs. [55–60]. Such work has, e.g., applied genetic algorithms to identify optimal scenarios based on multiple criteria.

2.7. Coding and execution

EnergyPLAN is programmed and maintained in Delphi Pascal. The tool along with manuals, reports and descriptions of algorithms in the tool are available from www.energyplan.eu. The training period required to use the tool can take from a few days up to a month, depending on the level of competency required.

EnergyPLAN is a freeware. Users can be involved on a semi open-source basis in which independent add-ons and help tools can be added. EnergyPLAN has a facility to include such add-ons based on any type of coding as long as they provide an exe-file. In the current version, EnergyPLAN includes several help tools. Moreover, the tool may be executed from other platforms such as Excel or MATLAB, which allows multi-execution [55,61].

2.8. Considerations regarding time

EnergyPLAN simulates a one leap-year time period in total; thus, for longer-spanning analyses, several simulations would have to be run. Within the one-year period, EnergyPLAN simulates the energy system on an hourly resolution level [11]. This entails that all demands and productions are exogenously defined using hourly time series.

The reason is that the integration of RESrenewable energy is a key focus for EnergyPLAN. Thus, it is important to adequately factor in associated intermittencies. The hourly simulation level that this requires is contrary to some scenario tools, which simulate the system on an annual basis or some optimisation tools that are based on time slicing, where hourly sample periods are identified for more in-depth analyses.

The hourly resolution allows the user to investigate hourly, daily, weekly and seasonal differences in electricity and heat demands and productions and, e.g., water inputs to large hydropower systems.

2.9. Grid stability

EnergyPLAN seeks the balance between electricity production and demand with an hourly resolution. Thus, active power and frequency stability are considered at this time step. Voltage stability and short-circuit power are not modelled explicitly; however, EnergyPLAN gives the user the option of requiring certain units to have a minimum production at all hours. This requires that in each hour, a minimum share of the power production comes from ancillary service-providing units, and that the share of each production category that should be interpreted as providing ancillary service should be defined. See e.g. Refs. [62,63] for analyses where this has been a focal point.

2.10. Inputs and outputs

Fig. 1 provides an overview of inputs as well as outputs of the model. EnergyPLAN comes with a graphical user interface in which the user can type in inputs and maintain an overview of the model.

Overall, the following input structure of EnergyPLAN refers to the aspects of an energy system:

- Energy demands (heat, electricity, transport, etc.)
- Energy production units and resources (wind turbines, power plants, oil boilers, storage, etc.) including energy conversion units such as electrolysers, biogas and gasification plants as well as hydrogenation units.
- Simulation (defining the simulation and operation of each plant and the system including technical limitations such as transmission capacity, etc.)
- Costs (fuel costs, exchange of electricity and gas, taxes, variable and fixed operational costs and investment costs)

The outputs produced by EnergyPLAN are energy balances and resulting annual productions, fuel consumption, import/export of electricity, and total costs including income from the exchange of electricity. With a temporal resolution of 1 hour, results can be presented down to this resolution as well. Through the export facility, the results can be imported into a spreadsheet for further investigation or illustration.

More immediately, results are presented in monthly and yearly overviews of production and demands within different technology categories as well as gas and electricity imports/exports. Yearly aggregates also include carbon dioxide emissions, money flows to/from an external electricity market and fuel consumption.

2.11. The smart energy systems approach of EnergyPLAN

EnergyPLAN has been developed in parallel with the concept of smart energy systems as defined in a series of papers [16,64–66].

The design of EnergyPLAN thus emphasises the option of looking at the complete energy system as a whole (see Fig. 2). E.g., the challenge of integrating variable RES-based power into the electricity grid by the use of smart grids should not be looked upon as an isolated issue, but should be seen as one out of various means and challenges of approaching sustainable energy systems in general. Therefore, EnergyPLAN is designed to be a tool in which, e.g., electricity smart grids can be coordinated with the utilisation of RES for other purposes than electricity production.

In EnergyPLAN, RES are converted into other forms of energy carriers than electricity via different power-to-x technologies, including heat, hydrogen, e-gases and electrofuels. EnergyPLAN can also model renewable energy systems by including different types of energy conservation and efficiency improvements, such as the cogeneration of heat and power (CHP) fuel cells.

All these measures have the potential to replace fossil fuels or improve the fuel efficiency of the system. The long-term relevant systems are those in which such measures are combined with energy conservation and system efficiency improvements. Consequently, EnergyPLAN can be used for analyses which illustrate, e.g., why electricity smart grids should be seen as part of overall smart energy systems.

Consequently, EnergyPLAN does not only calculate an hourly electricity balance, but also hourly balances of district heating, cooling, hydrogen and natural gas, including contributions from biogas, gasification as well as electrolysis and hydrogenation. Figs. 3–5 present a view of the production and conversion units involved in the balancing of the different grid structures.

3. Computational approach

This section details the computational core of EnergyPLAN focusing on how it simulates energy systems.

3.1. General computational strategy

As displayed in Fig. 6, the very first calculations are made as data is entered. E.g., if wind capacity is entered and an hourly wind distribution file is chosen from the library, EnergyPLAN will simultaneously calculate the annual and the hourly electricity production.

Afterwards (Stage 2 in Fig. 6), EnergyPLAN completes a number of initial computations which do not involve electricity balancing, such as the amount of heat provided by industry, the hourly demand of heat in the three district heating systems and the hourly non-flexible electricity demand.

Based on a user-specified simulation strategy, EnergyPLAN then branches: For the technical simulation (Stage 3A in Fig. 6 – See also section 3.2), EnergyPLAN identifies the least fuel-consuming solution, while for the market-economic simulation (Stage 3B in Fig. 6 – See also section 3.3), it identifies the consequences of operating each unit on the electricity market with the aim of optimising the business-economic profit.

For both simulation strategies, EnergyPLAN will finish by computing the socio-economic consequences of the system (total energy systems costs and carbon dioxide externality). As the entire calculation process only takes a few seconds, both simulation strategies can be easily completed and compared.

In the following, the technical and market-economic simulations are further detailed.

3.2. Technical simulation strategy

With the technical energy systems simulation strategy, the computation is carried out in the following steps as illustrated in Fig. 7. After each of the steps, a calculation is made of condensing mode power and import/export including CEEP and EEEP (Critical and Exportable Excess Electricity Production). The steps represent the calculation sequence and not necessarily the importance of each measure and technology.

Step 1. First, EnergyPLAN calculates the electricity and heat productions of the units in the district heating supply systems. As a start, all heat units are producing solely according to the heat demand, and these units are given priority on an hourly basis according to the following sequence:

1. Solar Thermal
2. Industrial excess heat incl. electrolysers and thermal gasification
3. Heat production from waste fuel
4. Heat plant CHP
5. Heat pumps
6. Peak load boilers

Hourly electricity productions from variable RES are already calculated in Stage two.

Step 2. Next, EnergyPLAN identifies the potential to utilise flexible electricity demand, if any, which is specified as an input. The electricity demand can either be made flexible, as specified in the next steps, or within short periods according to four time horizons. The user can choose to stipulate an annual demand that may be shifted within three timeframes – 24h, 1w or 4w – within a capacity constraint.

EnergyPLAN calculates the best use of flexible demands to achieve a balance between demand and supply with two

EnergyPLAN

INPUT

Demands
Electricity
Heating
Cooling
Industry
Transport
Desalination

Supply
Heat and electricity
Central Power prod.
Variable Renewables
Heat Only
Waste
Biotfuels
Biogases
Hydrogen
Electrofuels
Gas to Liquid

Balancing & Storage
Electricity storage
Thermal storage
Liquid and
Gas
Fuel storage
Hydrogen Storage
Compressed Air

Transport
Petrol/Diesel Vehicles
Gas Vehicles
Electric Vehicles
V2G Electric Vehicles
Hydrogen Vehicles
BiofuelVehicles

Electricity Market
Average prices
Price elasticity
Minimum and
Maximum prices

Fuel Cost & CO2
Fuel prices
Fuel handling costs
Fuel taxes
CO2 Emission Factor
CO2 Emission Costs

Technology Cost
Variable Operation
Fixed Operation
Investment
Interest Rate

Temporal distribution data library

Electricity Demand District Heating Wind Hydro Waste
Solarthermal Photovoltaic Geothermal Individual Heating
IndustrialCHP Transportation Market Prices Waste heat Etc....

EnergyPLAN Simulation Core

Either: Technical simulation strategies

- 1) Balancing heat demand
- 2) Balancing both heat and electricity demand

Or: Electricity market simulation strategy

Market simulation of plant optimization based on business economic marginal production costs.

And: Critical Excess Electricity Production

Reducing wind
Replacing CHP with boiler or heat pump
Electric heating and/or bypass

OUTPUT

Results
(Annual, Monthly and Hourly Values)

Electricity balance
Heating balance
Gas balance
Hydrogen balance
Biomass balance
Electrofuel balance
Import Expenditures
Export Revenues
Fuel Consumption
CO2 Emissions
Share of RES





Fig. 1. Data inputs and outputs of EnergyPLAN.




Fig. 2. The overall technology and flow model on which EnergyPLAN is based (adopted from Ref. [67]).

limitations: It must be positive at any time and it should be below the stipulated capacity constraint. A normalisation of the variation ensures that the average demand for the period equals the yearly average.

Step 3. As input, one can choose if the operation of CHP and heat pumps for district heating should seek to balance the electricity supply and demand of the overall system. If this strategy is chosen, the calculations of Step 1 are replaced by a strategy in which the export of electricity is minimised mainly by the use of heat pumps at CHP plants. This will simultaneously increase the electricity demand to the heat pumps and decrease the electricity production from CHP units, as the CHP units must decrease their heat production. By utilising unused capacity at the CHP plants in the given hour combined with heat storages, any production at condensing-mode plants is minimised and replaced by CHP production.

Step 4. Hydropower is then used for replacing the condensing-mode plants and decreasing, first, Critical Excess Electricity production (CEEP) and, secondly, Exportable Excess Electricity production (EEEP) in the following way: First, the potential of replacing the condensing-mode power plant ($e_{Hydro-Inc}$) is determined as the minimum value of the production of the condensing unit and the difference between hydropower capacity and hydropower production.

$$e_{Hydro-Inc} = \text{MIN} (e_{pp}, (C_{Hydro} - e_{Hydro}))$$

The hydro production, e_{Hydro} , is the production identified in

Stage 1. The potential to decrease hydropower in the case of CEEP ($e_{Hydro-Dec-CEEP}$) is determined as the minimum value of the CEEP and the hydropower production. At the same time, the potential is limited by the fact that the hydropower plant potentially forms part of grid stabilisation:

$$e_{Hydro-Dec-CEEP} = \text{MIN} (e_{CEEP}, e_{Hydro})$$

$$e_{Hydro-Dec-CEEP} \leq e_{Hydro} - e_{Hydro-Min-Grid-Stab}$$

In the case of reverse hydropower, i.e., a pump and both a lower and a higher water reservoir, the potential to further decrease CEEP ($e_{Hydro-Pump-Dec-CEEP}$) is determined as the minimum value of the CEEP (minus the share that is already dispatched), the pump capacity, and the content of the lower water storage, $S_{Hydro-PUMP}$:

$$e_{Hydro-Pump-Dec-CEEP} = \text{MIN} [(e_{CEEP} - e_{Hydro-Dec-CEEP}), C_{Hydro-PUMP}, S_{Hydro-PUMP} / \mu_{Hydro-PUMP}]$$

In the same way, the potential to decrease hydropower in the case of EEEP ($e_{Hydro-Dec-EEEP}$) is found. Knowing the potentials to increase and decrease the hydropower production, a balance is found in which the annual hydropower production is maintained. The reduction of CEEP is given priority over the reduction of EEEP.

$$\Sigma e_{Hydro-Inc} = \Sigma e_{Hydro-Dec-CEEP} + \Sigma e_{Hydro-Dec-EEEP}$$

The hydropower production (e_{Hydro}) is modified in accordance




Fig. 3. Units involved in EnergyPLAN's simulation of the hourly balancing of the District Heating and Cooling system including interactions with other parts of the entire system. In EnergyPLAN, district heating is divided into three separate systems: One for boiler-only systems; one for small CHP systems, and one for large extraction CHP plant-based systems.

with the generator capacity, the hourly distribution of the water supply, and the storage capacity in the following way:

$$\text{Hydro storage content} = \text{Hydro storage content} + w_{\text{Hydro}}$$

$$e_{\text{Hydro}} = e_{\text{Hydro}} + e_{\text{Hydro-Inc}} - e_{\text{Hydro-Dec-CEEP}} - e_{\text{Hydro-Dec-EEEP}}$$

$$e_{\text{Hydro-Input}} \leq (\text{Hydro storage content} - S_{\text{Hydro}}) * \mu_{\text{Hydro}}$$

$$e_{\text{Hydro-Input}} \leq C_{\text{Hydro}}$$

Differences in the storage content at the beginning and at the end of the calculation period may cause errors in the calculations. To correct these errors, the above calculation seeks to identify a solution in which the storage content at the end is the same as at the beginning. Initially, the storage content is defined as 50% of the




Fig. 4. Units involved in EnergyPLAN's simulation of the hourly balancing of the Electricity system including interactions with other parts of the whole system.




Fig. 5. Units involved in EnergyPLAN's simulation of the hourly balancing of the gas system including interactions with other parts of the whole system.

storage capacity. After the first iteration, a new initial content is defined as the resulting content at the end of the calculation. However, one may as input specify a start and end value of the hydro storage. In this case, these values will be used.

Step 5. The calculations of individual CHP and heat pump systems are based on the computation in Stage 1 in which solar thermal (if

any) is given priority. If heat storage capacity is specified, EnergyPLAN will exploit the option of using the electricity productions and demands of these units to balance the electricity supply and demand of the overall system. This will update the productions on the individual CHP and heat pump systems.

Step 6. Four electrolyser systems are described in the model. Two




Fig. 6. Overall structure of the energy system simulation procedures.

of these are systems which are assumed to be located next to the district heating based on backpressure units and extraction plants, respectively, along with the CHP units, heat pumps and boilers. Here, the waste heat production of the electrolyzers can be utilised in the district heating supply. The two other systems produce hydrogen for micro CHP systems or for transport and hydrogenation. The electrolyser is assumed to be a hydrolyser (producing hydrogen), but it may be used for modelling any kind of equipment converting electricity into fuel and heat.

The calculation is based on the result of the Stage 1 calculation in which the minimum capacity of the electrolyser is identified together with the electricity demand, d_{ElcM} . EnergyPLAN seeks to avoid CEEP/EEEP and condensing-mode power generation by reorganising the production. First, the potential to increase the production at hours of excess production, $d_{\text{ElcM-inc-pot}}$, is identified as the lower value of CEEP and the difference between the capacity, C_{ElcM} , and the production of the electrolyser:

$$d_{\text{ElcM-inc-pot}} = \text{Min} [e_{\text{CEEP}}, (C_{\text{ElcM}} - d_{\text{ElcM}})]$$

Secondly, the potential to decrease production at hours of power-only production, $d_{\text{ElcM-dec-pot}}$, is identified as the minimum of the power production, e_{PP} , and the electrolyser demand:

$$d_{\text{ElcM-dec-pot}} = \text{Min} [e_{\text{PP}}, d_{\text{ElcM}}]$$

Then a balance is created in which either the potential to increase or the potential to decrease is lowered to achieve the same level as that of the annual potentials:

$$\text{If } D_{\text{ElcM-dec-pot}} > D_{\text{ElcM-inc-pot}} \text{ then } d_{\text{ElcM-dec-pot}} = d_{\text{ElcM-dec-pot}} * D_{\text{ElcM-inc-pot}} / D_{\text{ElcM-dec-pot}}$$

$$\text{If } D_{\text{ElcM-inc-pot}} > D_{\text{ElcM-dec-pot}} \text{ then } d_{\text{ElcM-inc-pot}} = d_{\text{ElcM-inc-pot}} * D_{\text{ElcM-dec-pot}} / D_{\text{ElcM-inc-pot}}$$

A new optimal temporal distribution of the electrolyser electricity demand (producing exactly the same annual fuel as before) is calculated as:

$$d_{\text{ElcM}} = d_{\text{ElcM}} - d_{\text{ElcM-dec-pot}} + d_{\text{ElcM-inc-pot}}$$

Finally, the temporal distribution is evaluated against the hydrogen storage capacity. First, the changes in storage content are calculated.

If the storage content based on this calculation is below zero, the production of the electrolyser is increased.

If the storage content exceeds the storage capacity, the production of the electrolyser is decreased.

Step 7. Thermal storage in district heating systems is used to improve the possibilities for minimising the electricity export. The heat storage capacity is included in the model for each of the district heating groups 2 and 3. The storage capacities are used for minimising the excess and condensing mode power generation in the system.

Step 8. Electric vehicles including the concept of vehicle to grid (V2G) can be operated with smart charge as well as smart discharge. One important input is the hourly distribution of the transport demand (δ_{V2G}), which is used for two purposes. One is to determine the number of V2G battery electric vehicles which are driving and consequently not connected to the grid in the hour in question. This, together with the $\text{V2G}_{\text{Max-Share}}$ (the maximum share of V2G battery electric vehicles which are driving during peak demand hour) and the $\text{V2G}_{\text{Connection-Share}}$, determines the fraction of the V2G fleet that is available to the electrical system in any given hour. The other purpose of defining δ_{V2G} is to determine the discharging of the battery storage caused by driving. The hourly transport demand, and thereby the discharging of the battery (t_{V2G}), is calculated as follows:

$$t_{\text{V2G}} = [D_{\text{V2G}} * \delta_{\text{V2G}} / \sum \delta_{\text{V2G}}] * \eta_{\text{CHARGE}}$$

The grid connection capacity of the total V2G fleet on an hourly basis (c_{V2G}) is calculated as follows:

$$c_{\text{V2G}} = C_{\text{Charger}} * \text{V2G}_{\text{Connection-Share}} * ((1 - \text{V2G}_{\text{Max-Share}}) + \text{V2G}_{\text{Max-Share}} * (1 - \delta_{\text{V2G}} / \text{Max}(\delta_{\text{V2G}})))$$

This equation includes three factors. The first factor is C_{Charger} , the power capacity of the entire V2G fleet. This is multiplied by $\text{V2G}_{\text{Connection-Share}}$, the fraction of the parked vehicles which is assumed to be plugged. The third factor, in parentheses, calculates the fraction of vehicles on the road in each hour. The third parenthesised factor is based on the sum of two terms. The first term, $(1 - \text{V2G}_{\text{Max-Share}})$, represents the minimum fraction of vehicles parked. The second term is the additional fraction of vehicles parked during non-rush hours. The hourly fraction of vehicles parked is derived from the known input of hourly energy demand for the fleet. This equation yields c_{V2G} , the power capacity of all connected V2G




Fig. 7. Graphical representation of Stage 3A: Technical Simulation Strategy in EnergyPLAN.

vehicles, in any given hour. For each hour, the model calculates as follows.

The V2G battery electric vehicles will charge in the case of available excess electricity production (e_{CEEP}) and available battery energy capacity ($SV_{2G-Battery} - SV_{2G-Battery}$) within the limitations of the power capacity of the grid connection (C_{V2G}) for that particular hour. Thus, the equation is the minimum of three values:

$$e_{Charge} = \min [e_{CEEP}, (SV_{2G-Battery} - SV_{2G-Battery}) / \mu_{Charge}, C_{V2G}]$$

Moreover, as mentioned above, the charging is forced in the case in which the transport demands of the present and the next “y” hours cannot be supplied by the battery content. Initially, the “y” value is set to 1 h. If this leads to lack of battery content, the value is raised in steps of 1 h.

The minimum battery content needed is calculated:

$$SV_{2G-Battery-min} = \sum_{a+y}^{x-a} t_{V2G}$$

Then, the charging of the battery is adjusted accordingly, by requiring that:

$$e_{Charge} \geq [SV_{2G-battery} - SV_{2G-Battery-min}] / \mu_{Charge}$$

If e_{Charge} becomes higher than the capacity of the grid connection, C_{V2G} , the number of hours, y, is raised by one, and the calculations start again. The new battery content is then calculated by adding the above charging and subtracting the discharging caused by driving (t_{V2G}):

$$SV_{2G-Battery} := SV_{2G-Battery} - t_{V2G} + (e_{Charge} * \mu_{Charge})$$

The V2G battery electric vehicles are simulated supplying the grid in the case of a potential replacement of production from power plants (e_{PP}) and available stored electricity in the battery after the supply of the transport demand:

$$e_{Inv} = \min [e_{PP}, ((SV_{2G-Battery} - SV_{2G-Battery-min}) * \mu_{Inv}), C_{V2G}]$$

The resulting new battery content is then calculated as follows

$$SV_{2G-Battery} := SV_{2G-Battery} - (e_{Inv} / \mu_{Inv})$$

Similar to the description for the hydropower energy storage, the above calculation is repeated until the storage content at the end is the same as at the beginning.

Step 9. The electricity storage is described in the model as a hydro storage consisting of the following components:

- Pump (converting electricity to potential energy) defined by a capacity and an efficiency
- Turbine (converting potential energy to electricity) defined by a capacity and an efficiency
- Storage (storing energy) defined by a capacity.

However, this hydro storage can be used for modelling any kind of electricity storage, for example batteries. The simulation of the storage is used solely to avoid critical excess electricity production. The storage facility is regulated in the following way:

The pump is used for charging the storage in the case of critical excess production, $e_{CEEP} > 0$. In this case, the available capacity in the storage ($SC_{AES} - S_{CAES}$) is calculated and the electricity demand of the pump (e_{Pump}) is identified as the minimum value of the

following three values:

- e_{CEEP} , the critical excess production
- $(SC_{AES} - S_{CAES}) / \alpha_{Pump}$ available storage capacity divided by the pump efficiency
- C_{Pump} , the maximum capacity of the pump.

If $e_{CEEP} > 0$ then $e_{Pump} := \min [e_{CEEP}, (SC_{AES} - S_{CAES}) / \alpha_{Pump}, C_{Pump}]$

$$S_{CAES} = S_{CAES} + e_{Pump} / \alpha_{Pump}$$

The turbine is used for discharging the storage, first by replacing import and then power plant production if $e_{PP} > 0$. In this case, the content of the storage (S_{CAES}) is identified and the electricity production of the turbine ($e_{Turbine}$) is identified as the minimum value of the following three parameters:

- e_{import} , e_{PP} , electricity import or electricity production of the power plant, respectively
- $S_{CAES} * \mu_{Turbine}$, storage content multiplied by turbine efficiency
- $C_{Turbine}$, the maximum capacity of the turbine.

If $e_{import} > 0$ then $e_{Turbine1} := \min [e_{import}, S_{CAES} * \mu_{Turbine}, C_{Turbine}]$

If $e_{PP} > 0$ then $e_{Turbine2} := \min [e_{PP}, S_{CAES} * \mu_{Turbine}, (C_{Turbine} - e_{Turbine1})]$

$$e_{Turbine} = e_{Turbine1} + e_{Turbine2}$$

$$S_{CAES} = S_{CAES} - e_{Turbine} / \mu_{Turbine}$$

Similar to the description for the hydropower and the V2G energy storage, the above calculation is repeated until the storage content at the end of the year is the same as at the beginning.

Step 10. As a final step, a number of measures to reduce Critical Excess Electricity Production, e_{CEEP} , are calculated depending on the input specification in which one can choose between:

- 1 Reducing renewable electricity productions from wind, photo voltaic, wave power, etc.
- 2 Reducing CHP production by replacing with peak load fuel-based boilers
- 3 Replacing fuel-based boiler production with electric heating
- 4 Increasing CO₂ hydrogenation
- 5 Part-loading nuclear power generation (otherwise nuclear is simulated following an exogenously given temporal distribution curve)

It is possible for the user to prioritise these measures.

3.3. Market economic simulation strategy

If market-economic simulation is chosen (see Fig. 6), EnergyPLAN distinguishes between business economy (including taxes) and socio-economy (not including taxes). Basically, EnergyPLAN seeks the least-cost solution of operating the system, assuming an electricity market in which all plant operators seek to optimise their business-economic profit. The market-economic modelling is based on the identification of the electricity market price at each hour resulting from the demand and supply of electricity. Moreover, the exact production level of the various units at which the resulting market price becomes equal to the marginal production price is identified. Similarly, marginal consumption prices are found for electricity-consuming units such as heat pumps and

electrolysers. The net import is identified as the difference between the electricity demand, d_{Total} , and the supply, e_{Total} . The market price on the external market, p_X , is found as follows:

$$p_X = p_i + (p_i / p_o) * \text{FaC}_{\text{depend}} * d_{\text{Net-Import}}$$

where p_i is the system market price.

$\text{FaC}_{\text{depend}}$ is the price elasticity (Currency/MWh/MW)
 p_o is the basic price level for price elasticity (input),
 $d_{\text{Net-Import}}$ is the trade on the market.

Import is calculated as positive and export as negative, resulting in an increase in the market price in the case of import and a decrease in the case of export.

The production level of a certain unit at which the resulting market price becomes equal to the marginal production price is identified as an integrated part of the procedure. Here, the calculation is illustrated by the example of the geothermal power plant.

First, the net-import, $d_{\text{Net-Import}}$, is calculated as well as the market price, p_X , when the electricity production of the geothermal power plant is zero. Then, the balance production is calculated as follows:

$$\text{BalanceProduction}_{\text{Geothermal}} = - [(\text{VEPP}_{\text{Geothermal}} - p_X) / (\text{FaC}_{\text{depend}} * p_X / p_o) - d_{\text{Net-Import}}]$$

where $\text{VEPP}_{\text{Geothermal}}$ is the marginal production cost of geothermal power production.

p_X is the market price before geothermal production
 $\text{FaC}_{\text{depend}}$ is the price elasticity (Currency/MWh/MW)
 p_o is the basic price level for price elasticity (input)
 $d_{\text{Net-Import}}$ is the trade on the market before geothermal production

The equation is typically subject to the limitations on power plant capacity.

The user may stipulate whether the transmission line capacity should limit $d_{\text{Net-Import}}$ or not. If EnergyPLAN is set to 'Transmission capacity limits the effect on the system price', then $d_{\text{Net-Import}}$ will be limited to the transmission line capacity of the system, in absolute values. If EnergyPLAN is set to "Transmission capacity does not limit the effect on the system price", then the transmission line capacity does not limit $d_{\text{Net-Import}}$.

The simulation is done in the following steps as illustrated in Fig. 8:

Step 1. The hourly prices on an external electricity market is defined as an input. The fluctuations of the market prices are presented as an hourly distribution file for a year. The influence of import/export on the external market prices is given in terms of a dependence factor (price elasticity and a basic price level for the price elasticity). When the business-economic best operation strategy is identified for each plant in the following, the influence on the market price is taken into consideration.

Step 2. All marginal production costs are calculated on the basis of fuel costs, taxes, CO₂ costs and variable operational costs. For units connected to district heating plants (such as CHP and heat pumps), power stations and individual micro CHP, marginal costs are given in currency/MWh of electricity production/consumption. Currency can be chosen by the user, e.g. DKK or EUR. For storage units such as hydrogen CHP and pump storage systems, marginal costs are given according to a multiplication factor together with an addition factor. Basically, the simulation criterion is the following:

$$p_{\text{sell}} > p_{\text{buy}} * f_{\text{MUL}} + f_{\text{ADD}}$$

In which p_{sell} is the market electricity price when selling (Currency/MWh)

p_{buy} is the market electricity price when buying (Currency/MWh)

f_{MUL} is the multiplication factor (always higher than 1).

f_{ADD} is the addition factor (Currency/MWh)

Step 3. As a starting point for the simulation, the electricity system prices are calculated on the basis of:

- the electricity demand including flexible demand (calculated as described above)
- the production from RES

The production from RES is potentially affected by the "RES influence on system electricity price" setting, which has two options:

- "Zero bidding price (RES can stop)": When using this option, the Variable RES electricity production will be curtailed at negative system electricity market prices.
- "Negative bidding prices (RES cannot stop)": When using this option, the Variable RES will not be curtailed due to negative electricity market prices.

As a starting point, all district heating is defined as supplied by boilers. The sequence of optimising the individual plant type aggregation is then identified by the subsequent procedure.

Step 4. The least-cost solutions of buying the minimum amount of electricity needed to meet the following demands are identified, given the market price fluctuations and limitations on storage capacities, etc.:

- for producing hydrogen for transport
- for charging electric vehicles
- for producing hydrogen for micro-CHP systems

When identifying the least-cost solution for the hydrogen micro-CHP systems, the option of producing heat with a boiler using less hydrogen than the CHP unit is considered in situations of high electricity prices.

In the case of smart charge EV and V2G (Vehicle to Grid) possibilities, the optimal business-economic solutions of buying and selling are found on the basis of the multiplication and addition factors identified as an input.

Step 5. The following electricity-consuming options are sorted according to marginal consumption costs:

- replacing boiler with heat pumps in district heating Group 2
- replacing boiler with heat pumps in district heating Group 3
- replacing boiler with electrolysers in district heating Group 2
- replacing boiler with electrolysers in district heating Group 3
- replacing electric heating with heat pumps in individual houses
- replacing boiler with electric boiler in district heating Group 2
- replacing boiler with electric boiler in district heating Group 3
- producing steam for high-temperature thermal storage if the electricity price is lower than the cost of fuel for condensing-mode power generation and power generation at the extraction-mode CHP in DH Group 3 taking efficiencies into account.




Fig. 8. Graphical representation of Stage 3B: Market-Economic Simulation Strategy in EnergyPLAN.

Each option is then optimised according to market electricity prices, by starting with the option with the highest marginal costs and taking into consideration the fact that each change in consumption influences the market price (increases the price).

Step 6. Then, the best business-economic production from concentrated solar power (CSP) is identified taking into consideration limitations on storage and generator capacities, and a similar calculation is done for hydropower. In the case of pumped hydro

storage possibilities, the optimal business-economic solution of buying and selling is identified.

Step 7. The following electricity production options are then sorted according to the lowest marginal costs of production:

- Nuclear
- Geothermal
- Condensing-mode power plants

- Individual small-scale CHP units
- Individual biomass CHP
- CHP replacing boilers in district heating Group 2
- CHP replacing boilers in district heating Group 3
- CHP replacing heat pumps in district heating Group 2
- CHP replacing heat pumps in district heating Group 3
- CHP replacing electrolyzers in district heating Group 2
- CHP replacing electrolyzers in district heating Group 3

Each option is then optimised according to market electricity prices, starting with the option with the lowest marginal costs and taking into consideration the fact that each change in consumption influences the market price (decreases the market price). Limitations on transmission lines are taken into consideration by setting a limit on the production of each unit, so that the total export will not exceed the transmission capacity (if possible). Limitations on import are calculated with regard to the condensing power plants, which will simply be activated in the case that the import transmission capacity is exceeded.

Step 8. The optimal business-economic solution of buying and selling is identified on the basis of the above-mentioned multiplication and addition factors.

Step 9. In order to calculate the impact on the simulation of the consumption units after the market price is influenced by the production options, the procedure from Steps 3 to 8 is repeated.

Step 10. Any critical excess production is removed following the technical simulation procedure Step 10 as described in Section 3.2.

4. Summary and conclusion

In line with the objectives set out for the tool, EnergyPLAN enables the user to make consistent and comparative analyses of energy systems based on renewable energy, fossil fuels, and nuclear power. The tool considers all sectors of the energy system (electricity, heat, industry and transport) and includes a wide variety of technologies. Furthermore, EnergyPLAN makes it possible to quickly complete the modelling without losing coherence for a large variety of systems including current systems (which are based on fossil fuel production) as well as those with radical technological changes (such as 100% renewable energy systems).

EnergyPLAN is a freeware with a long record of active use. It involves independent add-ons and help tools and it may be executed from other platforms such as Excel or MATLAB, which enables multi-execution. In addition, it can calculate the hourly operation of an energy system to ensure that supply and demand are reliably matched, even with the introduction of intermittent renewable energy.

With EnergyPLAN, the modeller can also differentiate between a technical simulation, which ignores existing electricity market constructions and price levels, and a market-economic simulation, which can be adjusted using taxes. For both simulations, the tool can calculate the costs of the total system divided into investments costs, operation costs, fuel costs, CO₂ costs and other taxes. Hence, EnergyPLAN can create data for further analysis of socio-economic feasibility studies, such as the balance of payment and job creation. It is freely available for download along with detailed documentation about its operation, which enables its functionality and methodologies to be freely debated and improved.

Compared to other models, the main advantages of EnergyPLAN are the ability to model the entire system with all sectors, the aggregation of units into representative units limiting the data requirement, the ability to quickly simulate a user-defined scenario, the transparency in how scenarios are developed, the 1h temporal

simulation step and the ability to simulate an entire year with seasonal variations.

The limitations of EnergyPLAN to some extent mirror the advantages. With a focus on the entire system and with the aggregation employed in EnergyPLAN, the detailed operation of individual units are not captured. Likewise, the exogenous and transparent system design (and resulting fast computational time) comes at the expense of larger requirements of the user; thus, some experience is required to identify favourable scenarios.

EnergyPLAN's appropriateness is dependent on the individual user's objectives. EnergyPLAN is particularly suitable if the main objective is to analyse the impact of long-term alternatives, particularly in relation to renewable energy, and where distinct scenarios are analysed without endogenous system optimisation. Other tools can often be used in combination with EnergyPLAN if there are additional objectives that need to be met when completing an energy system analysis.

Lastly, EnergyPLAN is undergoing continuous development to always be able to meet the modelling requirements of future energy systems. Currently, the model is being improved in its ability to identify suitable flexible use of electrolyzers as well as in its ability to properly handle different assumptions on how variable renewable electricity productions influence negative electricity market prices.

Declaration of competing interestCOI

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgement

This work received funding from the SENTINEL project of the European Union's Horizon 2020 research and innovation programme under grant agreement No 837089, and the RE-Invest project which is supported by the Innovation Fund Denmark under grant agreement No 6154-00022B.

References

- [1] United Nations. Framework Convention on Climate change [UNFCCC]. Paris agreement. Paris, France: United Nations. 2015. FCCC/CP/2015/L.9.
- [2] Dagoumas AS, Koltsaklis NE. Review of models for integrating renewable energy in the generation expansion planning. *Appl Energy* 2019;242: 1573–87. <https://doi.org/10.1016/j.apenergy.2019.03.194>.
- [3] Oberle S, Elsland R. Are open access models able to assess today's energy scenarios? *Energy Strat Rev* 2019;26:100396. <https://doi.org/10.1016/j.esr.2019.100396>.
- [4] Connolly D, Lund H, Mathiesen BV, Leahy M. A review of computer tools for analysing the integration of renewable energy into various energy systems. *Appl Energy* 2010;87:1059–82. <https://doi.org/10.1016/j.apenergy.2009.09.026>.
- [5] Ringkjøb HK, Haugan PM, Solbrekke IM. A review of modelling tools for energy and electricity systems with large shares of variable renewables. *Renew Sustain Energy Rev* 2018;96:440–59. <https://doi.org/10.1016/j.rser.2018.08.002>.
- [6] Lopion P, Markewitz P, Robinius M, Stolten D. A review of current challenges and trends in energy systems modeling. *Renew Sustain Energy Rev* 2018;96: 156–66. <https://doi.org/10.1016/j.rser.2018.07.045>.
- [7] Priesmann J, Nolting L, Praktiknjo A. Are complex energy system models more accurate? An intra-model comparison of power system optimization models. *Appl Energy* 2019;255:113783. <https://doi.org/10.1016/j.apenergy.2019.113783>.
- [8] Pilpola S, Lund PD. Analyzing the effects of uncertainties on the modelling of low-carbon energy system pathways. *Energy* 2020;201:117652. <https://doi.org/10.1016/j.energy.2020.117652>.
- [9] Tapia-Ahumada K, Octaviano C, Rausch S, Pérez-Arriaga I. Modeling intermittent renewable electricity technologies in general equilibrium models. *Econ Model* 2015;51:242–62. <https://doi.org/10.1016/j.econmod.2015.08.004>.
- [10] Østergaard PA. Reviewing EnergyPLAN simulations and performance indicator

- applications in EnergyPLAN simulations. *Appl Energy* 2015;154:921–33. <https://doi.org/10.1016/j.apenergy.2015.05.086>.
- [11] Liu W, Lund H, Mathiesen BV. Large-scale integration of wind power into the existing Chinese energy system. *Energy* 2011;36:4753–60. <https://doi.org/10.1016/j.energy.2011.05.007>.
- [12] Connolly D, Mathiesen BV. A technical and economic analysis of one potential pathway to a 100% renewable energy system. *Int J Sustain Energy Plan Manag* 2014;1:7–28. <https://doi.org/10.5278/ijsepm.2014.1.2>.
- [13] Connolly D, Lund H, Mathiesen BV, Leahy M. The first step towards a 100% renewable energy-system for Ireland. *Appl Energy* 2011;88:502–7. <https://doi.org/10.1016/j.apenergy.2010.03.006>.
- [14] Lund H, Arler F, Østergaard PA, Hvelplund F, Connolly D, Mathiesen BV, et al. Simulation versus optimisation: theoretical positions in energy system modelling. *Energies* 2017;10:1–17. <https://doi.org/10.3390/en10070840>.
- [15] Lund H. *Renew Energy Syst 2010*. <https://doi.org/10.1016/C2009-0-20259-5>.
- [16] Lund H. *Renewable energy systems - a smart energy systems approach to the choice and modeling of 100% renewable solutions*. second ed. Academic Press; 2014.
- [17] Østergaard PA. Reviewing optimisation criteria for energy systems analyses of renewable energy integration. *Energy* 2009;34:1236–45. <https://doi.org/10.1016/j.energy.2009.05.004>.
- [18] Lund H, Sorknæs P, Mathiesen BV, Hansen K. Beyond sensitivity analysis: a methodology to handle fuel and electricity prices when designing energy scenarios. *Energy Res Soc Sci* 2018. <https://doi.org/10.1016/j.erss.2017.11.013>.
- [19] Hansen K, Mathiesen BV, Skov IR. Full energy system transition towards 100% renewable energy in Germany in 2050. *Renew Sustain Energy Rev* 2019;102:1–13. <https://doi.org/10.1016/j.rser.2018.11.038>.
- [20] Nielsen S, Sorknæs P, Østergaard PA. Electricity market auction settings in a future Danish electricity system with a high penetration of renewable energy sources – a comparison of marginal pricing and pay-as-bid. *Energy* 2011;36:4434–44. <https://doi.org/10.1016/j.energy.2011.03.079>.
- [21] Sorknæs P, Djørup SR, Lund H, Thellufsen JZ. Quantifying the influence of wind power and photovoltaic on future electricity market prices. *Energy Convers Manag* 2019;180:312–24. <https://doi.org/10.1016/j.enconman.2018.11.007>.
- [22] Askeland K, Bozhkova KN, Sorknæs P. Balancing Europe: can district heating affect the flexibility potential of Norwegian hydropower resources? *Renew Energy* 2019;141:646–56. <https://doi.org/10.1016/j.renene.2019.03.137>.
- [23] Sáfarián F. Modelling the Hungarian energy system - the first step towards sustainable energy planning. *Energy* 2014;69:58–66. <https://doi.org/10.1016/j.energy.2014.02.067>.
- [24] Gota DI, Lund H, Miclea L. A Romanian energy system model and a nuclear reduction strategy. *Energy* 2011;36:6413–9. <https://doi.org/10.1016/j.energy.2011.09.029>.
- [25] Fernandes L, Ferreira P. Renewable energy scenarios in the Portuguese electricity system. *Energy* 2014;69:51–7. <https://doi.org/10.1016/j.energy.2014.02.098>.
- [26] Ali H, Sanjaya S, Suryadi B, Weller SR. Analysing CO2 emissions from Singapore's electricity generation sector: strategies for 2020 and beyond. *Energy* 2017;124:553–64. <https://doi.org/10.1016/j.energy.2017.01.112>.
- [27] Ma T, Østergaard PA, Lund H, Yang H, Lu L. An energy system model for Hong Kong in 2020. *Energy* 2014;68. <https://doi.org/10.1016/j.energy.2014.02.096>.
- [28] Novosel T, Čosić B, Krajačić G, Duić N, Pukšec T, Mohsen MS, et al. The influence of reverse osmosis desalination in a combination with pump storage on the penetration of wind and PV energy: a case study for Jordan. *Energy* 2014;76:73–81. <https://doi.org/10.1016/j.energy.2014.03.088>.
- [29] Paardekooper S, Lund H, Chang M, Nielsen S, Moreno D, Thellufsen JZ. *Heat Roadmap Chile: a national district heating plan for air pollution decontamination and decarbonisation*. *J Clean Prod* 2020;272.
- [30] Xiong W, Wang Y, Mathiesen BV, Lund H, Zhang X. Heat roadmap China: new heat strategy to reduce energy consumption towards 2030. *Energy* 2015;81:274–85. <https://doi.org/10.1016/j.energy.2014.12.039>.
- [31] Cabrera P, Lund H, Carta JA. Smart renewable energy penetration strategies on islands: the case of Gran Canaria. *Energy* 2018;162:421–43. <https://doi.org/10.1016/j.energy.2018.08.020>.
- [32] Alves M, Segurado R, Costa M. On the road to 100% renewable energy systems in isolated islands. *Energy* 2020;198:117321. <https://doi.org/10.1016/j.energy.2020.117321>.
- [33] Groppi D, Astiaso Garcia D, Lo Basso G, De Santoli L. Synergy between smart energy systems simulation tools for greening small Mediterranean islands. *Renew Energy* 2019;135:515–24. <https://doi.org/10.1016/j.renene.2018.12.043>.
- [34] Thellufsen JZ, Lund H, Sorknæs P, Østergaard PA, Chang M, Drysdale D, et al. Smart energy cities in a 100% renewable energy context. *Renew Sustain Energy Rev* 2020;129. <https://doi.org/10.1016/j.rser.2020.109922>.
- [35] Menapace A, Thellufsen JZ, Pernigotto G, Roberti F, Gasparella A, Righetti M, et al. The design of 100% renewable smart urban energy systems: the case of Bozen-Bolzano. *Energy* 2020. <https://doi.org/10.1016/j.energy.2020.118198>.
- [36] Yuan M, Thellufsen JZ, Lund H, Liang Y. The first feasible step towards clean heating transition in urban agglomeration: a case study of Beijing-Tianjin-Hebei region. *Energy Convers Manag* 2020. <https://doi.org/10.1016/j.enconman.2020.113282>.
- [37] Hagos DA, Gebremedhin A, Zethraeus B. Towards a flexible energy system – a case study for Inland Norway. *Appl Energy* 2014;130:41–50. <https://doi.org/10.1016/j.apenergy.2014.05.022>.
- [38] Connolly D, Lund H, Mathiesen BV. Smart Energy Europe: the technical and economic impact of one potential 100% renewable energy scenario for the European Union. *Renew Sustain Energy Rev* 2016;60:1634–53. <https://doi.org/10.1016/j.rser.2016.02.025>.
- [39] Lund H, Salgi G. The role of compressed air energy storage (CAES) in future sustainable energy systems. *Energy Convers Manag* 2009;50:1172–9.
- [40] Kwon PS, Østergaard PA. Priority order in using biomass resources - energy systems analyses of future scenarios for Denmark. *Energy* 2013;63. <https://doi.org/10.1016/j.energy.2013.10.005>.
- [41] Lund R, Mathiesen BV. Large combined heat and power plants in sustainable energy systems. *Appl Energy* 2015;142:389–95. <https://doi.org/10.1016/j.apenergy.2015.01.013>.
- [42] Thellufsen JZ, Nielsen S, Lund H. Implementing cleaner heating solutions towards a future low-carbon scenario in Ireland. *J Clean Prod* 2019. <https://doi.org/10.1016/j.jclepro.2018.12.303>.
- [43] Lund H. Renewable heating strategies and their consequences for storage and grid infrastructures comparing a smart grid to a smart energy systems approach. *Energy* 2018;151. <https://doi.org/10.1016/j.energy.2018.03.010>.
- [44] Hedegaard K, Mathiesen BV, Lund H, Heiselberg P. Wind power integration using individual heat pumps - analysis of different heat storage options. *Energy* 2012;47. <https://doi.org/10.1016/j.energy.2012.09.030>.
- [45] Lund H, Kempton W. Integration of renewable energy into the transport and electricity sectors through V2G. *Energy Pol* 2008;36:3578–87. <https://doi.org/10.1016/j.enpol.2008.06.007>.
- [46] Kwon PSPS, Østergaard P. Assessment and evaluation of flexible demand in a Danish future energy scenario. *Appl Energy* 2014;134:309–20. <https://doi.org/10.1016/j.apenergy.2014.08.044>.
- [47] Djørup S, Thellufsen JZ, Sorknæs P. The electricity market in a renewable energy system. *Energy* 2018;162:148–57. <https://doi.org/10.1016/j.energy.2018.07.100>.
- [48] Sorknæs P, Lund H, Skov IR, Djørup S, Skytte K, Morthorst PE, et al. Smart Energy Markets - future electricity, gas and heating markets. *Renew Sustain Energy Rev* 2020;119. <https://doi.org/10.1016/j.rser.2019.109655>.
- [49] Nielsen S, Sorknæs P, Østergaard PA. Electricity market auction settings in a future Danish electricity system with a high penetration of renewable energy sources - a comparison of marginal pricing and pay-as-bid. *Energy* 2011;36. <https://doi.org/10.1016/j.energy.2011.03.079>.
- [50] Drysdale D, Mathiesen BV, Paardekooper S. Transitioning to a 100% renewable energy system in Denmark by 2050: assessing the impact from expanding the building stock at the same time. *Energy Effic* 2019. <https://doi.org/10.1007/s12053-018-9649-1>.
- [51] Lund H, Thellufsen JZ, Aggerholm S, Wichtten KB, Nielsen S, Mathiesen BV, et al. Heat saving strategies in sustainable smart energy systems. *Int J Sustain Energy Plan Manag* 2014;3–16. <https://doi.org/10.5278/ijsepm.2014.4.2>.
- [52] Bačeković I, Østergaard PA. A smart energy system approach vs a non-integrated renewable energy system approach to designing a future energy system in Zagreb. *Energy* 2018;155. <https://doi.org/10.1016/j.energy.2018.05.075>.
- [53] Bačeković I, Østergaard PA. Local smart energy systems and cross-system integration. *Energy* 2018;151:812–25. <https://doi.org/10.1016/j.energy.2018.03.098>.
- [54] Hansen K, Breyer C, Lund H. Status and perspectives on 100% renewable energy systems. *Energy* 2019;175:471–80. <https://doi.org/10.1016/j.energy.2019.03.092>.
- [55] Mahbub MS, Cozzini M, Østergaard PA, Alberti F. Combining multi-objective evolutionary algorithms and descriptive analytical modelling in energy scenario design. *Appl Energy* 2016;164:140–51. <https://doi.org/10.1016/j.apenergy.2015.11.042>.
- [56] Viesi D, Crema L, Mahbub MS, Veronesi B, Brunelli R, Baggio P, et al. Integrated and dynamic energy modelling of a regional system: a cost-optimized approach in the deep decarbonisation of the Province of Trento (Italy). *Energy* 2020;209. <https://doi.org/10.1016/j.energy.2020.118378>.
- [57] Prina MG, Cozzini M, Garegnani G, Moser D, Oberegger UF, Vaccaro R, et al. Smart energy systems applied at urban level: the case of the municipality of Bressanone-Brixen. *Int J Sustain Energy Plan Manag* 2016;10:33–52. <https://doi.org/10.5278/ijsepm.2016.10.4>.
- [58] Prina MG, Cozzini M, Garegnani G, Manzolini G, Moser D, Filippi Oberegger U, et al. Multi-objective optimization algorithm coupled to EnergyPLAN software: the EPLANopt model. *Energy* 2018;149:213–21. <https://doi.org/10.1016/j.energy.2018.02.050>.
- [59] Prina MG, Moser D, Vaccaro R, Sparber W. EPLANopt optimization model based on EnergyPLAN applied at regional level: the future competition on excess electricity production from renewables. *Int J Sustain Energy Plan Manag* 2020;27. <https://doi.org/10.5278/ijsepm.3504>.
- [60] Prina MG, Lionetti M, Manzolini G, Sparber W, Moser D. Transition pathways optimization methodology through EnergyPLAN software for long-term energy planning. *Appl Energy* 2019;235:356–68. <https://doi.org/10.1016/j.apenergy.2018.10.099>.
- [61] Cabrera P, Lund H, Thellufsen JZ, Sorknæs P. The MATLAB Toolbox for EnergyPLAN: a tool to extend energy planning studies. *Sci Comput Program* 2020;191:102405. <https://doi.org/10.1016/j.scico.2020.102405>.
- [62] Pillai JR, Heussen K, Østergaard PA. Comparative analysis of hourly and dynamic power balancing models for validating future energy scenarios. *Energy* 2011;36. <https://doi.org/10.1016/j.energy.2011.03.014>.
- [63] Østergaard PA. Ancillary services and the integration of substantial quantities of wind power. *Appl Energy* 2006;83. <https://doi.org/10.1016/j.apenergy.2005.04.007>.

- [64] Mathiesen BV, Lund H, Connolly D, Wenzel H, Østergaard PA, Möller B, et al. Smart Energy Systems for coherent 100% renewable energy and transport solutions. *Appl Energy* 2015;145. <https://doi.org/10.1016/j.apenergy.2015.01.075>.
- [65] Lund H, Andersen AN, Østergaard PA, Mathiesen BV, Connolly D. From electricity smart grids to smart energy systems - a market operation based approach and understanding. *Energy* 2012;42:96–102. <https://doi.org/10.1016/j.energy.2012.04.003>.
- [66] Lund H, Mathiesen BV, Connolly D, Østergaard PA, Vad Mathiesen B, Connolly D. Renewable energy systems - a smart energy systems approach to the choice and modelling of 100 % renewable solutions. *Chem Eng Trans* 2014;39:1–6. <https://doi.org/10.3303/CET1439001>.
- [67] Lund H, Thellufsen JZ. EnergyPLAN - advanced energy systems analysis computer model. 2020. <https://doi.org/10.5281/zenodo.4017214>. Version 15.1.