

Optimal operation of stand-alone microgrid considering emission issues and demand response program using whale optimization Algorithm

Tahmasebi, Mehrdad; Pasupuleti, Jagadeesh; Mohamadian, Fatemeh; Shakeri, Mohammad; Guerrero, Josep M.; Basir Khan, M. Reyesudin; Nazir, Muhammad Shahzad; Safari, Amir; Bazmohammadi, Najmeh

Published in:
Sustainability (Switzerland)

DOI (link to publication from Publisher):
[10.3390/su13147710](https://doi.org/10.3390/su13147710)

Creative Commons License
CC BY 4.0

Publication date:
2021

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Tahmasebi, M., Pasupuleti, J., Mohamadian, F., Shakeri, M., Guerrero, J. M., Basir Khan, M. R., Nazir, M. S., Safari, A., & Bazmohammadi, N. (2021). Optimal operation of stand-alone microgrid considering emission issues and demand response program using whale optimization Algorithm. *Sustainability (Switzerland)*, 13(14), Article 7710. <https://doi.org/10.3390/su13147710>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -






Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Downloaded from vbn.aau.dk on: December 05, 2025

Article

Optimal Operation of Stand-Alone Microgrid Considering Emission Issues and Demand Response Program Using Whale Optimization Algorithm

Mehrdad Tahmasebi ^{1,*}, Jagadeesh Pasupuleti ^{2,*}, Fatemeh Mohamadian ³, Mohammad Shakeri ² ,
Josep M. Guerrero ⁴ , M. Reyasudin Basir Khan ⁵ , Muhammad Shahzad Nazir ⁶ , Amir Safari ⁷
and Najmeh Bazmohammadi ⁴ 

¹ Department of Electrical Engineering, Ilam Branch, Islamic Azad University, Ilam, Iran

² Institute of Sustainable Energy, Universiti Tenaga Nasional (The National Energy University),
Jalan IKRAM-UNITEN, Kajang 43000, Malaysia; mshakeri@uniten.edu.my

³ Electronic Instructor, Technical and Vocational Training Organization, Tehran 1345653868, Iran;
fatemehmohamadian123@yahoo.com

⁴ Center for Research on Microgrids (CROM), Department of Energy Technology, Aalborg University,
9220 Aalborg East, Denmark; joz@et.aau.dk (J.M.G.); naj@et.aau.dk (N.B.)

⁵ School of Engineering, Manipal International University, No. 1, Persiaran MIU,
Nilai 71800, Malaysia; mohammed.reyasudin@miu.edu.my

⁶ Faculty of Automation, Huaiyin Institute of Technology, Huai'an 223003, China; nazir@hyit.edu.cn

⁷ Faculty of Technology & Natural Sciences, University of South-Eastern Norway, USN,
3616 Kongsberg, Norway; amir.safari@usn.no

* Correspondence: mtahmasebi@ilam-iau.ac.ir (M.T.); Jagadeesh@uniten.edu.my (J.P.)



Citation: Tahmasebi, M.; Pasupuleti, J.; Mohamadian, F.; Shakeri, M.; Guerrero, J.M.; Basir Khan, M.R.; Nazir, M.S.; Safari, A.; Bazmohammadi, N. Optimal Operation of Stand-Alone Microgrid Considering Emission Issues and Demand Response Program Using Whale Optimization Algorithm. *Sustainability* **2021**, *13*, 7710. <https://doi.org/10.3390/su13147710>

Received: 13 May 2021

Accepted: 25 June 2021

Published: 9 July 2021

Publisher's Note: MDPI stays neutral with regard to jurisdictional claims in published maps and institutional affiliations.



Copyright: © 2021 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

Abstract: Microgrids are new technologies for integrating renewable energies into power systems. Optimal operation of renewable energy sources in standalone micro-grids is an intensive task due to the continuous variation of their output powers and intermittent nature. This work addresses the optimum operation of an independent microgrid considering the demand response program (DRP). An energy management model with two different scenarios has been proposed to minimize the costs of operation and emissions. Interruptible/curtailable loads are considered in DRPs. Besides, due to the growing concern of the developing efficient optimization methods and algorithms in line with the increasing needs of microgrids, the focus of this study is on using the whale meta-heuristic algorithm for operation management of microgrids. The findings indicate that the whale optimization algorithm outperforms the other known algorithms such as imperialist competitive and genetic algorithms, as well as particle swarm optimization. Furthermore, the results show that the use of DRPS has a significant impact on the costs of operation and emissions.

Keywords: microgrid; optimization management; operation; emission; demand response program; whale optimization algorithm

1. Introduction

Recently, due to the high reliability, and the growing penetration of the distributed energy resources systems (DERS) into the power systems [1–3], a new concept called microgrid, which attracted a variety of researchers has been introduced [4,5]. A microgrid which can be explained as a low-voltage network with loads and different small-scale production systems can generate the demanded heat and power of the local loads. Increasing the usage of renewable energy sources (RESS) has led to an increase in the need for lateral services i.e., spinning reserve, frequency regulation, and controlling ramp rates, which practically increase the operation cost [6]. In this sense, it is worth mentioning that DRP is an important tool in the planning and operation of microgrids. DRP can change the electrical energy consumption from the normal pattern of consumers' power demand

following the electricity price changes at different times, or also to pay incentives for lower energy consumption in cases with the high wholesale power price or compromised system's reliability [7]. DRP with the ability to correct the consumption pattern can play a key role in energy supply and balance consumption and production [8]. Therefore, considering the active and effective role of microgrids in a restructured power system, planning and optimal energy management in the new environment require extensive research and analysis. In this regard, this research addresses the optimum management of a microgrid in the presence of DERs and DRPS to reduce costs of operation and emission using the whale optimization algorithm (WOA) method. The simulation findings indicate that the WOA has a high competitive ability in comparison to the existing meta-heuristic algorithms in terms of optimization answers, convergence speed, and presenting the result more sensibly. It has also been determined that the use of DRPS has a significant impact on the costs of operation and emissions. This paper is categorized as follows, Section 2 discusses a literature review of the demand response programs in the microgrid. Section 3 discusses the problems and objectives of the proposed algorithm. It will be followed by demand response model, optimization methods, case of study, results, and finally the conclusion. Tables 1 and 2 are the list of acronyms and list of symbols respectively.

Table 1. List of acronyms.

Symbol	Meaning
WOA	Whale optimization algorithm
DER	Distributed energy resources
DRP	Demand response program
EDRP	Emergency demand response program
PSO	Particle swarm optimization
GA	Genetic algorithm
ICA	Imperialist competitive algorithm
RES	Renewable energy sources
TOU	Time of use
DG	Diesel generator
MT	Micro turbine
FC	Fuel cell
WT	Wind turbine
PV	Photovoltaic

Table 2. List of symbols.

Abbreviation	Meaning
$CC(t)$	Operation cost function
$W1, W2$	The weight coefficient of operation cost and emission cost functions
$P_i(t)$	The output power of the i-th distributed generation resource in the period t
$\pi_i(t)$	The proposed price of the i-th distributed generation resource in the period t
$I_i(t)$	On and off status of the i-th distributed generation resource in the period t
$SU_i(t)$	The cost of starting up and shutting down the i-th distributed generation resource in the period t
$C_j^{DR}(t)$	The cost of demand reduction caused by the j-th demand response program in period t.
J	The number of demand response programs
X	The vector of variables including power output of resources and the power of charging and discharging of the battery

Table 2. Cont.

Abbreviation	Meaning
EMIDG(t) ine NDG	Emission cost function The number of distributed generations
$E_{CO_2}^{DG}, E_{SO_2}^{DG}, E_{NOX}^{DG}$	The amount of co2,so2,nox pollutants caused by the i-th distributed generation resources
π_c, Π_s, Π_N	The prices of co2,so2,nox pollutants caused by the i-th distributed generation resources
Pi DG(t)	The total power generated by distributed generation resources
$P_i^{DG}(t)$	The power of the i-th distributed generation resource
Pdemand(t)	The amount of consumed power in the period t
PDR(t)	The amount of active power participating in the demand response program
I(i, t)	The on/off mode of the i-th resource in the period t
RP(r, t), CP(c, t), IP(i, t)	The cost of payment to residential, commercial, and industrial consumers in the period t, respectively
IC(i, t), CC(c, t), RC(r, t)	The amount of the planned load reduction by each of the residential, commercial, and industrial consumers in the period t
$\zeta_{r,t}, \zeta_{i,t}, \zeta_{c,t}$	The number of incentive payments to each consumer in the period t
$RC_t^{\max}, CC_t^{\max}, IC_t^{\max}$	The maximum amount of the load-reduction offered by each consumer in the period t
Wess (t), Wess (t−1)	The amount of stored energy suffices the battery at current and previous times
Pcharge, Pdischarge	The amount of charge and discharge power of the battery
$\eta_{charge}, \eta_{discharge}$	The battery efficiency at the charge and discharge times
Icharge, Idischarge	Battery charge and discharge status
Pw (Vwind)	Wind turbine power
Vwind, Vci, Vr, Vco	Average wind speed, Wind turbine cut-in speed, Wind turbine nominal speed, Wind turbine cut-off speed
Pr	Wind turbine nominal power
Tcy	Cell temperature in Celsius
Kv	The coefficient of thermal voltage in volts per degree Celsius
Ki	Coefficient of flow temperature in amperes per degree Celsius
NOT	Nominal operating temperature of the cell
Isc	Short circuit current
Psy	Cell output power
Say	The average solar radiation intensity in kW per square meter
IMPP, VMPP	Current and voltage maximum powerpoint
FF	Filling factor
N	The number of solar cells
\vec{x}	The location vector
X^*	The location vector of the best current answer
\vec{X}_{rand}	An accidental location vector
t	Recent repetition

Table 2. Cont.

Abbreviation	Meaning
\vec{A}, \vec{C}	Multiplier vectors
\vec{r}	A random vector in $[0, 1]$
P, L	Random numbers in $[0, 1]$, $[-1, 1]$ respectively
B	A fixed value to describe the form of logarithmic helix
D'	The distance of the i-th whale to the hunt

2. Literature Review

In this section, numerous studies that have been performed on the exploitation of microgrids in literature are reviewed. In [9], modeling various types of DRPs is considered in terms of the price elasticity of demand and the idea of customer profit. Besides, the DRPs implementation effect on the operation of grid-associated microgrids is studied. Furthermore, various scenarios are provided to model the different sources of uncertainties in microgrids, i.e., generation components failure, random outages of upstream line and transmission lines, error in predicting load demand, ambiguity in producing renewable-based (solar and wind) distributed generation components, and the likelihood of not responding the customers to the arranged disruptions. The optimum operation of a microgrid in a grid-connected state has been studied in [10]. DRPS are utilized in this work considering time-of-use (TOU), price schemes, and emergency demand response programs (EDRPs). The combined integer linear programming is utilized for simulation purposes. In [11], a new reserve scheduling and stochastic energy management technique is provided for a microgrid considering different kinds of DRPS. In the suggested method, all kinds of commercial, industrial and residential customers can take part in DRPS including either reserve or energy scheduling.

Similarly, modeling the ambiguities associated with the RESs is performed through appropriate probability distribution functions as they are controlled by reserve offered by the distributed load and generations. Daily optimum scheduling problem of the networked microgrids regarding the intermittent nature of the load and generation is studied in the proposed energy management system (EMS) in [12]. The optimum scheduling model, which is a combination of RTP and TOU price schemes of DRPs is solved utilizing a meta-heuristic algorithm considering ambiguities of renewable energy sources and loads. Grid peak-shaving utilizing peak-time rebate structure demand response for microgrid energy administration is provided in [13]. The highest profit for the microgrid with DRP such as manageable loads, diesel generators, and battery storage is obtained with this approach. This approach results in optimum microgrid energy management. This results in a lower cost of the main grid in comparison to other peak-shaving traditional programs. The peak-time rebate structure includes peak-time rebate incentive rewards and manageable loads demand response participation. In [14], a microgrid with RESs and fuel/battery micro-turbine, via the help of the multi-purpose algorithm adaptively modified particle swarm optimization (AMPSO), has been used. In its formularization, a non-linear model was used aiming at minimizing the cost and emission of the greenhouse gases, simultaneously. In [15], modeling an intelligent park microgrid is considered as containing photovoltaic (PV) power generation, integrated cooling/heating, and power system, responsive loads, and energy storage systems. The goal is to investigate the optimum operation approach of these components by considering the price-oriented demand reaction. In this sense, an enhanced model for the microgrid's economic operation is made which chiefly aims at minimizing the microgrid's operating cost and making complete utilization of clean energy regarding demand response and the distributed power generation. The genetic algorithm (GA) is used to solve this optimizing problem. Besides, the DRP and the clean energy utilization strategy determine the best solution for the best operation approach.

In [16], the authors provide a multi-objective optimization model to achieve the Pareto solutions taking into account both the emission and generation fuel costs. Nevertheless, both methods may lead to high financial and environmental costs. The concurrent arrangement of electrical vehicles and responsive loads is studied in [17] to decrease the emission and operation cost by the existing PV and wind powers in a microgrid. The suggested technique uses the electrical vehicles for peak-shaving and modifying the load curve while employing the responsive loads to meet the reserves required for compensating the intrinsic ambiguities of PV and wind powers. Additionally, an established two-stage model is suggested in order to determine the microgrid's anticipated operation cost. The effect of the participation level of customers in EDRP and the influence of illogical incentive values in the implementation of EDRP on the operation of the microgrid are provided in [18]. Microgrid operation is investigated in [19] from a technical point of view. An economic operation approach for a grid-linked microgrid is suggested in [20] to minimize the operation cost for the operation course of 24 h ahead. In [21], the optimal power is calculated requiring a generation by the units in a microgrid to minimize the entire generation cost at the consumer's premises and enhance to minimize the entire generation cost at the consumer's premises and enhance the system's steady-state condition. In this paper, the scheduling optimization problem in microgrids, including operating and emissions costs, is studied while considering DRPs. Besides, technical, economic, and environmental issues of the microgrid are taken into account. The optimization problem is solved utilizing the WOA in the MATLAB environment. The results show that the WOA outperforms particle swarm optimization (PSO), imperialist competitive algorithm (ICA), and GA in solving the microgrid scheduling problem. It has also been determined that the use of DRPS has a significant impact on the costs of operation and emissions. In [9], energy management strategies (EMS) and system optimization were reviewed for wind energy and a stand-alone photovoltaic system combined with fuel cells. By integrating the system enhancement and EMS ARE, it is not common to discourse them separately in terms of system-level design.

Hence, this study deals with a discussion on the general optimization formulation framework and the categorization and reviewing a different kind of optimizing technique.

The impact of implementing the Time-of-Use Demand Response Program (TOU-DRP) on a separated microgrid was analyzed in [22] by taking into account various capacities of the installed wind power with and without energy storage unit. In this sense, various levels of participation of the customers in TOU-DRP, its impacts on operation cost, wind power spillage, and the unserved energy are comprehensively examined. In [23], optimal energy setting up of a stand-alone microgrid under system ambiguities is assessed and, then, numerous operational strategies are examined to study the system performance. The suggested optimization energy management system is mainly aimed at improving the energy use efficiency and also, decreasing the system fuel cost and gas emissions decrease through designing generations of energy resources every hour for the next day. To minimize the created emission and operation costs, the system is modeled as a constrained single-objective optimization problem. The objective in [24] is a techno-economic analysis of energy, optimal sizing as well as a cost-effective stand-alone multi-carrier microgrid. In this regard, a long-term planning approach is stated considering reliability considerations and battery degradation. Using particle swarm optimization, the optimization problem is solved. In [25], the interconnected microgrids' operation is concentrated. In energy management, a step-wise demand response program (DRP) is taken into account to obtain a cost-effective operation. Moreover, for the power exchange between the interconnected microgrids, a novel pricing model is presented in terms of microgrid marginal pricing. In [26], provided a novel hybrid microgrid energy management strategy, which includes demand response and internal power market with multiple market configurations. This planning consists of interactions between incentive strategies, microgrids, and consumers. This is a stochastic linear programming technique with emission, demand cost and microgrid cost as the objective functions, where energy price, loads, wind speed and solar radiation

considered as undefined factors. Microgrid system renewable energy resources economic, environmental and reliability benefits are evaluated in [27]. This research focused on improving microgrid system green technologies benefits by minimizing annual load loss cost, cost of energy, life-cycle GHG emission cost and life-cycle cost. Operational model of microgrid consists of different generation resources connected to grid is developed in [28]. The suggested technique is solved with set of Pareto solutions obtained using weighted sum method. ELECTRE and paired comparison matrix technique resulted in operator preferences best operation status. Hybrid AC/DC microgrids including multiple fuel options scheduling algorithm is discussed in [29]. Particle swarm optimization multi-objective function consists of gas emission and operational cost.

3. Problem Description

3.1. Objective Function

The general objective function in terms of the operation cost and the emission cost which is defined as Equation (1), is the combination of the above functions [23].

$$\text{MinF} = w_1 \cdot f_1 + w_2 \cdot f_2 \quad (1)$$

where f_1 is the operation cost function and f_2 is the emission cost function. w_1 and w_2 which are the weight coefficients of each of these functions, specify the optimization priority. The operation cost function (f_1) is defined by Equations (2) and (3).

$$\text{CC}(t) = \sum_{i=1}^{N_{DG}} [P_i(t)\pi_i(t)I_i(t) + \text{SU}_i(t)|I_i(t) - I_i(t-1)|] + \sum_{j=1}^J C_j^{\text{DR}}(t) \quad (2)$$

$$f_1(x) = \sum_{t=1}^T \text{CC}(t) \quad (3)$$

The emission cost function involves the pollution cost caused by DERs. The considered pollutants include CO_2 [30], SO_2 [31], and NO_x and the mathematical model of the emission cost function is defined according to Equation (4). Besides, the average cost of pollution resultant from non-renewable units is determined according to Equation (5).

$$f_2(X) = \sum_{t=1}^T [\text{EMI}_{DG}(t)] \quad (4)$$

$$\text{EMI}_{DG}(t) = \sum_{i=1}^{N_{DG}} \left(E_{\text{CO}_2}^{DG}(i) \times \pi_c + E_{\text{SO}_2}^{DG}(i) \times \pi_s + E_{\text{NO}_x}^{DG}(i) \times \pi_N \right) \times P_i^{DG}(t) \quad (5)$$

3.2. Constraints

3.2.1. Power Balance Constraint

The entire power generated by DERs and the demand reduction caused by DRP in each interval should be equivalent to the entire demand.

$$\sum_{i=1}^{N_{DG}} P_{DG,i}(t) = P_{\text{Demand}}(t) - P_{\text{DR}}(t) \quad (6)$$

$P_{\text{DR}}(t)$ is the amount of active power participating in DRP defined according to Equation (7).

$$P_{\text{DR}}(t) = \sum_r \text{RC}(r,t) + \sum_c \text{CC}(c,t) + \sum_i \text{IC}(i,t) \quad (7)$$

3.2.2. Minimum and Maximum Generated Power

The minimum and maximum power generated by each unit are limited by Equation (8). The limitation of solar and wind power generation also depends on the nominal capacity of these sources and the amount of radiation intensity and forecasted wind speed. The constraints on the power generation capacity of these resources are set out in Equations (9) and (10).

$$P_i^{\min I_{i,t} P_{i,t} P_i^{\max t} \gamma_{i,t} i_{i,t}} \quad (8)$$

$$0 \leq P_{PV,t} \leq P_{sy,t} \quad (9)$$

$$0 \leq P_{WIND,t} \leq P_{w,t} \quad (10)$$

3.2.3. Battery System Constraints

Equation (11) indicates the battery capacity, which can vary depending on the amount of charge and discharge energy per hour for the next hour. Equation (12) indicates that battery can only be discharged or charged at any time. In Equations (13)–(15), $W_{ess,min}$ and $W_{ess,max}$ show the minimum and the maximum amount of battery stored energy; $P_{charge}(t)$, $P_{charge,max}$ are the amount of battery charge power in the period t and maximum battery charge power; $P_{discharge}(t)$, $P_{discharge,max}$ are the amount of battery discharge power in the period t and maximum battery discharge power, respectively [32].

$$W_{ess}(t) = W_{ess}(t-1) - \frac{1}{\eta_{discharge}} I_{discharge}(t) P_{discharge}(t) + \eta_{charge}(t) I_{charge}(t) P_{charge}(t) \quad (11)$$

$$I_{discharge}(t) + I_{charge}(t) \leq 1 \quad (12)$$

$$W_{ess,min} \leq W_{ess}(t) \leq W_{ess,max} \quad (13)$$

$$P_{charge}(t) \leq P_{charge,max} \quad (14)$$

$$P_{discharge}(t) \leq P_{discharge,max} \quad (15)$$

3.2.4. Wind and Solar Power Relations

Equation (16) determines the power of WT [33,34]. Besides, Equations (17)–(21) represent the power of the PV system.

$$P_w(V_{wind}) = \begin{cases} 0 & V_{wind} < V_{ci} \\ P_R \frac{(V_{wind} - V_{ci})}{(V_r - V_{ci})} & V_{ci} \leq V_{wind} < V_r \\ P_R & V_r \leq V_{wind} < V_{co} \\ 0 & V_{wind} \geq V_o \end{cases} \quad (16)$$

$$T_{cy} = T_A + s_{ay} \left(\frac{N_{OT} - 20}{0.8} \right) \quad (17)$$

$$I_y = s_{ay} [I_{sc} + K_i (T_c - 25)] \quad (18)$$

$$V_y = V_{oc} - K_v^* T_{cy} \quad (19)$$

$$P_{sy}(s_{ay}) = N^* FF^* V_y^* I_y \quad (20)$$

$$FF = \frac{V_{MPP}^* I_{PP}}{V_c^* I_{sc}} \quad (21)$$

4. Demand Response Model

In this model [33], the load is classified into 3 types, i.e., residential (RC), commercial (CC), and industrial consumers (IC). DRP is based on the price packages and incentives to the customers for load reduction. The cost of incentive payment to residential, commercial, and industrial consumers due to load reduction in the period t is formulated in the following equations. Moreover, constraints express that the amount of load reduction by

each consumer should be equal to or less than the maximum amount of their suggested load reduction.

$$RP(r, t) = RC(r, t) \cdot \zeta_{r,t}, RC(r, t) \leq RC_t^{\max} \quad (22)$$

$$CP(c, t) = CC(c, t) \cdot \bar{\zeta}_{c,t}, CC(c, t) \leq CC_t^{\max} \quad (23)$$

$$IP(i, t) = IC(i, t) \cdot \bar{\zeta}_{i,t}, IC(i, t) \leq IC_t^{\max} \quad (24)$$

in this article, participation in DRP is considered to be voluntary.

5. Optimization Method

Operation management of microgrids is a complex problem that should be solved by smart innovative methods. A meta-heuristic optimization algorithm is an innovative method that can be optimized with low modifications for optimization problems. Multi-combinational algorithms significantly increase the ability of high-quality solutions for hard-core optimization problems. The common feature of these algorithms is the use of the exit mechanism from the local optimum. To solve the stated microgrid optimization problem, the WOA which is a novel technique to solve the optimization problems and is very competitive in comparison to the state-of-art meta-heuristic algorithms and usual approaches are being utilized. This algorithm inspired by the bubble-net hunting of humpback whales consists of three operators for simulating encircling prey, exploitation phase of bubble-net attacking, and exploration phase of the search for prey, which is represented by model Equations (25)–(27), respectively. Humpback whales first detect the location of prey and surround it, then update their location according to the best search agent, or accidentally the whales swimming procedure around the prey, is in the form of a contraction circle and in a helix path. With a probability of 50% one of these two modes is selected in modeling. Applying the WOA to the problem under consideration is as follows: The WOA algorithm initiates with a group of random solutions. First, an initial population is generated as X_i ($i = 1, 2, \dots, n$), and then, the fitness of each search agent is calculated. At each iteration, search agents update their locations based on either a randomly selected search agent or the best solution obtained so far. This behavior is provided as:

$$\begin{aligned} \vec{D} &= |\vec{C} \cdot \vec{X}^*(t) - \vec{X}(t)| \\ \vec{X}(t+1) &= \vec{X}^*(t) - \vec{A} \cdot \vec{D} \\ \vec{A} &= 2\vec{a} \cdot \vec{r} - \vec{a} \\ \vec{C} &= 2 \cdot \vec{r} \end{aligned} \quad (25)$$

$$\begin{aligned} \vec{X}(t+1) &= \\ &\leq \begin{cases} \vec{X}^*(t) - \vec{A} \cdot \vec{D} & \text{if } p < 0.5 \quad (a) \\ \vec{D}' \cdot e^{bl} \cdot \cos(2\pi l) + \vec{X}^*(t) & \text{if } p \geq 0.5 \quad (b) \end{cases} \end{aligned} \quad (26)$$

$$\begin{aligned} \vec{D} &= |\vec{C} \cdot \vec{X}_{\text{rand}} - \vec{X}| \\ \vec{X}(t+1) &= \vec{X}_{\text{rand}} - \vec{A} \cdot \vec{D} \end{aligned} \quad (27)$$

The parameter is deduced from 2 to 0, to provide the exploration and exploitation phases. The best solution is selected when $|\vec{A}| < 1$ and, then, the search agent is updated by Equation (26) while a random search agent is selected when $|\vec{A}| > 1$. Next, the position of each search agent is updated by the Equation (27). Based on the value of p , WOA can shift between the circular (a-26) and the spiral movements (b-26). Finally, the WOA algorithm is ended by satisfying a termination criterion.

6. Case Study and Simulation Results

The microgrid structure is represented in Figure 1. According to this figure, it is clear that microgrid includes diesel generator (DG), fuel cell (FC), microturbine (MT), wind turbine (WT), and photovoltaic (PV) distributed generation resources. Besides, in the

microgrid structure, a battery is used as an energy storage system. The cost and coefficients of different resources are presented in Table 3.




Figure 1. Typical smart micro-grid system [33].

Table 3. Bids and emission coefficients of the DG sources [33].

Type	Pmax (kW)	Pmin (kW)	NO _x Price (\$/kg)	SO ₂ Price (\$/kg)	CO ₂ Price (\$/kg)	Start-up/Shutdown Cost (\$/kWh)	O&M (\$/kWh)
DG	300	30	1.49	1.302	0.033	0.17	0.099
MT	30	6	1.49	1.302	0.033	1.09	0.05
FC	30	3	1.49	1.302	0.033	1.88	0.098
PV	25	0	1.49	1.302	0.033	0	0
WT	15	0	1.49	1.302	0.033	0	0
Bat	30	−30	1.49	1.302	0.033	0	0

Regarding Figure 2, microgrid loads are divided into three types of RCs, CCs and ICs.




Figure 2. Daily load curve for different consumer [33].

In the selected microgrid, a WT with a nominal capacity of 15 kW, cut-in speed 3.5 m/s, nominal speed 17.5 m/s, and cut-off speed 18 m/s is considered. In Figure 3, the average wind speed predicted for the next 24 h is shown. The used PV capacity is 25 Kw which is of the SOLAREX MSX type. The amount of sunlight in the considered location for the next 24 h is also shown in Figure 4. Based on Figures 3 and 4, the predicted power of WT and PV for the next 24 h, can be calculated using the mathematical relations presented in Section 3. In calculating the output power of WT and PV, it is supposed that the power factor of these sources is one and does not produce reactive power. In the chosen microgrid, the minimum and maximum storage levels are set to 10% and 100% of the battery of 180 kWh capacity, respectively. Battery charging and discharging efficiency is also considered 94% [33]. According to Table 3, the maximum discharge and charge power of the battery is also 30 kW, which is equivalent to one-sixth of the capacity of the battery. The suggested packages for DRP [35] are represented in Table 4. A maximum of 30% participate is assumed in these programs.




Figure 3. Hourly wind speed forecast [33].




Figure 4. Hourly solar irradiance forecast [33].

Table 4. Suggested packages for demand response [33].

Level	Interruptible Load Range	Price (\$)
1	0–5 kW	0.06
2	5–10 kW	0.13
3	10–50 kW	0.26
4	50–70 kW	0.36

7. Simulation and Data Analysis

The following scenarios are considered to solve the microgrid energy management problem using DRPs and WOA.

Scenario 1: Enhancing the operation cost and the emissions cost regardless of DRP

Scenario 2: Enhancing the operation cost and the emission cost considering DRP

Then, the results of the above scenarios are compared and the effect of using DRP is investigated.

7.1. Scenario 1

In this scenario, the efficiency of the WOA algorithm in solving the problem is evaluated by comparing it to the results of GA [36,37], PSO [38,39], and ICA [40,41] algorithms. To compare WOA performance to these algorithms, the problem is modeled without demand response. Given the fact that the considered microgrid has 6 units and each unit is scheduled for 24 h, the problem variables are $24 \times 6 = 144$. For all four algorithms, the population is 100 and the maximum number of iterations is set to 100. Each algorithm runs ten times and, finally, the best answer, the worst answer and the average answer of each run are computed and stored. This information is presented for the algorithms in Table 5. For these simulations, both w_1 and w_2 values in the cost function are considered to be 0.5. It is assumed that the importance of reducing the operation cost and emission cost is the same. Based on the presented result in Table 5, it can be seen that the best answer, the worst answer and the average answer of the WOA are the best as compared to the other three algorithms. Furthermore, the results show the optimal scheduling of the distributed

resources at minimum costs of operation and emission. In Figure 5, the value of the cost function based on the number of repetitions, for ten runs for every four algorithms, is shown. Based on this figure, it is clear that for all answers, the convergence rate of the WOA is better than other algorithms.

Besides, in Figures 6 and 7, the predicated power and purchasing power of PV and WT are shown for each of the four algorithms, respectively. Predicated solar and wind power means the power generated by these resources according to their nominal capacities and hourly forecast curves for solar radiation and wind speed. As it is known, due to the low cost of PV operation, the maximum use of them is optimally detected. Figure 7 shows that in all algorithms, wind power has been used to a large extent, among which the WOA algorithm has the highest rank in utilizing this power. In Figure 8, the power of charge, discharge power, and stored energy per hour are shown for each of the four algorithms.






Figure 5. Convergence comparison of the algorithms for ten runs with a population of 100 and several replicates of 100.

Table 5. Comparison of WOA, PSO, ICA and GA.


Algorithm	Best Answer	Worst Answer	Average of Answer	Emission Cost (\$)	Operation Cost (\$)	Run Time (s)
WOA	219.16	221.37	218.84	102.41	335.91	88
PSO	224.93	229.52	226.77	107.32	342.53	82
ICA	227.15	229.96	228.71	108.04	346.26	80
GA	228.66	231.07	229.98	109.51	347.82	62




(a) GA



(b) ICA



(c) PSO



(d) WOA

Figure 6. Predicated and purchased power of PV.




Figure 7. Predicated and purchased power of WT.

According to Figure 8, the battery is discharged at peak times and charged at off-peak periods. This will reduce the amount of power generation from more expensive sources or sources of pollution. Now that the effectiveness of the WOA is cleared in solving this operation management problem and to achieve accurate results, we multiply the population by 5, set it to 500, solve the problem with 100 repetitions of the WOA, and, finally, obtain the optimal amount of each resource in this case. It is assumed that the importance of reducing the costs of operation and emission is the same. Accordingly, the weight coefficients w_1 and w_2 are set to 0.5. For this scenario, the operation cost is \$335.91 and the emission cost is \$102.41. Figure 8 shows the objective function values versus the number of repetitions of the WOA algorithm. Table 6 also shows the optimal power of each resource for each hour. In this table, the positive and negative values for the battery show the discharge and charge power, respectively.

In Figure 8, the charge power, discharge power, and stored battery power are shown per hour. Matching this shape with the load curve shown in Figure 2, it is clear that the

battery is charged at off-peak periods and discharged at peak time. In Figures 9 and 10, the predicted power and the purchasing power are shown for WT and PV. Figure 10 and Table 6 show that PV power is used more than other resources. The reason is that the emission cost of this resource is lower than other resources. It is also clear that the most available WT power is used. In this sense, according to Table 3, the operation cost of WT is much less than other sources too, such as diesel generators. Therefore, like PV, the use of WT power is optimized to reduce emissions.





Figure 8. Charge power, discharge power, and stored battery energy during optimization.

Table 6. Optimal power of each source for each hour in scenario 1.

Var	Pbat (kW)	Pwt (kW)	Ppv (kW)	Pfc (kW)	Pmt (kW)	Pd (kW)	DR
1	−25.579	4.832	0	30	30	40.747	0
2	−27.425	4.982	0	29.013	30	38.43	0
3	−30	4.317	0	29.461	30	38.221	0
4	−30	4.767	0	30	30	30.232	0
5	−29.943	3.803	0	26.679	30	40.46	0
6	−28.147	4.06	1.358	30	28.466	49.262	0
7	13.754	4.06	4.107	30	30	37.078	0
8	30	3.739	10.25	30	30	60.011	0
9	6.964	3.096	15.992	30	30	110.95	0
10	−16.926	1.585	21.422	30	30	158.92	0
11	−29.994	0.6	23.331	30	30	179.06	0
12	30	1.071	23.748	30	30	116.18	0
13	−11.022	1.596	21.636	30	30	174.79	0
14	30	2.635	17.632	30	30	142.73	0
15	−28.556	3.696	13.898	30	30	191.96	0
16	−0.33	4.778	9.192	30	30	156.36	0
17	30	5.303	4.28	30	30	114.41	0
18	30	4.328	1.56	30	30	132.1	0
19	−5.194	3.792	0	30	30	161.4	0
20	30	4.478	0	30	30	125.52	0
21	30	4.285	0	30	30	99.714	0
22	−17.673	3.76	0	30	30	116.91	0
23	17.382	3.235	0	30	30	40.382	0
24	30	3.696	0	20.304	30	0	0

**Figure 9.** Predicated and purchased power of wind turbine in scenario 1.




Figure 10. Predicated and purchased power of PV in scenario 1.

7.2. Scenario 2

In this scenario, the problem under study is solved using WOA. In this sense, DRP is also considered. As mentioned, it has been assumed that up to 30% of consumers are involved in DRP. Considering the power output of the resources and the amount of power consumed by residential, commercial and industrial consumers within 24-h, the number of variables is 216 and the number of population and repetitions are 500 and 100, respectively. For this scenario, the value of the total cost function for each WOA repetition is represented in Figure 11. The cost of operation and the cost of emission were \$250.5 and \$64.270, respectively. In this regard, \$29.243 of the operating cost, is related to the demand response cost. In Table 6, the optimal amount of resource power and also the amount of demand reduction per hour have been shown. In Figure 12, the amount of charge power, discharge power and stored energy in the battery is shown for each hour. The battery is charged at off-peak periods and is discharged during peak intervals.




Figure 11. The total cost function of scenario 2 (the population of 500 and 100 repetitions).




Figure 12. Charge power, discharge power and stored battery power in scenario 2.

8. Investigating the Effect of Demand Response

In Figure 13, the amount of load for all customers is shown for each hour, before and after the demand response. According to Figure 14, it is clear that the demand response occurred both at peak times and off-peak periods. The reason for using demand response is to reduce the pollution because, in some hours, the power of some resources with high pollution, such as diesel generators, is small. Moreover, by carrying out DRPS, it is possible to turn off these resources during off-peak periods, which will significantly reduce the operation and emission costs. According to Figure 15, the most use of demand response has occurred in peak hours. This has been done to reduce the use of expensive energy resources and also to reduce emissions. In Table 7, the costs of operation and emission for scenarios 1 and 2 have been compared.




Figure 13. Predicated and purchased power of wind turbine in scenario 2.




Figure 14. Predicated and purchased power of PV in scenario 2.




Figure 15. The amount of microgrid load before and after of DR.

Table 7. Comparison of scenario 1 and 2.

Scenario	Operation Cost (\$)	Emission Cost (\$)	Demand Response Cost (\$)
1	335.91	102.41	-
2	250.5	64.27	29.243

According to Table 7, using the DRP has reduced operating costs by \$85.41, which is equivalent to 25.4% of the total operating cost. Moreover, it has also reduced the emission cost by \$38.39 which is equivalent to 37.4% of the total emission cost. Accordingly, it is worth mentioning that the results indicate a significant improvement.

9. Conclusions

In this research, an optimum operation management model for a stand-alone microgrid considering DRP is proposed. The aim is to minimize the operation and emission cost, simultaneously. To manage the energy of the microgrid, incentive-based DRP has been used. The optimization problem is solved with the WOA in the MATLAB environment. First of all, the model is simulated for WOA and the three optimization algorithms without considering of the DRP; PSO, ICA and GA, to assess the WOA's performance. The findings showed that the WOA as compared to other algorithms has proved better performance for worst, best and average taken results. Furthermore, the results showed the optimal scheduling of the distributed resources at minimum costs of operation and emission. Then, the microgrid energy management model was performed considering DRP. Simulation results showed that using DRP has reduced the operating costs and emission cost by 25% and 34%, respectively. DRP provides better utilization of the microgrid, both in terms of operating costs and emission cost, which proves the importance of DRPS.

Author Contributions: Conceptualization, M.T.; methodology, M.T.; software, M.T.; validation, M.T., M.S. and J.P.; formal analysis, M.T. and F.M.; investigation, N.B., M.T. and F.M.; Resources, M.T., M.S. and M.S.N.; data curation, M.T.; writing—original draft preparation, M.T., M.S. and F.M.; writing—review and editing, M.T., M.S. and M.R.B.K.; visualization, M.T., J.P. and M.K.H.; supervision, A.S. and M.R.B.K.; project administration, M.T., M.S., J.P. and J.M.G.; funding acquisition J.P. All authors have read and agreed to the published version of the manuscript.

Funding: This research publication is funded by J510050002—BOLDREFRESH2025—CENTRE OF EXCELLENCE from the iRMC of Universiti Tenaga Nasional (UNITEN).

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: Not applicable.

Acknowledgments: The authors would like to thank Universiti Tenaga Nasional (UNITEN) for providing BOLD Research Grant J510050002/2021080 to support this research and acknowledge the publication support through J510050002—BOLDREFRESH2025—CENTRE OF EXCELLENCE from the iRMC of UNITEN.

Conflicts of Interest: The authors declare no conflict of interest.

References

1. Zhang, Y.; Wang, J.; Li, Z. Uncertainty modeling of distributed energy resources: techniques and challenges. *Curr. Sustain. Energy Rep.* **2019**, *6*, 42–51. [\[CrossRef\]](#)
2. Lasseter, R. Microgrids. In Proceedings of the IEEE Power Engineering Society Winter Meeting, Singapore, 23–27 January 2000; pp. 27–31.
3. Ahshan, R.; Iqbal, M.T.; Mann, G.K.; Quicoe, J.E. Micro-grid system based on renewable power generation units. In *CCECE 2010*; IEEE: Calgary, AB, Canada, 2010; pp. 1–4.
4. Valinejad, J.; Marzband, M.; Korkali, M.; Xu, Y.; Al-Sumaiti, A.S. Coalition Formation of Microgrids with Distributed Energy Resources and Energy Storage in Energy Market. *J. Mod. Power Syst. Clean Energy* **2020**, *8*, 906–918. [\[CrossRef\]](#)
5. Ahshan, R.; Saleh, S.A.; Al-Badi, A. Performance Analysis of a Dq Power Flow-Based Energy Storage Control System for Microgrid Applications. *IEEE Access* **2020**, *8*, 178706–178721. [\[CrossRef\]](#)
6. Kwon, K.b.; Kim, D. Enhanced method for considering energy storage systems as ancillary service resources in stochastic unit commitment. *Energy* **2020**, *213*, 118675. [\[CrossRef\]](#)
7. McPherson, M.; Stoll, B. Demand response for variable renewable energy integration: A proposed approach and its impacts. *Energy* **2020**, *197*, 117205. [\[CrossRef\]](#)
8. Heydarian-Forushani, E.; Golshan, M. Quantitative flexibility assessment of a comprehensive set of demand response programs. *Int. J. Electr. Power Energy Syst.* **2020**, *116*, 105562. [\[CrossRef\]](#)
9. Ghadi, M.J.; Ghavidel, S.; Rajabi, A.; Azizivahed, A.; Li, L.; Zhang, J. A review on economic and technical operation of active distribution systems. *Renew. Sustain. Energy Rev.* **2019**, *104*, 38–53. [\[CrossRef\]](#)
10. Bui, V.H.; Kim, H.M.; Song, N.O. Applying demand response based on TOU and EDRP to optimal microgrid operation. *Int. J. Smart Home* **2015**, *9*, 41–50. [\[CrossRef\]](#)

11. Zakariazadeh, A.; Jadid, S.; Siano, P. Smart microgrid energy and reserve scheduling with demand response using stochastic optimization. *Int. J. Electr. Power Energy Syst.* **2014**, *63*, 523–533. [\[CrossRef\]](#)
12. Nikmehr, N.; Najafi-Ravadanegh, S.; Khodaei, A. Probabilistic optimal scheduling of networked microgrids considering time-based demand response programs under uncertainty. *Appl. Energy* **2017**, *198*, 267–279. [\[CrossRef\]](#)
13. Shen, J.; Jiang, C.; Liu, Y.; Qian, J. A microgrid energy management system with demand response for providing grid peak shaving. *Electr. Power Compon. Syst.* **2016**, *44*, 843–852. [\[CrossRef\]](#)
14. Moghaddam, A.A.; Seifi, A.; Niknam, T.; Pahlavani, M.R.A. Multi-objective operation management of a renewable MG (micro-grid) with back-up micro-turbine/fuel cell/battery hybrid power source. *Energy* **2011**, *36*, 6490–6507. [\[CrossRef\]](#)
15. Wang, Y.; Huang, Y.; Wang, Y.; Zeng, M.; Li, F.; Wang, Y.; Zhang, Y. Energy management of smart micro-grid with response loads and distributed generation considering demand response. *J. Clean. Prod.* **2018**, *197*, 1069–1083. [\[CrossRef\]](#)
16. Norouzi, M.R.; Ahmadi, A.; Nezhad, A.E.; Ghaedi, A. Mixed integer programming of multi-objective security-constrained hydro/thermal unit commitment. *Renew. Sustain. Energy Rev.* **2014**, *29*, 911–923. [\[CrossRef\]](#)
17. Rabiee, A.; Sadeghi, M.; Aghaei, J.; Heidari, A. Optimal operation of microgrids through simultaneous scheduling of electrical vehicles and responsive loads considering wind and PV units uncertainties. *Renew. Sustain. Energy Rev.* **2016**, *57*, 721–739. [\[CrossRef\]](#)
18. Imani, M.H.; Niknejad, P.; Barzegaran, M. The impact of customers' participation level and various incentive values on implementing emergency demand response program in microgrid operation. *Int. J. Electr. Power Energy Syst.* **2018**, *96*, 114–125. [\[CrossRef\]](#)
19. Vergara, P.P.; López, J.C.; da Silva, L.C.; Rider, M.J. Security-constrained optimal energy management system for three-phase residential microgrids. *Electr. Power Syst. Res.* **2017**, *146*, 371–382. [\[CrossRef\]](#)
20. El-Hendawi, M.; Gabbar, H.; El-Saady, G.; Ibrahim, E.N. Control and EMS of a grid-connected microgrid with economical analysis. *Energies* **2018**, *11*, 129. [\[CrossRef\]](#)
21. Dulău, L.I.; Bică, D. Optimization of generation cost in a microgrid. *Procedia Manuf.* **2018**, *22*, 703–708. [\[CrossRef\]](#)
22. Imani, M.H.; Niknejad, P.; Barzegaran, M. Implementing Time-of-Use Demand Response Program in microgrid considering energy storage unit participation and different capacities of installed wind power. *Electr. Power Syst. Res.* **2019**, *175*, 105916. [\[CrossRef\]](#)
23. Moradi, H.; Esfahanian, M.; Abtahi, A.; Zilouchian, A. Optimization and energy management of a standalone hybrid microgrid in the presence of battery storage system. *Energy* **2018**, *147*, 226–238. [\[CrossRef\]](#)
24. Lorestani, A.; Gharehpetian, G.; Nazari, M.H. Optimal sizing and techno-economic analysis of energy-and cost-efficient standalone multi-carrier microgrid. *Energy* **2019**, *178*, 751–764. [\[CrossRef\]](#)
25. Ahmadi, S.E.; Rezaei, N. A new isolated renewable based multi microgrid optimal energy management system considering uncertainty and demand response. *Int. J. Electr. Power Energy Syst.* **2020**, *118*, 105760. [\[CrossRef\]](#)
26. Tabar, V.S.; Ghassemzadeh, S.; Tohidi, S. Energy management in hybrid microgrid with considering multiple power market and real time demand response. *Energy* **2019**, *174*, 10–23. [\[CrossRef\]](#)
27. Adefarati, T.; Bansal, R.C. Reliability, economic and environmental analysis of a microgrid system in the presence of renewable energy resources. *Appl. Energy* **2019**, *236*, 1089–1114. [\[CrossRef\]](#)
28. Karimi, H.; Jadid, S. Optimal microgrid operation scheduling by a novel hybrid multi-objective and multi-attribute decision-making framework. *Energy* **2019**, *186*, 115912. [\[CrossRef\]](#)
29. Abo-Elyousr, F.K.; Sharaf, A. Optimal Scheduling of Interconnected AC/DC Combined Heat and Power System Microgrids with Multiple Fuel Options. *Energy Procedia* **2019**, *162*, 285–295. [\[CrossRef\]](#)
30. Strachan, N.D.; Farrell, A.E. Emissions from distributed generation. *CEIC Work. Pap.* **2002**. Available online: <https://www.cmu.edu/ceic/assets/docs/publications/working-papers/ceic-02-04.pdf> (accessed on 8 July 2021).
31. Levinson, R.; Akbari, H. Potential benefits of cool roofs on commercial buildings: conserving energy, saving money, and reducing emission of greenhouse gases and air pollutants. *Energy Effic.* **2010**, *3*, 53. [\[CrossRef\]](#)
32. Xie, C.; Wang, D.; Lai, C.S.; Wu, R.; Huang, J.; Lai, L.L. Optimal sizing of battery energy storage system in smart microgrid with air-conditioning resources. In Proceedings of the 2020 IEEE International Smart Cities Conference (ISC2), Piscataway, NJ, USA, 28 September–1 October 2020; pp. 1–8.
33. Aghajani, G.; Shayanfar, H.; Shayeghi, H. Demand side management in a smart micro-grid in the presence of renewable generation and demand response. *Energy* **2017**, *126*, 622–637. [\[CrossRef\]](#)
34. Atwa, Y.; El-Saadany, E.; Salama, M.; Seethapathy, R. Optimal renewable resources mix for distribution system energy loss minimization. *IEEE Trans. Power Syst.* **2009**, *25*, 360–370. [\[CrossRef\]](#)
35. Kirby, B.J. *Demand Response for Power System Reliability: FAQ*; Oak Ridge National Laboratory: Oak Ridge, TN, USA, 2006.
36. Holland, J.H. *Adaptation in Natural and Artificial Systems: An Introductory Analysis with Applications to Biology, Control, and Artificial Intelligence*; MIT Press: Cambridge, MA, USA, 1992.
37. Ishraque, M.F.; Shezan, S.A.; Ali, M.; Rashid, M. Optimization of load dispatch strategies for an islanded microgrid connected with renewable energy sources. *Appl. Energy* **2021**, *292*, 116879. [\[CrossRef\]](#)
38. Eberhart, R.; Kennedy, J. Particle swarm optimization. In Proceedings of the ICNN'95—International Conference on Neural Networks, Perth, Australia, 27 November–1 December 1995; Volume 4, pp. 1942–1948.
39. Roslan, M.; Hannan, M.; Ker, P.J.; Begum, R.; Mahlia, T.I.; Dong, Z. Scheduling controller for microgrids energy management system using optimization algorithm in achieving cost saving and emission reduction. *Appl. Energy* **2021**, *292*, 116883. [\[CrossRef\]](#)

-
40. Atashpaz-Gargari, E.; Lucas, C. Imperialist competitive algorithm: an algorithm for optimization inspired by imperialistic competition. In Proceedings of the 2007 IEEE Congress on Evolutionary Computation, Singapore, 25–28 September 2002; pp. 4661–4667.
 41. Barja-Martinez, S.; Rücker, F.; Aragüés-Peñalba, M.; Villafafila-Robles, R.; Munné-Collado, Í.; Lloret-Gallego, P. A novel hybrid home energy management system considering electricity cost and greenhouse gas emissions minimization. *IEEE Trans. Ind. Appl.* **2021**, *57*, 2782–2790. [[CrossRef](#)]