

## Quantitative Mapping of Modeling Methods for Stability Validation in Microgrids

Song, Yubo; Sahoo, Subham; Yang, Yongheng; Blaabjerg, Frede

*Published in:*  
IEEE Open Journal of Power Electronics

*DOI (link to publication from Publisher):*  
[10.1109/OJPEL.2022.3214200](https://doi.org/10.1109/OJPEL.2022.3214200)

*Creative Commons License*  
CC BY 4.0

*Publication date:*  
2022

*Document Version*  
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*  
Song, Y., Sahoo, S., Yang, Y., & Blaabjerg, F. (2022). Quantitative Mapping of Modeling Methods for Stability Validation in Microgrids. *IEEE Open Journal of Power Electronics*, 3, 679-688. Article 9918047. <https://doi.org/10.1109/OJPEL.2022.3214200>

### General rights





Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

### Take down policy

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# Quantitative Mapping of Modeling Methods for Stability Validation in Microgrids

YUBO SONG <sup>1</sup> (Student Member, IEEE), SUBHAM SAHOO <sup>1</sup> (Member, IEEE),  
YONGHENG YANG <sup>2</sup> (Senior Member, IEEE), AND FREDE BLAABJERG <sup>1</sup> (Fellow, IEEE)

<sup>1</sup>Department of Energy (AAU Energy), Aalborg University, 9220 Aalborg East, Aalborg, Denmark

<sup>2</sup>College of Electrical Engineering, Zhejiang University, Hangzhou 310027, Zhejiang, China

CORRESPONDING AUTHOR: YUBO SONG (e-mail: yuboso@energy.aau.dk).

The work is supported by the Reliable Power Electronic-Based Power System (REPEPS) project at Department of Energy, Aalborg University, as a part of the Villum Investigator Program funded by the Villum Foundation, Denmark.

**ABSTRACT** Although power electronic converters have been the key enablers for the integration of renewable generation, heterogeneous controllers and lower inertia increase the complexity of microgrids, more likely to cause instability. Hence, it is significant to study the stability of microgrids using prospective modeling tools such as, bode plots, Nyquist plots, eigenvalue loci, etc. The modeling of microgrids is an important step of stability analysis, where state-space-based and impedance-based modeling are the two commonly used stability evaluation approaches in microgrids. Miscellaneous modeling methods have respective pros and cons, which have been investigated in the existing literatures to some extent. However, it is still critical to quantify the modeling techniques so as to formalize the stability validation in an intuitive way, which is not addressed in existing literatures. Therefore, in this paper, modeling methods for stability validation are mapped based on an order-indicated complexity, and a quantitative framework for the mapping is provided. The proposed framework can be instructive when modeling microgrid systems with different sizes, topologies or control strategies, etc., and it turns out to be well applicable as demonstrated by exemplified simulations and experimental tests.

**INDEX TERMS** Microgrids, stability characterization, stability modeling, stability validation, power electronics.

## I. INTRODUCTION

Power electronics have been providing enormous possibilities for energy conversion and integration of new types of loads [1], [2]. In microgrids (MGs), a large number of renewable energy sources (RES) are integrated and utilized through power electronic converters, including photovoltaic arrays, batteries and fuel cells. The power electronic converters have fast dynamics due to the underlying controllers, and the power generation profiles from RES are also less steady than synchronous generators. These two aspects have led to lower inertia and less robustness in MGs [2], [3], [4]. On the other hand, the controllers will bring about interactions among converters leading to complicated harmonics and resonances [5]. Hence, a comprehensive framework to categorically assess the stability of MGs still remains a challenge in this field.

Many reported studies are focused on the modeling and evaluation of stability in MGs. In most cases, the controllers of converters are considered as the most critical part, which is not common in the modeling of conventional power systems [6]. The controllers can be modeled as, e.g., state spaces [7], [8], transfer functions [9] or equivalent impedances [10], [11], [12], [13], but due to approximations, different modeling methods exhibit distinct accuracy levels. Basically, there are two commonly used modeling mechanisms, namely state-space-based modeling [7], [8] and impedance-based modeling [9], [10]. MGs are modeled into state-space matrices or impedance networks, and the stability of the MG is then characterized through eigenvalue loci [7], [8], Nyquist plots [9], [11] or Bode diagrams [11], [12], [13], etc. In practice, state-space-based modeling is more suitable for mathematical programming with modular and reusable forms, while

impedances have clearer physical interpretation of frequency-domain characteristics.

However, in [7], [8], [9], [10], [11], [12], [13], the modeled systems are similar in their scales, such that the applied modeling methods do not show much difference in simplicity. For example, in [7], a system consisting of three identical converters is selected as the study case. If complicated systems like the IEEE standard systems [14] (with larger scale or complicated architectures) or the CIGRE benchmark [15] (with RES or various controllers) are considered, the computational difference between the modeling methods will be of much importance during stability analysis, considering the following factors: heterogeneity of controllers and the size of system matrix which could increase in a non-linear manner with the increase in the number of nodes. Under such circumstances, the modeling methods will imply different computation burden. Consequently, there have been studies focusing on the modeling and performance validations of large-scale MG systems [16], requiring many approximations and much advanced solvers to reduce the computation time.

Under this scenario, the comparison of the modeling methods becomes a practical and general concern. There are many aspects under discussion, including the procedures of modeling and stability evaluation in [17], [18], and the availability of modeling methods in [19]. However, the literatures are mostly qualitative classifications, where the borderline between modeling methods are specified only in certain applications such as black-box systems, without intuitive mapping of system properties. The validations can be consequently ambiguous when the system grows complicated with large scale or multiple RES.

In light of the above, this paper aims at formalizing an explicit framework for stability validation in MGs, by mapping the modeling methods in a quantitative way. In our previous study [20], the complexity of modeling has been discussed, which is an important concern in terms of computation in practice. The mapping regarding different applications has also been demonstrated with study cases. In this paper, the mapping of modeling methods is further explored, and quantitative metrics based on order of elements in the system are proposed for the first time. The definitions of the metrics are introduced, which quantify the computational efforts for each modeling method for a given system in a handy way, formalizing stability validations and thereby serve as a clear baseline methodology for benchmarking the modeling methods. The efficacy is demonstrated by simulations and experimental results.

## II. MAPPING OF STABILITY MODELING IN MICROGRIDS

### A. STATE-SPACE-BASED AND IMPEDANCE-BASED MODELING

State-space-based modeling is particularly suitable for multiple-in-multiple-out (MIMO) systems, as it is in the form of state matrix and state variable vectors [7]. Based on Lyapunov definitions, a MG is stable when all state variables

**TABLE 1. Comparison of State-Space-Based and Impedance-Based Method**

	State-Space-Based Method	Impedance-Based Method
Size of matrix	Dependent on state variables	Dependent on impedance nodes
Order of elements in the matrix	Low	High
Domain of modeling	Time domain	Mostly frequency domain
Applicable frequency range	Wide	From around $f_i$ to control bandwidth <sup>1</sup>
For large-scale systems	Easy for dimensional expansion	Moderate
For high-order systems	More state variables. Lyapunov functions are not influenced	Higher order of transfer function. Bode plots are not influenced
For black-box system	Difficult	Frequency scanning can be used for modeling
Possible source of inaccuracy	Linearization and approximations for numerical purpose	Linearization and ignoring coupling / asymmetry in the $dq$ or $\alpha\beta$ components

Note 1:  $f_i$  is the fundamental frequency (normally 50 or 60 Hz).

describing the system converge towards or around a stable operation point with time, which co-aligns well with the small-signal stability of the MG. Accordingly, the stability of the MG is characterized by the eigenvalues of the state matrix or by the Lyapunov functions. The eigenvalue analysis is widely applicable for linear or linearized systems and easy to perform, but for systems that are not suitable for linearization, Lyapunov functions are preferred as a more general candidate approach.

In impedance-based modeling, the converters with filters are modeled into a Thevenin circuit or Norton circuit, where the control loops can also be modeled into impedances [11], [13]. Taking the Thevenin equivalence as an example, the MG is regarded as a network of voltage sources and impedances, and the stability of the MG is thereby translated by the stability of the impedance network. There are many approaches to conduct the impedance-based modeling, and two widely-used ones are: (1) developing the transfer functions by constructing the admittance matrix of the network [9], and (2) partitioning the MG into two parts and employing the Nyquist criteria [10]. Subsequently, Bode or Nyquist plots are often used for impedance-based stability analysis, which are quite straightforward to reflect the behavior of MGs at different frequencies, e.g., in response to inputs or disturbances.

A comparative evaluation of both the modeling methods considering different aspects has been summarized in Table 1 [19], [20]. Both the two modeling methods have respective pros and cons in particular applications, but their differences need to be comprehended in terms of complexity and applications when both can achieve high accuracy.

**TABLE 2. Order Contribution of Units in a Microgrid**

Units	Contribution to System Order
Proportional (P) controller	0
Integral (I) controller	1
Control delays in <i>Padé</i> approximation [19], [20]	Dependent on the order of approximation employed
Simple resistor	0
Inductor or capacitor in filters	1
Synchronous-reference-frame phase-locked loop (SRF-PLL) [21]	2
Droop controller	0
First-order low-pass filters (LPF) for power in droop controllers <sup>3</sup>	1 for active power 1 for reactive power
Integration of $\omega$ in <i>P-f</i> droop	1
Loads or lines in <i>RL</i> equivalence	1
Transmission lines in $\pi$ model	3

## B. QUANTIFICATION OF COMPLEXITY OF MODELING METHODS

For stability characterization in MGs, the modeling methods can lead to differences in calculation complexity, fidelity and intuitiveness in terms of applications, etc. [19], [20]. The complexity is mostly related to the differentials or integrals inside, defining the order of MGs. Higher-order systems always have higher dimension in the state matrix or more complicated transfer functions derived by impedances, which are time-consuming in computation.

### Remark 1:

It is true that operations like matrix inversions and eigenvalue calculations can be time-consuming in large systems or some advanced modeling methods, but the differentials are generally playing the major role in complexity considering its large number of appearances in the modeling. But if there are repetitive or nested advanced operations, the complexity should be the total effect of all operations instead.

A MG normally consists of multiple renewable generations and various loads, which are mostly interfaced by converters and passive filters. When modeled within control bandwidth (several kHz), the behaviors of converters can be averaged by switching period and then linearized. The passive filters and controllers are then described into transfer functions or differential equations with respective orders.

Under this circumstance, the contributions of units in a MG (controllers or passive components, etc.) are listed in Table 2. In this paper, two-level DC-AC converters are considered, while multi-level converters could also contribute much to the total order and could be studied in details in the future. In Table 2, when a unit is synthesized as a transfer function, the order is the maximum of the numerator and denominator, or the maximum order of inputs and outputs in the corresponding differential equation.

To introduce the metrics for quantifying the modeling methods, it is assumed that there is a total of  $n$  nodes in the MG system, and there is one converter and up to one passive load at each node.

A MG can be normally modeled into a state space as (1) [7] or via admittance matrix as (2) and (3) [9].

$$\begin{aligned}\dot{\mathbf{x}}_{MG}(t) &= \mathbf{A}_{MG}\mathbf{x}_{MG}(t) + \mathbf{B}_{MG}\mathbf{u}_{MG}(t) \\ \mathbf{y}_{MG}(t) &= \mathbf{C}_{MG}\mathbf{x}_{MG}(t) + \mathbf{D}_{MG}\mathbf{u}_{MG}(t)\end{aligned}\quad (1)$$

where,  $\mathbf{x}_{MG}$  is the vector of observed state variables,  $\mathbf{u}_{MG}$  is the input vector consisting of the reference of controllers, initial states or small-signal disturbances,  $\mathbf{y}_{MG}$  is the output vector indicating the behavior or performance of the MG, and  $\mathbf{A}_{MG}$ ,  $\mathbf{B}_{MG}$ ,  $\mathbf{C}_{MG}$ ,  $\mathbf{D}_{MG}$  are the state matrices. If the total number of state variables is denoted as  $\lambda$ , then the vector of state variables  $\mathbf{x}_{MG}$  is in the dimension of  $\lambda \times 1$ .

$$\begin{bmatrix} I_{conv,I} \\ I_{conv,II} \end{bmatrix}_{\mu \times 1} = [\mathbf{Y}_{MG}]_{\mu \times \mu} \begin{bmatrix} V_{conv,I} \\ V_{conv,II} \end{bmatrix}_{\mu \times 1} \quad (2)$$

$$\begin{cases} V_{conv,I} = G_{1,I}V_{conv,I}^* + G_{2,I}I_{conv,I} \\ I_{conv,II} = G_{1,II}I_{conv,II}^* + G_{2,II}V_{conv,II} \end{cases} \quad (3)$$

where,  $V_{conv}$  and  $I_{conv}$  are respectively the voltage and current of converters at the point of grid integration. The converters are divided into two types dependent on the control references: Type I with voltage reference (e.g., grid-forming converters) and Type II with current reference (e.g., grid-following converters).  $G_1$  and  $G_2$  are the respective transfer functions regarding the references or disturbances, which are diagonal for local controllers without considering cross-converter coupling [9].  $\mathbf{Y}_{MG}$  is the admittance matrix considering both lines and loads.  $\mu$  is the dimension of the admittance matrix, which can be equal to  $m$  (e.g., in single-phase or symmetric single-in-single-out (SISO) cases),  $2m$  (e.g., in the  $dq$  or  $\alpha\beta$  frame) or  $3m$  (e.g., in the  $dq0$  or  $abc$  frame).

In both state-space-based and impedance-based modeling, there are variables under observation and matrices indicating the relationship between the variables. The vector containing the variables under observation is the *state vector*, i.e.,  $\mathbf{x}_{MG}$  in (1) or  $[V_{conv,I}, I_{conv,II}]^T$  in (3). One of the matrices can be regarded as the *representative matrix*, which describes the overall architecture and is normally the largest one, for example,  $\mathbf{A}_{MG}$  in (1) or  $\mathbf{Y}_{MG}$  in (2). The size of the representative matrix determines the space complexity of the modeling method in computation, as listed in [20].

Based on the basics and the assumptions above, two metrics are thereby defined to evaluate the modeling complexity, *maximum-order complexity* (MOC) and *apparent-order complexity* (AOC).

MOC is aimed at estimating a lower bound of the complexity of modeling methods when all couplings are neglected:

**Definition I:** The MOC is defined as the sum of:

- Vector Part (VP): the total order of calculation directly applied to the state vector;*
- Matrix Part (MP): the sum of maximum orders of each row of the representative matrix.*

Furthermore, AOC can be used to include the non-diagonal elements in state matrices or admittance matrices as well and to obtain the overall computational burden:

**Definition II:** The AOC is defined as the sum of:

**TABLE 3. Calculation of Maximum-Order Complexity and Apparent-Order Complexity**

		State-Space-Based Modeling	Impedance-Based Modeling
Maximum-Order Complexity (MOC)	Vector Part (VP)	$VP_{SS,MOC} = \sum_{x_i \in x} \text{Ord} \left\{ \frac{d}{dt} x_i \right\} = \lambda$	$VP_{Imp,MOC} = \text{Ord} \left\{ \begin{bmatrix} \frac{V_{conv,1}}{V_{conv,1}}(s) \\ \frac{I_{conv,1}}{I_{conv,1}}(s) \\ \frac{V_{conv,2}}{V_{conv,2}}(s) \\ \frac{I_{conv,2}}{I_{conv,2}}(s) \end{bmatrix} \right\} = \sum_{i=1}^{\mu} \text{Ord} \{g_{1,i}\}$
	Matrix Part (MP)	$MP_{SS,MOC} = \sum_{i=1}^{\lambda} \text{MaxOrd} \{[A_{MG}]_i\} = \sum_{i=1}^{\lambda} \text{Ord} \{a_{MG,ii}\} = 0$	$MP_{Imp,MOC} = \sum_{i=1}^{\mu} \text{MaxOrd} \{[Y_{MG}]_i\} = \sum_{i=1}^{\mu} \text{Ord} \{y_{MG,ii}\}$
Apparent-Order Complexity (AOC)	Vector Part (VP)	$VP_{SS,AOC} = \sum_{x_i \in x} \text{Ord} \left\{ \frac{d}{dt} x_i \right\} = \lambda$	$VP_{Imp,AOC} = \text{Ord} \left\{ \begin{bmatrix} \frac{V_{conv,1}}{V_{conv,1}}(s) \\ \frac{I_{conv,1}}{I_{conv,1}}(s) \\ \frac{V_{conv,2}}{V_{conv,2}}(s) \\ \frac{I_{conv,2}}{I_{conv,2}}(s) \end{bmatrix} \right\} = \sum_{i=1}^{\mu} \text{Ord} \{g_{1,i}\}$
	Matrix Part (MP)	$MP_{SS,AOC} = \sum \text{Ord} \{A_{MG}\} = \sum_{i=1}^{\lambda} \sum_{j=1}^{\lambda} \text{Ord} \{a_{MG,ij}\} = 0$	$MP_{Imp,AOC} = \sum \text{Ord} \{Y_{MG}\} = \sum_{i=1}^{\mu} \sum_{j=1}^{\mu} \text{Ord} \{y_{MG,ij}\}$

Note:  $\text{Ord} \{\cdot\}$  denotes the order of a certain element, and  $\text{MaxOrd} \{\cdot\}$  indicates the maximum order in a group of elements (or elements of a matrix).


- Vector Part (VP): the total order of calculations directly applied to the state vector;*
- Matrix Part (MP): the sum of the orders of all elements in the representative matrix.*

The calculations of AOC and MOC for state-space-based (denoted as the subscript *SS*) and impedance-based (denoted as the subscript *Imp*) modeling are listed in Table 3. The MOC can also be regarded as the size of systems measured by orders instead of the number of converters, where the complexities of controllers are also included. When either advanced controllers are employed or the system consists of more nodes, the MOC will increase in a linear way according to the total order. On the other hand, the AOC for state-space-based modeling is actually equal to the MOC, since the state matrix only consists of scalars. In contrast, for impedance-based modeling, the order of impedances (both lines and loads) across every two converters are additionally included, which means  $AOC \geq MOC$ . In this case, the VP only describes the complexity of the state vector, so it is not necessarily influenced by the coupling relationship between states. The MP, however, is used to look into the representative matrix, where the non-diagonal elements are the coupling. For example, in state-space-based modeling, the MP is always 0, indicating that the coupling among states will not likely influence the modeling complexity. Therefore, the MOC can be regarded as the case where the representative matrix is the sparsest, or MOC can normally be the lower bound of AOC with the same modeling method.

An example is given based on a multi-converter MG to illustrate the metrics. In Fig. 1, all  $m$  converters in parallel are controlled by droop controllers and double-loop voltage regulation. It is assumed that the control framework is uniformly deployed with proportional-integral (PI) controllers in the  $dq$  frame. Transmission lines between the converters can all be regarded as resistor-inductor ( $RL$ ) in series, and the loads are  $RL$  loads.

In each converter, the total order involves:

- The first-order power filters for droop controllers (including both active and reactive power),



**FIGURE 1. An islanded MG with  $m$  converters in parallel. The partition point is used for the impedance-based modeling with 2-part partitioning [10] discussed in Section II-C.**

- The integration of  $\omega$  in  $P$ - $f$  droop,
- The double-loop PI controllers, and
- The  $LC$  filters.

Therefore, the total order of a single converter is obtained as:

$$\begin{aligned} \text{Ord}\{\text{conv}\} &= \underbrace{(1 \times 2 + 1)}_{\text{LPF and } f\omega dt \text{ in droop controllers}} + \underbrace{(1 + 1) \times 2}_{\text{Voltage and current PI controllers (dq)}} + \underbrace{(1 + 1) \times 2}_{\text{LC filter (dq)}} \\ &= 11 \end{aligned} \quad (4)$$


while, the order is obtained as (5) instead if only one of the  $dq$  components is considered (or neglecting the  $dq$  coupling, which is denoted as "single axis" in this paper). In this case, the admittance matrix is  $m \times m$  instead of  $2m \times 2m$ .

$$\begin{aligned} \text{Ord}\{\text{Conv}_{\text{single}}\} &= \underbrace{(1 \times 2 + 1)}_{\text{LPF and } f\omega dt \text{ in droop controllers}} + \underbrace{(1 + 1) \times 1}_{\text{Voltage and current PI controllers}} + \underbrace{(1 + 1) \times 1}_{\text{LC filter}} \\ &= 7 \end{aligned} \quad (5)$$



**TABLE 4. Maximum-Order Complexity and Apparent-Order Complexity in Terms of the Number of Converters**

	State-Space-Based Modeling	Impedance-Based Modeling
Maximum-Order Complexity (MOC)	$MOC_{SS} = \underbrace{1 \cdot (17m - 2)}_{\text{VP: state variables}} + \underbrace{0 \cdot (17m - 2)}_{\text{MP: state matrix}} = 17m - 2$	$MOC_{Imp} = \underbrace{11 \cdot m}_{\text{VP: } m \text{ Converters}} + \underbrace{1 \cdot 2m}_{\text{MP: } 2m \times 2m \text{ } Y_{MG} \text{ Network of lines and loads}} = 13m, \text{ } MOC_{Imp, \text{ single}} = 8m$
Apparent-Order Complexity (AOC)	$AOC_{SS} = \underbrace{1 \cdot (17m - 2)}_{\text{VP: state variables}} + \underbrace{0 \cdot (17m - 2)^2}_{\text{MP: state matrix}} = 17m - 2$	$AOC_{Imp} = \underbrace{11 \cdot m}_{\text{VP: } m \text{ Converters}} + \underbrace{1 \cdot (2m)^2}_{\text{MP: } 2m \times 2m \text{ } Y_{MG} \text{ Network of lines and loads}} = 4m^2 + 11m, \text{ } AOC_{Imp, \text{ single}} = m^2 + 7m$




**FIGURE 2. Comparison of AOC as the number of converters increases.**


Accordingly, the MOC and AOC of the two modeling methods are calculated and listed in Table 4. Apart from the given modeling methods, there are advanced modeling methods such as harmonic-domain Toeplitz matrix in [24], wherein the complexity can also be evaluated similarly. It can be concluded that, the MOC is in the increasing rate of  $O(m)$  (i.e., being bounded by  $m$  multiplied by finite constants), or linearly related to the size of system. The AOC, which is related to the total number of differentials in the mathematical model, increases faster in impedance-based modeling and shows the major differences of the modeling methods. Technically, the AOC could be used for evaluating the relative computational burden of modeling methods, while the MOC could be used as a benchmark for e.g., improving the modeling for sparse matrices.

### C. MAPPING OF THE MODELING METHODS BY COMPLEXITY

After the calculation of respective MOC and AOC, the modeling methods can be subsequently mapped to MGs with different sizes. Taking the case in Fig. 1 as an example, the increase of complexity can be plotted in Fig. 2. Another modeling method introduced in [10] is also compared together, namely the impedance-based modeling by partitioning a MG into two parts (the *grid part*, a voltage source with serial impedance  $Z_g$ , and the *load part*, a current source with parallel impedance  $Z_0$ ). For this method, it should be noted that  $[Z_g, Z_0]^T$  is regarded as the representative matrix, and the modeling is always under the *single-axis* condition.



**FIGURE 3. Comparison of relative apparent-order complexity as the number of converters increases, where the base value is  $2m$ .**




**FIGURE 4. Comprehensive mapping of the modeling methods for stability in MGs by applications.**

The modeling methods show significant differences in large-scale systems. For example, if both the  $d$  and  $q$  components are modeled when there are 10 converters, the AOC of impedance-based modeling (510) is almost three times to that of the state-space-based modeling (168), which indicates that the state-space-based modeling is more appropriate. However, if the  $d$  and  $q$  components are symmetric, impedance-based modeling is simpler in return. More generally, the impedance-based method is more suitable for smaller systems, while the state-space-based method for larger ones, and the boundary can be defined by the proposed metrics.

#### Remark II:

- In this case, all converters are assumed to be with the same PI control scheme and filters, but this framework is




**FIGURE 5.** System for illustrating the stability validation based on the proposed quantitative metrics. To simplify the analysis, the transient of DC link is neglected.

**TABLE 5.** Parameters of the Validations



Parameters	In simulations	In experiments
AC Voltage $V_n$	230 V / 50 Hz	110 V / 50 Hz
Switching frequency $f_{sw}$	10 kHz	10 kHz
Line inductance $L_{line1}$	1.0 mH	—
Line inductance $L_{line2}$	1.5 mH	1.5 mH
Load Resistance $R_{load}$	115 $\Omega$	57.5 $\Omega$
		115 $\Omega$ in parallel for Case II
$P$ - $f$ droop coefficient $m_p$	$9.4 \times 10^{-5}$	$9.4 \times 10^{-5}$
$Q$ - $V$ droop coefficient $n_q$	$1.3 \times 10^{-3}$	$1.3 \times 10^{-3}$
Voltage loop $K_{pv}$	0.0675	0.04
Voltage loop $K_{iv}^{-1}$	390	168 for Case I 162 for Case II
Current loop $K_{pc}$	10.5	10.5
Current loop $K_{ic}$	16000	16000

Note 1: In experiments,  $K_{iv}$  is selected differently for verifying steady-state case (Case I) and dynamic case (Case II), since a relatively stable operation point is required in Case II.




**FIGURE 6.** Eigenvalue loci of the system in simulations: with (blue asterisk) and without (red cross) the decoupling of the  $dq$  components in current loop.

also applicable for heterogeneous controllers. If e.g., advanced controllers are employed, the pattern of the curve may vary. Based on Table 3, the number of converters and the number of the states will both contribute to the total computational burden as revealed by the proposed metrics.




**FIGURE 7.** Load voltage and current by simulations when (a) the  $dq$  decoupling is enabled, and (b) the  $dq$  decoupling is disabled.



**FIGURE 8.** Configuration of the experimental setup, including power amplifier as the source, 2 converter racks, passive filters and resistive loads. Two DC-AC converters are inside each converter rack.

- The metrics are an estimation of the modeling complexity, while the actual complexity can also be decreased by e.g., the cancellation of zeros and poles in impedance-based modeling, which requires deeper inspection with specific parameters. Methods like model-order reduction by clustering of nodes [25], [26] can also reduce the complexity.
- If there are nested advanced operations, e.g., taking the inversion of impedance matrix to get the admittance matrix, the proposed metrics are still taking the major part of modeling complexity, but may not be linearly related to the computation time in practice.



**FIGURE 9.** Eigenvalue loci of the system in experiments: with (blue asterisk) and without (red cross) the decoupling of the  $dq$  components in current loop.

To reflect the differences of the modeling methods more clearly, the number of independent state variables under observation can be chosen as a base value of the complexity, denoted as the *freedom* or *rank* of the state variables. The AOC is thereby normalized into *relative AOC*. For example, in Fig. 1, if the output voltage and current of the  $m$  converters are the focus, the base value will be  $2m$ . But when the load current is included, the base value will be  $3m-1$ , where the Kirchhoff's equations will reduce the freedom of currents by 1. In principle, this base value reflects the relative scale of a MG system similar to the MOC, but it is only determined by the number of nodes (system architecture) and the observed variables, without focusing on the internal complexity (controllers, filters, etc.) of each node.


In the case where the base value is  $2m$ , the relative AOC is plotted in Fig. 3.

In this way, the intersection points can be illustrated more clearly by the base value, and the increasing rate of relative AOC can show the scalability of modeling methods: The lower the increasing rate is, the higher this method allows adaptation for larger-scale systems.


#### D. MAPPING OF THE MODELING METHODS BY APPLICATIONS

Stability modeling methods may also vary by applications. The tools employed in the modeling procedure can be mapped by the respective accuracy in certain applications. Based on Table 1 and our previous study [20], a comprehensive mapping can be concluded in Fig. 4. The frequency under study and the linearization in the modeling are illustrated.

The modeling methods can thereby be properly linked with the scale of the MG system and the applications under study. The accuracy of a modeling method is the rationality of




(a)



(b)

**FIGURE 10.** Load voltage (Phase A) and current by experiments when (a) the  $dq$  decoupling of current loop is enabled, and (b) the  $dq$  decoupling of current loop is disabled. The load is  $57.5 \Omega$ .



**FIGURE 11.** Variation of load voltage (Phase A) and current when  $dq$  decoupling of current loop is disabled. The load changes from 0.6 kW to 0.9 kW.

possible modeling results, while the proposed metrics basically sort the eligible methods by complexity, measuring the amenity of the modeling methods. For example, the resonance in single- or double-converter systems can easily be revealed by impedance-based modeling with Bode plots. But eigenvalue loci in state-space-based modeling is more suitable for multi-converter system or cases regarding  $dq$  coupling where the number of states is double of that in symmetric cases.

It has to be noted that, the mapping is not unique in most cases, but it could serve as a clear and practical guideline



for optimizing the modeling methods. There also exist cases, where certain modeling methods can best fulfill the requirement, e.g., phasor portraits for transient stability [27].

### III. CASE STUDY FOR STABILITY VALIDATIONS

To illustrate the stability validation based on the proposed quantitative mapping, a simple case is selected for simulations and experimental tests. As shown in Fig. 5, the system consists of two parallel converters with droop controllers and  $LC$  filters. A resistive load is connected to the point of common coupling (PCC). The DC link is created by rectifying from a 230 V from the AC end. The objective is to verify the role of  $dq$  decoupling in the current loop (the feedforward terms related to  $\omega_0 L_f$ ), which is consequently enabled or disabled for comparing the differences in stability performances.

Parameters of the validations are listed in Table 5. The parameters of simulations and experiments are different due to available hardware configurations. In experiments, Case I is aimed to verify the steady-state performance, and Case II is focused on dynamics.

Based on the proposed complexity metrics, the AOC of state-space-based modeling is:

$$AOC_{SS} = \underbrace{11 \times 2}_{2 \text{ Converters}} + \underbrace{2 \times 2}_{2 \text{ Lines}} = 26 \quad (6)$$

The AOC of impedance-based modeling is:

$$AOC_{Imp} = \underbrace{11 \times 2}_{VP: 2 \text{ converters}} + \underbrace{1 \times 4^2}_{MP: 4 \times 4 Y_{MG}} = 38 \quad (7)$$

Therefore, state-space-based modeling is more appropriate in this case with less complexity, and eigenvalue loci is capable of evaluating the stability of the system.

Similar to [7], the MG can be modeled into the following small-signal state space:

$$\frac{d}{dt} \begin{bmatrix} \Delta \mathbf{x}_{conv} \\ \Delta \mathbf{i}_{line} \\ \Delta \mathbf{i}_{load} \end{bmatrix} = \mathbf{A}_{MG} \begin{bmatrix} \Delta \mathbf{x}_{conv} \\ \Delta \mathbf{i}_{line} \\ \Delta \mathbf{i}_{load} \end{bmatrix} \quad (8)$$

where,  $\mathbf{x}_{conv}$  consists of the state variables of converters:

$$\Delta \mathbf{x}_{conv} = \begin{bmatrix} \Delta \mathbf{x}_{conv,1} \\ \Delta \mathbf{x}_{conv,2} \end{bmatrix} \quad (9)$$

$$\Delta \mathbf{x}_{conv,k,dq} =$$

$$\Delta [\delta_k \quad P_k \quad Q_k \quad E_{v,k,dq} \quad E_{i,k,dq} \quad i_{s,k,dq} \quad v_{o,k,dq} \quad i_{o,k,dq}]^T \quad (10)$$

where, for the  $k$ -th converter,  $i_s$  is the current of filter inductors,  $v_o$  and  $i_o$  are, respectively, the voltage and current at the output of  $LC$  filters, and  $E_v$  and  $E_i$  are the integral error of  $v_o$  and  $i_s$ , respectively. The subscript  $dq$  indicates that the MG is modeled in a  $dq$  frame synchronized at the PCC.

### A. SIMULATION RESULTS

Based on the state space and the given parameters, the eigenvalue loci of the system can be plotted in Fig. 6. According to the eigenvalue loci, there are right-half-plane (RHP) poles

when the  $dq$  decoupling is disabled, which indicates the potential instability of the system. Simulations based on PLECS is then conducted, as shown in Fig. 7.

In the simulations, when the  $dq$  decoupling is disabled, the waveforms are distorted with harmonics with the frequency around 1.1 kHz, which accords with the eigenvalue loci in Fig. 6, as there are RHP poles. It preliminarily illustrates the application of the proposed metrics for complexity evaluation.

### B. EXPERIMENTAL RESULTS

The configuration of the experimental setup is shown in Fig. 8. Two converter racks are used, each consisting of two three-phase 7.5-kW DC-AC converters. Different from the simulations, only one inductor is employed as the transmission line  $L_{line2}$  in Fig. 6 due to available hardware configurations.

Similar to the simulations, the eigenvalue loci of the experimental parameters are plotted in Fig. 9. The control parameters are modified to ensure the performance in the hardware setup. As evident from Fig. 9, there are RHP poles in both cases, but when the  $dq$  decoupling is enabled, the poles are closed to the imaginary axis, so the system can be critically stable. In contrast, the system is much more unstable when the  $dq$  decoupling is disabled, or more likely to diverge under large-signal disturbances.

#### 1) CASE I: STEADY-STATE PERFORMANCE

Experimental results in steady-state case are shown in Fig. 10, where the load is 57.5  $\Omega$ . The voltage and current waveforms are sinusoidal in normal operation, but when the  $dq$  decoupling is disabled, harmonics appear with the frequency of around 550 Hz, indicating the instability of the system.

#### 2) CASE II: DYNAMIC PERFORMANCE

Further results are presented in Fig. 11. In this case, the load is changed from 0.6 kW (57.5  $\Omega$ ) to 0.9 kW (another 115  $\Omega$  in parallel). The system can be critically stable when the operation point is carefully selected. However, it will lose its stability in response to large-signal disturbances, when the coupling between  $dq$  components will boost the disturbances.

Therefore, it can be concluded that the selected modeling methods mapped by the quantitative metrics is eligible in this case for stability validation. Generally, the mapping of modeling methods could be well employed in stability validations especially for MGs with a large number of converters or high penetration of RES, where the difference between methods will be even more significant.

### IV. CONCLUSION


In this paper, the modeling methods for stability validation of microgrids are mapped in terms of the properties of microgrids and the focus of study in practice. The modeling methods may differ in complexity and accuracy regarding different applications. Quantitative metrics for evaluating the complexity of modeling methods are proposed, which is obtained based on the order of system, and the metrics have been

proved to be feasible and able to clearly reflect the complexity difference between the methods. A study case with simulation and experimental results is presented, demonstrating the validation of stability based on the proposed quantitative mapping policies.


The mapping of modeling methods can serve as a practical step in the stability validation of microgrid systems, and can effectively formalize the validation of stability in microgrids. However, the mapping in this paper is aimed at optimize the validations with the particular objective of complexity reduction, which could vary and accordingly determine the definition of the metrics. Besides, the topologies of converters in microgrids like multi-level converters remain unconsidered in this paper, which could be a future extension of this topic.

## REFERENCES

- [1] F. Blaabjerg and K. Ma, "Future on power electronics for wind turbine systems," *IEEE J. Emerg. Sel. Top. Power Electron.*, vol. 1, no. 3, pp. 139–152, Sep. 2013.
- [2] Q. Peng, Q. Jiang, Y. Yang, T. Liu, H. Wang, and F. Blaabjerg, "On the stability of power electronics-dominated systems: Challenges and potential solutions," *IEEE Trans. Ind. Appl.*, vol. 55, no. 6, pp. 7657–7670, Nov./Dec. 2019.
- [3] M. Farrokhabadi et al., "Microgrid stability definitions, analysis, and examples," *IEEE Trans. Power Syst.*, vol. 35, no. 1, pp. 13–29, Jan. 2020.
- [4] J. Fang, H. Li, Y. Tang, and F. Blaabjerg, "On the inertia of future more-electronics power systems," *IEEE J. Emerg. Sel. Top. Power Electron.*, vol. 7, no. 4, pp. 2130–2146, Dec. 2019.
- [5] Y. Song, S. Sahoo, Y. Yang, and F. Blaabjerg, "System-level stability of the CIGRE low voltage benchmark system: Definitions and extrapolations," in *Proc. IEEE 22nd Workshop Control Modelling Power Electron.*, 2021, pp. 1–6.
- [6] D. Boroyevich, I. Cvetković, D. Dong, R. Burgos, F. Wang, and F. Lee, "Future electronic power distribution systems – A contemplative view," in *Proc. 12th Int. Conf. Optim. Elect. Electron. Equip.*, 2010, pp. 1369–1380.
- [7] N. Pogaku, M. Prodanovic, and T. C. Green, "Modeling, analysis and testing of autonomous operation of an inverter-based microgrid," *IEEE Trans. Power Electron.*, vol. 22, no. 2, pp. 613–625, Mar. 2007.
- [8] Y. Wang, X. Wang, F. Blaabjerg, and Z. Chen, "Harmonic instability assessment using state-space modeling and participation analysis in inverter-fed power systems," *IEEE Trans. Ind. Electron.*, vol. 64, no. 1, pp. 806–816, Jan. 2017.
- [9] X. Wang, F. Blaabjerg, and W. Wu, "Modeling and analysis of harmonic stability in an AC power-electronics-based power system," *IEEE Trans. Power Electron.*, vol. 29, no. 12, pp. 6421–6432, Dec. 2014.
- [10] J. Sun, "Impedance-Based stability criterion for grid-connected inverters," *IEEE Trans. Power Electron.*, vol. 26, no. 11, pp. 3075–3078, Nov. 2011.
- [11] X. Wang, L. Harnefors, and F. Blaabjerg, "Unified impedance model of grid-connected voltage-source converters," *IEEE Trans. Power Electron.*, vol. 33, no. 2, pp. 1775–1787, Feb. 2018.
- [12] K. Ma, W. Tang, R. Cheng, and Y. Song, "Modeling of interconnected voltage and current controlled converters with coupled LC-LCL filters," *IEEE Trans. Power Electron.*, vol. 36, no. 4, pp. 3995–4005, Apr. 2021.
- [13] Y. Li, Y. Gu, Y. Zhu, A. Junyent-Ferre, X. Xiang, and T. C. Green, "Impedance circuit model of grid-forming inverter: Visualizing control algorithms as circuit elements," *IEEE Trans. Power Electron.*, vol. 36, no. 3, pp. 3377–3395, Mar. 2021.
- [14] S. Peyghami, P. Davari, M. Fotuhi-Firuzabad, and F. Blaabjerg, "Standard test systems for modern power system analysis: An overview," *IEEE Ind. Electron. Mag.*, vol. 13, no. 4, pp. 86–105, Dec. 2019.
- [15] S. Papathanassiou, N. D. Hatziaargyriou, and K. Strunz, "A benchmark low voltage microgrid network," in *Proc. CIGRE Symp.: Power Syst. Dispersed Gener.*, Apr. 2005, pp. 1–8.
- [16] W. Du et al., "Modeling of grid-forming and grid-following inverters for dynamic simulation of large-scale distribution systems," *IEEE Trans. Power Del.*, vol. 36, no. 4, pp. 2035–2045, Aug. 2021.
- [17] Q. Xu, X. Wang, M. G. Taul, and F. Blaabjerg, "Conceptual systematic stability analysis of power electronics based power systems," in *Proc. IEEE Energy Convers. Congr. Expo.*, 2019, pp. 2232–2238.
- [18] L. Fan and Z. Miao, "Admittance-based stability analysis: Bode plots, nyquist diagrams or eigenvalue analysis?," *IEEE Trans. Power Syst.*, vol. 35, no. 4, pp. 3312–3315, Jul. 2020.
- [19] L. Huang, C. Wu, D. Zhou, and F. Blaabjerg, "Comparison of three small-signal stability analysis methods for grid-following inverter," in *Proc. Int. Aegean Conf. Elect. Machines Power Electron. Int. Conf. Optim. Elect. Electron. Equip.*, 2021, pp. 34–41.
- [20] Y. Song, S. Sahoo, Y. Yang, and F. Blaabjerg, "System-level mapping of modeling methods for stability characterization in microgrids," in *Proc. IEEE Energy Convers. Congr. Expo.*, 2021, pp. 2943–2949.
- [21] J. Liu and M. Molinas, "Impact of digital time delay on the stable grid-hosting capacity of large-scale centralised PV plant," *IET Renewable Power Gener.*, vol. 15, no. 7, pp. 1422–1435, 2021.
- [22] C. Dong, S. Yang, H. Jia, and P. Wang, "Padé-based stability analysis for a modular multilevel converter considering the time delay in the digital control system," *IEEE Trans. Ind. Electron.*, vol. 66, no. 7, pp. 5242–5253, Jul. 2019.
- [23] S. Golestan, J. M. Guerrero, and J. C. Vasquez, "Three-phase PLLs: A review of recent advances," *IEEE Trans. Power Electron.*, vol. 32, no. 3, pp. 1894–1907, Mar. 2017.
- [24] C. Zhang, M. Molinas, S. Føyen, J. A. Suul, and T. Isobe, "Harmonic-Domain SISO equivalent impedance modeling and stability analysis of a single-phase grid-connected VSC," *IEEE Trans. Power Electron.*, vol. 35, no. 9, pp. 9770–9783, Sep. 2020.
- [25] P. Vorobev, P.-H. Huang, M. Al Hosani, J. L. Kirtley, and K. Turitsyn, "High-fidelity model order reduction for microgrids stability assessment," *IEEE Trans. Power Syst.*, vol. 33, no. 1, pp. 874–887, Jan. 2018.
- [26] A. Gorbunov, J. C.-H. Peng, and P. Vorobev, "Identification of critical clusters in inverter-based microgrids," *Electr. Power Syst. Res.*, vol. 189, Dec. 2020, Art. no. 106731.
- [27] H. Wu and X. Wang, "Design-oriented transient stability analysis of PLL-synchronized voltage-source converters," *IEEE Trans. Power Electron.*, vol. 35, no. 4, pp. 3573–3589, Apr. 2020.



**YUBO SONG** (Student Member, IEEE) received the B.Eng. and M.Sc. degrees in electrical engineering from Shanghai Jiao Tong University, Shanghai, China, in 2016 and 2019, respectively. He is currently working toward the Ph.D. degree with the Department of Energy, Aalborg University, Aalborg, Denmark. From May to July 2022, he was a Visiting Researcher with the University of Alberta, Edmonton, AB, Canada. His research focuses on the stability and reliability of power electronic systems.



**SUBHAM SAHOO** (Member, IEEE) received the B.Tech. and Ph.D. degrees in electrical and electronics engineering from the Veer Surendra Sai University of Technology, Burla, India and electrical engineering with the Indian Institute of Technology, Delhi, New Delhi, India, in 2014 and 2018, respectively. He is currently an Assistant Professor with the Department of Energy, Aalborg University (AAU), Aalborg, Denmark, where he is also the Vice-leader of the Research Group on Reliability of Power Electronic Converters (ReliaPEC), AAU Energy, Aalborg, Denmark. His research interests include control, optimization, stability, and cybersecurity of power electronic systems. He was the recipient of the Indian National Academy of Engineering Innovative Students Project Award for the best Ph.D. thesis across all the institutes in India for the year 2019. He was also a distinguished Reviewer of IEEE TRANSACTIONS ON SMART GRID in the year 2020. He chairs the cybersecurity working Group in the IEEE PELS Technical Committee (TC 10) on Design Methodologies.



**YONGHENG YANG** (Senior Member, IEEE) received the B.Eng. degree in electrical engineering and automation from Northwestern Polytechnical University, Xi'an, China, in 2009, and the Ph.D. degree in energy technology (power electronics and drives) from Aalborg University, Aalborg, Denmark, in 2014. From 2009 to 2011, he was a Postgraduate Student with Southeast University, Nanjing, China. In 2013, he was a Visiting Scholar with Texas A&M University, College Station, TX, USA. During 2014–2020, he was with the Department of Energy Technology, Aalborg University, where he became a tenured Associate Professor in 2018. In January 2021, he joined Zhejiang University, Hangzhou, China, as a ZJU100 Professor. His research focuses on the grid-integration of photovoltaic systems and control of power converters, in particular, grid-forming technologies. Dr. Yang was the Chair of the IEEE Denmark Section during 2019–2020. He was the recipient of the 2018 IET Renewable Power Generation Premium Award, 2021 Richard M. Bass Outstanding Young Power Electronics Engineer Award from the IEEE Power Electronics Society, and 2022 Isao Takahashi Power Electronics Award from the Institute of Electrical Engineers of Japan. In addition, he was also the recipient of two IEEE best paper awards. He was an Outstanding Reviewer for the IEEE TRANSACTIONS ON POWER ELECTRONICS in 2018. He has been included on the list of Highly Cited Chinese Researchers by Elsevier in 2022. He is currently the Secretary of the IEEE PELS Technical Committee on Sustainable Energy Systems and a Council Member of the China Power Supply Society.



**FREDE BLAABJERG** (Fellow, IEEE) received the Ph.D. degree in electrical engineering from Aalborg University, Aalborg, Denmark, in 1995. From 1987 to 1988, he was with ABB-Scandia, Randers, Denmark. He became an Assistant Professor in 1992, Associate Professor in 1996, and a Full Professor of power electronics and drives in 1998. From 2017, he became a Villum Investigator. He is honoris causa with The University Politehnica Timisoara, Timișoara, Romania, and Tallinn Technical University, Tallinn, Estonia. His research

interests include power electronics and its applications, such as in wind turbines, PV systems, reliability, harmonics, and adjustable speed drives. He was the recipient of 32 IEEE Prize Paper Awards, the IEEE PELS Distinguished Service Award in 2009, EPE-PEMC Council Award in 2010, IEEE William E. Newell Power Electronics Award 2014, Villum Kann Rasmussen Research Award 2014, Global Energy uPrize in 2019 and 2020 IEEE Edison Medal. From 2006 to 2012, he was the Editor-in-Chief of the IEEE TRANSACTIONS ON POWER ELECTRONICS. He was a Distinguished Lecturer of the IEEE Power Electronics Society from 2005 to 2007 and IEEE Industry Applications Society from 2010 to 2011 and 2017 to 2018. During 2019–2020, he was the President of the IEEE Power Electronics Society. He is the Vice-President of the Danish Academy of Technical Sciences. He is nominated in 2014–2019 by Thomson Reuters to be between the most 250 cited researchers in Engineering in the world.