



Aalborg Universitet

AALBORG UNIVERSITY
DENMARK

Investigation on Moisture and Indoor Environment in Eight Different Danish Houses

Jensen, Rasmus Lund; Jensen, Kasper Risgaard; Nørgaard, Jesper; Justesen, Rasmus
Onsild; Bergsøe, Niels Christian

Publication date:
2011

Document Version
Accepted author manuscript, peer reviewed version

[Link to publication from Aalborg University](#)

Citation for published version (APA):

Jensen, R. L., Jensen, K. R., Nørgaard, J., Justesen, R. O., & Bergsøe, N. C. (2011). *Investigation on Moisture and Indoor Environment in Eight Different Danish Houses*. Abstract from The 9th Nordic Symposium on Building Physics (NSB 2011), Tampere, Finland. <http://webhotel2.tut.fi/nsb2011/>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Investigation on moisture and indoor environment in eight different Danish houses

For many years focus has been on reducing the energy need for heating in buildings. In existing dwellings this is often done by changing the windows and tightening the building. In new buildings air tightness are required leaving the main part of the ventilation of the building in the hands of the occupants either by natural or mechanical ventilation. The increased focus on energy reduction is putting pressure on the requirements for fresh air. Together with the increased demands for comfort where draft from (natural)ventilation is unacceptable to most people there is an increased risk of lowering the indoor air quality and increasing the relative humidity that might leads to mould problems.

This paper describes an investigation of the indoor air quality, relative humidity and air change rate in eight different Danish dwellings all having problems with condensation on the windows. The dwellings where erected between 1930 and 2007. Some where only slightly renovated and others where completely renovated. Most where naturally ventilated.

In each house temperature, relative humidity and CO₂ where measured in all primary rooms a long with the outdoor conditions. The total air change rate of the house where measured by passive tracer gas technique over a period of one to two weeks.

Based on the measurements the ventilation of the buildings was compared to the build regulation (air change rate), indoor air quality (CO₂ level) and the use of the building (level of relative humidity). The results showed large variations between the eight houses but also between the three different measurements and thereby showing that the requirements in the Danish building regulations on fresh air as a function of the number of square metre can lead to both poor indoor air quality and high level of relative humidity but also to unnecessary energy use in the case where a large house are occupied by few people. An estimate on the moister production in the houses where made and compared to the values given in the literature. The moisture production in most houses where significantly higher than the values given in the literature.

Keywords: moisture production, passive tracer gas technique, air change rate, condensation on windows

Rasmus Lund Jensen

Kasper Risgaard Jensen, ph.d. stud, AAU Nano

Jesper Nørgaard, Studmedhjælp

Rasmus O. Justesen, Studmedhjælp

Niels Christian Bergsøe, SBI