



## A Distributed Control Strategy Based on DC Bus Signaling for Modular Photovoltaic Generation Systems With Battery Energy Storage

Sun, Kai; Zhang, Li; Xing , Yan ; Guerrero, Josep M.

*Published in:*

I E E E Transactions on Power Electronics

*DOI (link to publication from Publisher):*

[10.1109/TPEL.2011.2127488](https://doi.org/10.1109/TPEL.2011.2127488)

*Publication date:*

2011

*Document Version*

Early version, also known as pre-print

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*

Sun, K., Zhang, L., Xing , Y., & Guerrero, J. M. (2011). A Distributed Control Strategy Based on DC Bus Signaling for Modular Photovoltaic Generation Systems With Battery Energy Storage. *I E E E Transactions on Power Electronics*, 26(10), 3032-3045. <https://doi.org/10.1109/TPEL.2011.2127488>

### General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

### Take down policy

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# A Distributed Control Strategy based on DC Bus Signaling for Modular Photovoltaic Generation Systems with Battery Energy Storage

Kai Sun, Li Zhang, Yan Xing, and Josep M. Guerrero

**Abstract:** Modular generation system, which consists of modular power conditioning converters, is an effective solution to integrate renewable energy sources with conventional utility grid to improve reliability and efficiency, especially for photovoltaic generation. A distributed control strategy based on improved DC bus signaling is proposed for modular photovoltaic(PV) generation system with battery energy storage elements. In this paper, the modular PV generation system is composed of three modular DC/DC converters for photovoltaic arrays, two grid-connected DC/AC converters, one DC/DC converter for battery charging/discharging and local loads, which is available of either grid-connected operation or islanding operation. By using the proposed control strategy, the operations of modular PV generation system are categorized into four modes: islanding with battery discharging, grid-connected rectification, grid-connected inversion and islanding with constant voltage generation. The power balance of the system under extreme conditions such as the islanding operation with full-charged battery is taken into account in this control strategy. The DC bus voltage level is employed as an information carrier to distinguish different modes and determine mode switching. Control methods of modular DC/DC converters, battery converter and grid-connected converter are addressed. An autonomous control method for modular DC/DC converters is proposed to realize smooth switching between constant voltage operation and MPPT operation, which enables the DC bus voltage regulation capability of modular DC/DC converters. Seamless switching of battery converter between charging and discharging and that of grid-connected converter between rectification and inversion are ensured by the proposed control methods. Experiments verify the practical feasibility and the effectiveness of the proposed control strategies.

**Index terms:** Distributed control; DC bus signaling; Modular system; Photovoltaic generation; Battery energy storage;

Kai Sun is with State Key Lab of Power Systems, Department of Electrical Engineering, Tsinghua University, Beijing, China. (e-mail: sun-kai@mail.tsinghua.edu.cn)

Li Zhang and Yan Xing are with the Aero-Power Sci-Tech Center, Nanjing University of Aeronautics and Astronautics, Nanjing, China (e-mail: zhanglinuaa@nuaa.edu.cn; xingyan@nuaa.edu.cn)

J. M. Guerrero is with the Department of Automatic Control Systems and Computer Engineering, Universitat Politècnica de Catalunya, 08036 Barcelona, Spain and also with the Department of Energy Technology, Aalborg University, Aalborg 9220, Denmark (e-mail: josep.m.guerrero@upc.edu, joz@et.aau.dk).

## I INTRODUCTION

During recent years, the utilization of renewable energy sources has been promoted quickly to fulfill increasing energy demand and deal with global climate change. Since the distributed power generation by renewable energy has different characteristics with conventional power generation by fossil fuels, novel configurations, topologies and control techniques are employed to integrate renewable energy sources with utility grid [1]-[6]. As the cost decreases continuously, photovoltaic (PV) generation has become one of the most important renewable energy sources and has been widely used. A review of grid-connected inverters for photovoltaic modules shows that there are four topologies used in PV generation systems as shown in Fig.1 [6]. Considering cost and efficiency, multi-string topology is one of the most widely used solutions for PV generation as well as AC module topology [6][7]. As shown in Fig.1(c), the DC-DC converters for each string of PV modules can be implemented with modular design and share a DC bus, which connects AC utility grid through a DC-AC converter. This configuration has the potential to be extended to a DC bus based modular PV generation system, not only the modular DC/DC converters and DC/AC converters, but also the energy storage devices and local loads can be connected through DC bus. It will be an effective solution for the future applications of PV generation.

Due to the stochastic characteristic of PV generation, energy storage elements are indispensable to smooth the power flow and provide the electric energy with high quality. Lots of efforts have been carried out by the researchers on the integration and coordination of PV generation and energy storage elements. Multifunctional power converters are developed to integrate batteries as the backup for PV generation systems [8][9]. PV generation and battery are used coordinately to feed utility grid or plug-in hybrid electric vehicle (PHEV) load [10]-[12]. In these works, different power conditions and battery capacity limit are taken into account, but the islanding operation has not been considered. In grid-connected PV systems, the incorporation of




Fig.1 Configurations of PV generation systems

battery storage can improve the energy production, especially in presence of mismatching conditions. However, the upper/lower limits of state of charge (SoC) for batteries are usually ignored [13][14], which influences the effective utilization of battery storage. In order to minimize the demanded battery capacity, the so-called “smoothing-effect” has been investigated, which dumps the power flow fluctuation by using multi PV systems with different locations [15]. Besides batteries, fuel cells are also employed to smooth the energy production profile of grid-connected PV systems [16][17]. Although the control flexibility can be improved by diverse energy storage elements, high cost is still a critical issue for the generation system. Some stand-alone PV generation systems with energy storage are developed for residential and rural applications [18]-[21]. In these systems, the SoC limits of batteries during islanding operation are considered, but grid-connected power flow is not taken into account. Hybrid energy storage system, which consists of batteries and supercapacitors, is used to optimize the energy utilization and minimize the energy storage capacities [18][19]. Only a few literatures mention the control of DC bus based modular PV system with battery [22], but the detailed power management scheme and the SoC limits are not presented.

Based on the above review of previous works, it can be found that the researches on power management control for modular PV generation system are very rare and the existing control techniques can not be moved to modular PV generation system directly. In order to fulfill the requirements by distributed generation and optimize the energy utilization, the control of modular

PV generation systems with battery storage must have the following functions: 1) The reasonable power distribution among different modular converters should be ensured; 2) The system can be operating either at grid-connected mode or islanding mode; 3) The SoC limits (full-charged or full-discharged) of batteries must be considered.

To enhance the system reliability, a distributed control strategy so-called DC bus signaling (DBS) was applied for a hybrid renewable nanogrid [23][24]. DBS is an extension of the concept of using charge/discharge thresholds to schedule individual sources in a distributed fashion, which induces DC bus voltage level changes to realize the communications between difference source/storage interface converters. By using DBS, the system reliability can be inherently maintained since the DC bus itself is used as the communication link [24]. However, this control strategy is not suitable for modular PV generation system because: 1) The interaction with AC utility grid is not included; 2) The control method is developed for individual renewable sources, while not for modular sources; 3) Some extreme conditions such as the islanding operation with full-charged are not mentioned, which means the power regulation capability of battery is deteriorated.

In this paper, the DBS method has been improved for both grid-connected operation and islanding operation. A novel distributed control strategy based on DBS is proposed for the modular PV generation system. The configuration of DC bus based modular PV generation system with AC grid connection and battery storage is presented in Section II. A power management scheme taking full-charged battery conditions into account and control methods for modular DC/DC converters, grid-connected converters and battery converter are addressed in Section III. Experimental results are shown in Section IV and Section V concludes the works.

## **II SYSTEM CONFIGURATION**

The DC bus based modular photovoltaic generation system investigated in this paper is shown in Fig.2. Three modular DC/DC converters for PV arrays, two modular bi-directional DC/AC converters, a bi-directional DC/DC converter for battery and local loads share a DC bus. The modular DC/DC converters are the key elements in this system, which are implemented with modular design and same ratings. These modular DC/DC converters transfer the power generated by PV arrays to DC bus. The modular bi-directional DC/AC converters are used to connect the DC bus and AC utility grid, which enable bi-directional power flow. The battery with bi-directional DC/DC converter is used to balance the power differences between PV power supplies and local loads in islanding mode. The local loads include the auxiliary power supplies for system

operations, such as control/monitoring of PV arrays, battery monitoring, control/driving of converters.

Since the elements and devices in this system can be summarized into three categories: energy generation unit, energy storage unit and loads, the configuration shown in Fig.2 can be considered as a typical case of DC microgrid with renewable generation and energy storage. The control strategies developed for this system can also be applied on DC microgrids.




Fig.2 The DC bus based modular PV generation system

### III DISTRIBUTED CONTROL STRATEGY

The distributed control strategy for modular PV generation system consists of a power management scheme with DC bus signaling and the control methods for power converters.

#### A. Power management scheme with DC bus voltage signaling

In this paper, a power management scheme with DC bus voltage signaling is proposed to maintain the power balance and stable operation of the system under any conditions. In this scheme, the operation of the modular PV generation system is categorized into four modes: Mode I (islanding mode with battery discharging), Mode II (grid-connected mode with rectification), Mode III (grid-connected mode with inversion) and Mode IV (islanding mode with DC bus voltage regulation by PV). These four operation modes are identified by different DC bus voltage levels, which means the DC bus voltage is used as an information carrier. The switching between different modes and the corresponding changes of control methods for converters can be achieved through DC bus voltage changes without additional communication links. This benefits cost reduction and reliability enhancement.

Four operation modes are described as follows:

The nominal DC bus voltage in this system is  $V_{dc\_n}=200V$  and different reference DC bus voltages  $V_{dc\_ref}$  indicate different operation modes.

**Mode I:**  $V_{dc\_ref}=0.9V_{dc\_n}=180V$ . In this mode, the system operates in islanding mode and the DC bus voltage is regulated by battery discharging, which means the generated PV power is less than local load demands. The modular DC/DC converters for PV arrays work with maximum power point tracking (MPPT) and the grid-connected bi-directional DC/AC converters are disabled. Hence, this mode is called as the islanding mode with battery discharging.

**Mode II:**  $V_{dc\_ref}=0.95V_{dc\_n}=190V$ . In this mode, the system operates with connection to AC grid through bi-directional DC/AC converters. The DC bus voltage is regulated by the DC/AC converters through rectification, which means the generated PV power is less than local load demands. The modular DC/DC converters for PV arrays work with MPPT. If the battery has been fully charged, the DC/DC converter for battery does not work, otherwise the DC/DC converter is used to charge the battery. Hence, this mode is called as the grid-connected mode with rectification.

**Mode III:**  $V_{dc\_ref}=V_{dc\_n}=200V$ . In this mode, the system operates with connection to AC grid through bi-directional DC/AC converters. The DC bus voltage is regulated by the DC/AC converters through inversion, which means the generated PV power is greater than the local load demands. The modular DC/DC converters for PV arrays work with MPPT. If the battery has been fully charged, the DC/DC converter for battery does not work, otherwise the DC/DC converter is used to charge the battery.

**Mode IV:**  $V_{dc\_ref}=1.05V_{dc\_n}=210V$ . In this mode, the system operates in islanding mode and the DC bus voltage is regulated by modular DC/DC converters for PV arrays. Since the maximum power of PV arrays in this mode is greater than the local load demands, the modular DC/DC converters for PV modules must not be all operating with MPPT. Actually one of these modular converters is operating with constant voltage control. If the battery has been fully charged, the DC/DC converter for battery does not work, otherwise the DC/DC converter is used to charge the battery. The grid-connected bi-directional DC/AC converters do not work. Hence, this mode is called as the islanding mode with DC bus voltage regulation by PV.

The operation modes with corresponding DC bus voltage levels are illustrated in Fig.3. The

coefficient difference between different mode voltages is set at 0.05 (0.9, 0.95, 1.0, 1.05). This is determined based on the following considerations: 1) The voltage difference between different modes must not be too small, otherwise the malfunction of mode switching will occur due to the sampling inaccuracies and external disturbance; 2) The voltage difference between different modes should not be too large, otherwise the converters will operate with low voltage and high current, which will probably result in low efficiency and over-current faults. Hence, the voltage difference is set at 10V, which means the coefficient difference is  $0.05(=10V/200V)$ .




Fig.3 Operation modes with corresponding DC bus voltage levels

The functions of DC/DC converters and DC/AC converters in different modes are summarized in Table I. The converter regulating DC bus voltage, which works as a voltage source, is defined as the DC bus forming unit; The converter providing power with DC bus, which works as a current source, is defined as the DC bus feeding unit; The converter absorbing power from DC bus is defined as the load unit.

The power flows of DC/AC converters and battery converter are listed in Table II, where the positive directions of power flows are defined in Fig.2.

TABLE I  
FUNCTIONS OF POWER CONVERTERS UNDER DIFFERENT OPERATION MODES

	Mode I	Mode II	Mode III	Mode IV
DC bus forming	Battery converter (discharging)	Grid-connected converter (rectification)	Grid-connected converter (inversion)	PV converter (constant voltage generation)
DC bus feeding	PV converter (MPPT generation)	PV converter (MPPT generation)	PV converter (MPPT generation)	PV converter (MPPT generation)
DC bus Loading	-	Battery converter (charging)	Battery converter (charging)	Battery converter (charging)


TABLE II  
POWER FLOW UNDER DIFFERENT OPERATION MODES

Mode	Islanding/ Grid-connection	Power flow of DC/AC converters	Power flow of battery converters
I	Islanding	$P_{DC/AC}=0$	$P_{Battery}>0$
II	Grid-connection	$P_{DC/AC}<0$	$P_{Battery}<0$ or $=0$
III	Grid-connection	$P_{DC/AC}>0$	$P_{Battery}<0$ or $=0$
IV	Islanding	$P_{DC/AC}=0$	$P_{Battery}<0$ or $=0$

Generally, the system works at Mode III to utilize PV power fully during the daytime. When the sunshine is insufficient like nighttime or cloudy days, the system moves to Mode II to maintain power balance by using the power from AC grid. Only while the faults occur at AC utility grid, the system has to be disconnected with it. During the islanding operation, the system works at Mode I or Mode IV depending on the PV power conditions (lower or higher than load demands). Thus, the battery energy is only used to feed loads at emergent cases without grid-connection and the battery capacity should be designed to support the islanding operation with enough time required by users.

### B. Equivalent Circuits and Analysis

In order to analyze the system operation clearly, the equivalent circuits have been depicted in Fig.4 by using Thevenin theorem and Norton theorem.






Fig.4 Equivalent circuits of the system under different modes

In Mode I, all the PV converters with MPPT can be considered as current sources and the battery converter works as a voltage source to regulate the DC bus voltage.

Fig.4(b) shows a typical case of Mode II. In Mode II, all the PV converters work with MPPT, which are considered as current sources. Only one DC/AC converter works with non-full power rectification to regulate the DC bus voltage, which is considered as a voltage source. The other DC/AC converter works with full power rectification, which is considered as a current source, or at standby mode according to the power conditions. The battery is charged with constant current until it has been fully charged. The control methods for DC/AC converters and battery converter are presented in Section III.C in detail.

The condition in Mode III is similar to Mode II, as shown in Fig.4(c). In Mode III, all the PV converters work with MPPT, which are considered as current sources. Only one DC/AC converter works with non-full power inversion to regulate the DC bus voltage, which is considered as a voltage source. The other DC/AC converter works with full power inversion, which is considered as a current source, or at standby mode according to the power conditions. The battery is charged with constant current until it has been fully charged. The control methods for DC/AC converters and battery converter are presented in Section III.C in detail.

Fig.4(d) shows a typical case of Mode IV. Only the PV converter with constant voltage

control works as a voltage source, and other PV converters with MPPT work as current sources. The battery is charged with constant current until it has been fully charged

According to the above analysis, it can be found that at any time only one voltage source operates in each mode and all of the other converters work as current sources, which means the DC bus voltage can be regulated at constant in each mode. This characteristic ensures the system stability.

### C. Control methods for DC/DC converters and DC/AC converters

#### 1) A combined control method for modular PV DC/DC converters

Each modular DC/DC converter for PV arrays has two control modes: MPPT control and constant voltage (CV) control. The control diagram is shown in Fig.5.  $V_{dc}$  is the actual DC bus voltage and  $V_{dc\_d}$  is the detected DC bus voltage.  $K_d$  is the sampling coefficient for DC bus voltage detection, which depends on the parameter of sampling circuits. Even though the DC/DC converters for PV arrays are implemented with modular design, they still have some small differences in the values of  $K_d$  due to the component parameter errors in sampling circuits.  $V_{dc\_ref} = 210V$  is the reference voltage for DC bus in Mode IV.  $V_{pv}$ ,  $I_{pv}$  are the output voltage and output current of PV modules respectively.  $V_{MPPT}$  is the reference voltage for PV array.  $D^*$  is the reference duty ratio for DC/DC converters.




Fig.5 Control diagram of each modular DC/DC converter for PV array

When the system is operating in Mode I, II or III, the modular DC/DC converters are controlled with MPPT as current sources. In these modes since the DC bus voltage are regulated within 180V-200V, the output of constant voltage control reaches its positive saturation and has been disabled. When the system works in islanding mode and the generated PV power is greater than the local load, the extra power will be used to charge battery. If the battery has been fully charged, which means SoC reaches 95%, the DC bus voltage will increase. If the DC bus voltage

reaches 210V, the constant voltage controller of the modular DC/DC converter with maximum  $K_d$  will escape from positive saturation first and begin to regulate the DC bus voltage as  $V_{dc\_ref} = 210V$ , while the MPPT controller has been disabled. The modular DC/DC converter with maximum  $K_d$  reduces its output power and controls the output voltage of PV array at a constant value. Thus, the system moves to Mode IV. As shown in Fig.6, when the modular DC/DC converter is operated with constant voltage control the corresponding PV array must work within the right region divided by the dash line.




Fig.6 P-V curve of PV array

If the DC bus voltage increases continuously, the constant voltage controller of the modular DC/DC converter with maximum  $K_d$  will reach negative saturation (zero) and not provide energy with DC bus. Until a modular DC/DC converter for PV array with constant voltage control makes the power balance for the system, the DC bus voltage will be kept at 210V. At this time, the sampling coefficient of this modular DC/DC converter is defined as  $K_{dm}$ . The constant voltage controller outputs of the modular DC/DC converters with the sampling coefficients higher than  $K_{dm}$  are zero and these converters do not supply energy with DC bus; The constant voltage controller outputs of the modular DC/DC converters with the sampling coefficients lower than  $K_{dm}$  are at positive saturation because  $V_{dc\_ref} > K_d * V_{dc}$  and these converters work with MPPT control.

Hence, it is possible to realize that only one modular DC/DC converter works as a voltage source and other converter work in standby mode or as current sources based on the above control method. The key point is the inherent differences of sampling coefficients. In this control method, the basis for mode switching between constant voltage control and MPPT is that the constant voltage controller reaches its positive saturation or not.

If the DC bus voltage decreases resulting from PV power reduction or local load increase,

another modular DC/DC converter will change the operation mode from standby to constant voltage control for power balance. If all the modular DC/DC converters have been working with MPPT and the DC bus voltage decreases to 180V, the battery DC/DC converter will start and provide energy with DC bus by discharging. Then, the system moves to Mode I.

## 2) Control methods for grid-connected DC/AC converters

When AC utility grid is normally operating, the modular PV generation system will be connected to AC grid through the bi-directional DC/AC converters; otherwise it will be disconnected with AC grid to avoid faults occurring. The control for grid-connected DC/AC converters includes two level: ① Parallel control method for modular grid-connected DC/AC converters; ② Local control method for one grid-connected DC/AC converter.

The parallel control method proposed in [25] has been employed in this paper. By using this method, only one modular grid-connected DC/AC converter works with non-full load at a moment, others work with full load or at standby mode. As power increases, the modular DC/AC converters enter full load operation gradually depending on the DC bus sampling coefficients.

The local control method is shown in Fig.7. In Fig.7,  $V_{dc\_ref}$  is the reference voltage for DC bus,  $V_{dc\_d}$  is the detected DC bus voltage,  $I_{INV\_limit}$  is the maximum current limit for DC/AC converter corresponding to its power rating,  $V_{AC}$  is AC grid voltage,  $\theta$  is AC grid phase angle,  $I_{INV}^*$  is the reference output current for DC/AC converter,  $I_o$  is the detected output current of DC/AC converter and  $D^*$  is the duty ratio for DC/AC converter. When the system works in Mode II, the local load demands need to be supplied by the PV generated power and the power from AC grid through the DC/AC converters. In Mode II, the DC bus voltage is regulated at 190V by the rectification operation of the DC/AC converters. When the system works in Mode III, the PV generated power is greater than the local load and extra power will be transferred to AC grid through the DC/AC converters. In Mode III, the DC bus voltage is regulated at 200V by the inversion operation of the DC/AC converters. As shown in Fig.6, the seamless switching between Mode II and Mode III can be realized.

$$I_{INV}^* = (I_{r1} + I_{r2}) * \sin(\theta) \quad (1)$$




Fig.7 Local control diagram of grid-connected DC/AC converter

### 3) Control method for battery DC/DC converter

In Mode I, the battery DC/DC converter is employed as the DC bus forming unit and to regulate the DC bus voltage by battery discharging. If the battery has not been fully charged, which means its SoC (state of charge) is less than 95%, the battery will be charged in Mode II, Mode III and Mode IV. Considering above conditions, the control method for battery DC/DC converter is summarized in Fig.8. In Fig.8,  $V_B$  is the detected battery voltage,  $V_{BH}$  is the battery voltage corresponding to 95% SoC,  $V_{BL}$  is the battery voltage corresponding to 40% SoC,  $I_{BC\_limit}$  is the maximum current limit for battery charging,  $I_{BD\_limit}$  is the maximum current limit for battery discharging,  $I_B^*$  is the reference current for battery converter,  $I_B$  is the detected battery current and  $D^*$  is the duty ratio for DC/DC converter. As shown in Fig.8, the charging/discharging of battery converter is determined by  $I_B^*$ , which is the sum of the charging controller output and discharging controller output.

$$I_B^* = I_{r1} + I_{r2} \quad (2)$$

When  $I_B^* > 0$ , the battery converter is used for discharging; While  $I_B^* < 0$ , the battery converter is used for charging. Hence, the seamless switching between two modes is realized and the hysteresis is not necessary.

As shown in Fig.8, the overcharging protection and overdischarging protection have been taken into account by introducing  $V_{BH}$  and  $V_{BL}$ .




Fig.8 Control diagram of DC/DC converter for battery

#### ***D. Power rating requirements for the elements***

In the design of the system, the following power rating requirements must be fulfilled to ensure that, the proposed control methods can be realized effectively and the system operates safely and stably.

- 1) The maximum discharging power of batteries should be higher than the power demand of critical local loads, which means that the normal operation of critical loads is ensured even in islanding mode.

$$P_{\text{battery\_discharging\_max}} \geq P_{\text{critical\_load}} \quad (3)$$

- 2) The power rating of DC/AC converters must be higher than the sum of maximum local load power and maximum battery charging power to ensure the normal operation of the system in the condition without PV power.

$$P_{\text{DC/AC\_rating}} \geq (P_{\text{load\_max}} + P_{\text{battery\_charging\_max}}) \quad (4)$$

- 3) The maximum available power of PV panels should be greater than the sum of maximum local load power and maximum battery charging power to ensure that the grid-connected power generation can be realized.

$$P_{\text{PV\_max}} \geq (P_{\text{load\_max}} + P_{\text{battery\_charging\_max}}) \quad (5)$$

- 4) The DC/AC converters should be designed to be capable of transferring maximum PV power to AC grid.

$$P_{\text{DC/AC\_rating}} \geq P_{\text{PV\_max}} \quad (6)$$

- 5) The power rating of DC/AC converters is greater than maximum battery discharging is used to ensure the system can switch from Mode I to Mode II automatically.

$$P_{\text{DC/AC\_rating}} \geq P_{\text{battery\_discharging\_max}} \quad (7)$$

#### **IV EXPERIMENTAL VALIDATION**

In order to validate the proposed control methods, experimental tests have been carried out on an experimental setup in lab. The configuration and power flow direction setup is shown in Fig.9.

As shown in Fig.9, the experimental setup consists of 3 PV generation units, 2 grid-connection units, 1 energy storage unit and local resistor load, which are connected through a DC bus. The DC bus voltage is set at 180V, 190V, 200V and 210V according to different operation

modes. The rms value of AC grid voltage is 110V. The selection of experiment voltages (DC180V-210V, AC110V) is mainly based on the safety considerations for lab experiments. In real system, the experiment voltages can be enhanced to DC360V-420V and AC220V, since the power converters have enough power ratings.

Each PV generation unit is constituted by an emulated PV panel and a boost DC/DC converter. A DC voltage source (200V) series-connected with a resistor ( $33.3\Omega$ ) are used to emulate a string of PV panels. Hence, when the PV generation unit is operating with MPPT control, maximum power is 300W and the corresponding MPPT voltage is 100V. MPPT control and constant voltage control for PV generation are realized by the boost DC/DC converter. Two 500W bi-directional DC/AC converters are used as the grid-connection unit, which employs non-isolated single-phase H-bridge topology. A bi-directional Buck-Boost converter and a battery compose the energy storage unit. The nominal voltage of battery is 48VDC. The maximum charging current and maximum discharging current are 1.2A and 10A respectively, which is determined by the battery capacity (12Ah). The photo of experimental setup is shown in Fig.10.

Experimental tests have been carried out in terms of steady-state performance, dynamic performance within one mode (at load power changes or PV power changes), transient performance between different modes. There are totally 12 cases, which are illustrated in Fig.11.

In order to simplify the experimental circuits, only 1# PV generation unit (including emulated PV panel and PV converter) and 2# PV generation unit are connected with DC bus in the experimental tests of Case 1- 9, while 3# PV generation unit is disconnected. In the experimental tests of Case 10-12, all the three PV generation units are connected with DC bus and the DC/AC converters do not work.




Fig.9 Configuration of the experimental setup




Fig.10 Photo of the experimental setup






Fig.11 Cases of the experimental tests

### Case 1: Test results in Mode I

Experimental results during load changes in Mode I are shown in Fig.12. In Fig.12,  $V_{bus}$  is the DC bus voltage,  $I_{B\_Discharge}$  is the discharging current of battery,  $V_{PV1}$  is the input voltage of 1# PV converter, and  $V_{PV2}$  is the input voltage of 2# PV converter. As shown in Fig.12, the input voltages of 1#, 2# PV converter are kept at 100V, which means both of 1# and 2# PV generation units operate at MPPT mode. Since the PV power is greater than local load power in Mode I, the DC bus voltage is regulated at 180V by battery discharging. It can be seen that the DC bus voltage is controlled very well even during load change transitions.



a. Dynamic response at load power increase



b. Dynamic response at load power decrease

Fig.12 Experimental results during load changes in Mode I

### Case 2: Test results in the transition from Mode I to Mode II

Experimental results in the transition from Mode I to Mode II are shown in Fig.13. To simplify the experimental circuits, only one grid-connected DC/AC converter is used in this case. In Fig.13,  $V_{bus}$  is the DC bus voltage,  $I_{B\_Discharge}$  is the discharging current of battery,  $i_{grid}$  is AC grid current of the DC/AC converter and  $v_{grid}$  is AC grid voltage. As shown in Fig.13, after the grid-connected DC/AC converter starts, the DC bus voltage increases and the battery discharging stops. Then, the DC bus voltage is controlled at 190V by the rectification of the DC/AC converter.





Fig.13 Experimental results in the transition from Mode I to Mode II


### Case 3: Test results in Mode II

Dynamic experimental results during load changes with two grid-connected DC/AC converters in Mode II are shown in Fig.14.  $i_{grid1}$  and  $i_{grid2}$  are the AC grid currents of 1# and 2# DC/AC converters respectively. When the load power increases, 2# DC/AC converter changes from non-full load operation to full load operation and 1# DC/AC converter changes from standby mode to non-full load operation due to  $K_{d1} > K_{d2}$  (the DC bus voltage sampling coefficients);

When the load power decreases, 1# DC/AC converter changes from non-full load operation to standby mode and 2# DC/AC converter changes from full load operation to non-full load operation due to  $K_{d1} > K_{d2}$ . The parallel control method for modular DC/AC converters is described in [25]. As can be seen, the dynamic responses of the DC/AC converters to local load power changes are very fast and only a small fluctuation occurs on the DC bus voltage.



a. Dynamic response at load power increase



b. Dynamic response at load power decrease

Fig.14 Experimental results during load changes with two modular DC/AC converters in Mode II

Fig.15 shows the experimental results during a fault occurring. As can be seen, when 2# DC/AC converter is shut down due to fault, 1# DC/AC converter moves from standby mode to normal operation quickly and stably, which realizes hot swapping and enhances the system redundancy.




Fig.15 Experimental results during a fault occurring

#### Case 4: Test results in the transition from Mode II to Mode I

Experimental results in the transition from Mode II to Mode I are shown in Fig.16. In the initial state, 1# and 2# PV generation units operate at MPPT mode, a DC/AC converter works as a rectifier to regulate the DC bus voltage, and the energy storage unit does not work. As shown in Fig.16, after the system is disconnected with AC grid, the DC bus voltage decreases because the local load power is greater than the PV power. Then, the battery DC/DC converter is triggered and starts battery discharging. Finally, the DC bus voltage is regulated at 180V by battery discharging.




Fig.16 Experimental results in the transition from Mode II to Mode I

#### Case 5: Test results in the transition from Mode II to Mode III

Experimental results in the transition from Mode II to Mode III with two DC/AC converters are shown in Fig.17. Due to  $K_{d1} > K_{d2}$ , as rectified power increases 2# DC/AC converter reaches full load operation first during the rectification in Mode II and 1# DC/AC converter reaches full load operation first as inverted power increases during the inversion in Mode III.




Fig.17 Experimental results in the transition from Mode II to Mode III with two DC/AC converters

### Case 6: Test results in Mode III

Steady-state experimental results in Mode III are shown in Fig.18. In this case, since the PV power is greater than local load power the DC/AC converter works as an inverter (AC grid voltage and AC grid current are in phase) and controls the DC bus voltage at 200V. In addition, the battery is charged with constant current (1.2A).




Fig.18 Steady-state experimental results in Mode III

Experimental results on battery overcharging protection in Mode III are shown in Fig.19. When the battery voltage is detected to be equal to  $V_{BH}$ , which means that the SoC of battery reaches 95%, the constant current charging is stopped to avoid overcharging. Correspondingly, AC grid current increases.






Fig.19 Experimental results on battery overcharging protection in Mode III

Experimental results during load changes in Mode III with two DC/AC converters are shown in Fig.20. As can be seen, regardless whether the local load power increases or decreases the DC bus voltage has been kept at the reference voltage with small fluctuations.



a. Dynamic response at load power increase



b. Dynamic response at load power decrease

Fig.20 Experimental results during load changes in Mode III with two DC/AC converters

### Case 7: Test results in the transition from Mode III to Mode II

Experimental results in the transition from Mode III to Mode II with two DC/AC converters

are shown in Fig.21. Due to  $K_{d1} > K_{d2}$ , as rectified power increases 2# DC/AC converter reaches full load operation first during the rectification in Mode II and 1# DC/AC converter reaches full load operation first as inverted power increases during the inversion in Mode III.




Fig.21 Experimental results in the transition from Mode III to Mode II with two DC/AC converters

### Case 8: Test results in the transition from Mode III to Mode IV

Experimental results in the transition from Mode III to Mode IV are shown in Fig.22. In the initial state, 1# and 2# PV generation unit works at MPPT mode (PV converter input voltage 100V), the DC bus voltage is regulated at 200V by the inversion of grid-connected DC/AC converter, and the battery is under constant current charging. As shown in Fig.22, when the system is disconnected with AC grid, the DC bus voltage increases because the PV power is greater than local load power. In order to maintain power balance, 1# PV generation unit changes from MPPT mode to constant voltage (CV) mode (PV converter input voltage 170V) and controls the DC bus voltage at 208V. Although the reference DC bus voltage is 210V, 2V error exists due to the sampling coefficient variations. Since the battery has not been fully charged, the constant current charging continues. As shown in Fig.22, some small oscillations on  $V_{PV1}$  occur during the mode switching transition, which does not cause instability.




Fig.22 Experimental results in the transition from Mode III to Mode IV

### Case 9: Test results in the transition from Mode IV to Mode III

Experimental results in the transition from Mode IV to Mode III are shown in Fig.23. In the initial state, 2# PV generation unit works at MPPT mode, 1# PV generation unit works at CV mode (PV converter input voltage 170V) and regulates the DC bus voltage at 208V, the DC/AC converter does not work, and the battery is under constant current charging. As shown in Fig.23, when the system is connected with AC grid, the DC bus voltage is regulated at 200V by the inversion of the DC/AC converter and 1# PV generation unit changes from CV mode to MPPT mode (PV converter input voltage 100V). Since the battery has not been fully charged, the constant current charging continues.




Fig.23 Experimental results in the transition from Mode IV to Mode III

### Case 10: Test results in Mode IV

In Mode IV, the system is disconnected with AC grid and operates as an island. Since the maximum PV power is greater than the local load power, only one PV generation unit works at CV mode to maintain power balance, and the other PV generation units work at MPPT mode or standby mode.


Independent CV operations of 1#, 2# and 3# PV generation units have been tested. Although the reference DC bus voltage is 210V, the real DC bus voltage is regulated at 208V, 209V and 214V respectively due to different sampling coefficients. Hence, when the load power decrease, the three PV generation units change from MPPT mode to CV mode or standby mode gradually according to the following sequence 1# ->2# -> 3#.

Experimental results at load power changes in Mode IV are shown in Fig.24. In Fig.24,  $V_{bus}$  is the DC bus voltage,  $V_{PV1}$  is the input voltage of 1# PV converter,  $V_{PV2}$  is the input voltage of 2# PV converter,  $V_{PV3}$  is the input voltage of 3# PV converter.


Experimental results at load power decrease in Mode IV are shown in Fig.24(a). In the initial

state, 1# PV generation unit works at CV mode (PV converter input voltage 140V) and regulates the DC bus voltage at 208V, 2# and 3# PV generation units work at MPPT mode (PV converter input voltage 100V). When the load decrease occurs, since the DC bus voltage sampling coefficient of 2# PV generation unit is greater than the one of 3# PV generation unit, 2# PV generation unit changes from MPPT mode to CV mode (PV converter input voltage 150V) and regulates the DC bus voltage at 209V, 1# PV generation unit changes from CV mode to standby mode (PV converter input voltage 200V) and does not generate power, 3# PV generation unit keeps at MPPT mode.

Experimental results at load power increase in Mode IV are shown in Fig.24(b). In the initial state, 1# PV generation unit works at standby mode (PV converter input voltage 200V), 2# PV generation unit works at CV mode (PV converter input voltage 150V) and regulates the DC bus voltage at 209V, 3# PV generation unit works at MPPT mode (PV converter input voltage 100V). When the load increase occurs, 1# PV generation unit changes from standby mode to CV mode (PV converter input voltage 140V) and regulates the DC bus voltage at 208V, 2# PV generation unit changes from CV mode to MPPT mode, 3# PV generation unit keeps at MPPT mode.



a. Dynamic response at load power decrease



b. Dynamic response at load power increase


Fig.24 Experimental results at load power changes in Mode IV

Experimental results at PV power changes in Mode IV are shown in Fig.25. In Fig.25,  $I_{PV3}$  is the input current of 3# PV converter. PV power changes are realized by changing the series-connected resistor as shown in Fig.9.


Experimental results at PV power increase in Mode IV are shown in Fig.25(a). In the initial state, 1# PV generation unit works at standby mode, 2# PV generation unit works at CV mode (PV converter input voltage 120V), 3# PV generation unit works at MPPT mode (PV converter input voltage 100V and input current 3A). When a 150W power increase of 3# PV generation unit occurs, 3# PV generation unit keeps at MPPT mode (PV converter input voltage 100V) and the input current of 3# PV converter increases to 4.5A. The input voltage of 2# PV converter increases to 180V, which means the generated power of 2# PV generation unit is reduced. However, 2# PV generation unit still keeps at CV mode and regulates the DC bus voltage at 209V.

Experimental results at PV power decrease in Mode IV are shown in Fig.25(b). In the initial state, 1# PV generation unit works at standby mode, 2# PV generation unit works at CV mode, 3# PV generation unit works at MPPT mode (PV converter input voltage 100V and input current 4.5A). When a 150W power decrease of 3# PV generation unit occurs, 3# PV generation unit keeps at MPPT mode (PV converter input voltage 100V) and the input current of 3# PV converter decreases to 3A. The input voltage of 2# PV converter decreases, which means the generated power of 2# PV generation unit is enhanced. However, 2# PV generation unit still keeps at CV mode and regulates the DC bus voltage at 209V.

As shown in Fig.24 and Fig.25, the dynamic responses to load power changes and PV power changes are very fast and the overshoots are not severe under the proposed control methods.



a. Dynamic response at PV power increase



b. Dynamic response at PV power decrease

Fig.25 Experimental results during PV power changes in Mode IV

### Case 11: Test results in the transition from Mode IV to Mode I

Experimental results in the transition from Mode IV to Mode I are shown in Fig.26. In the initial state, the system is disconnected with AC grid, the energy storage unit does not work, 1# PV generation unit works at CV mode (PV converter input voltage 130V) and regulates the DC bus voltage at 208V, 2# and 3# PV generation units work with MPPT. When load power increase occurs, 1# PV generation unit changes from CV mode to MPPT mode. However, the PV power is still lower than the load power demands and the DC bus voltage decreases continuously. About 1 second later, the battery discharging is started and the DC bus voltage is regulated at 180V.




Fig.26 Experimental results in the transition from Mode IV to Mode I

### Case 12: Test results in the transition from Mode I to Mode IV

Experimental results in the transition from Mode I to Mode IV are shown in Fig.27. In the initial state, the system is disconnected with AC grid, 1#, 2#, 3# PV generation units work at MPPT mode, the energy storage unit controls the DC bus voltage at 180V by battery discharging. When load power decrease occurs, the DC bus voltage increases and the battery discharging is stopped, 1# PV generation unit changes from MPPT mode to CV mode (PV converter input

voltage 140V) and regulates the DC bus voltage at 208V, 2# and 3# PV generation units keep at MPPT mode.




Fig.27 Experimental results in the transition from Mode I to Mode IV

## V CONCLUSIONS

In this paper, a distributed control strategy based on DC bus signaling for modular photovoltaic generation system with battery energy storage is proposed. The DC bus voltage level is employed as an information carrier to represent different operation modes and determine mode switching. Control methods for modular PV converters, modular grid-connected DC/AC converters and battery converter are developed respectively.

Experimental tests in terms of steady-state performances and dynamic performances (transitions between different modes, load power changes and PV power changes) have been carried out on an experimental setup. The results demonstrate that: 1) The developed system operates stably in islanding mode and grid-connected mode with the proposed control strategy; 2) Smooth transitions between different modes are realized without severe oscillations of voltage or current; 3) The power balance of the system under extreme condition (the islanding mode with full-charged battery) is guaranteed by the proposed control method for modular PV converters; 4) The overcharging and overdischarging faults of batteries are avoided by the developed control method for battery converter. In a word, the practical feasibility and the effectiveness of the proposed control strategies have been validated by the experiments.

This modular PV generation system with distributed control strategy can be applied in residential PV generation in rural area, building integrated PV generation, and also the distributed control strategy can be applied for DC nanogrid and DC microgrids.

## REFERENCES

- [1] R. H. Lasseter, A. Akhil, C. Marnay, J. Stevens, J. Dagle, R. Guttromson, A. S. Meliopoulos, R. Yinger, and J. Eto. "White paper on integration of distributed energy resources, the certs microgrid concept." in Consortium for Electric Reliability Technology Solutions, Apr. 2002, pp. 1–27.
- [2] R. H. Lasseter, and P. Paigi. "Microgrid: a conceptual solution," in Proceedings of IEEE PESC'04, Vol.6, Jun. 2004, pp. 4285- 4290
- [3] Y. W. Li, and C. N. Kao. "An accurate power control strategy for power-electronics-interfaced distributed generation units operating in a low-voltage multibus microgrid." *IEEE Transactions on Power Electronics*, Vol. 24, Issue 12, Dec. 2009, pp. 2977-2988.
- [4] H. Kakigano, Y. Miura, T. Ise. "Configuration and control of a DC microgrid for residential houses." in IEEE Transmission & Distribution Conference & Exposition: Asia and Pacific, 2009, pp. 1-4.
- [5] H. Kakigano, Y. Miura, T. Ise, R. Uchida. "DC micro-grid for super high quality distribution-system configuration and control of distributed generations and energy storage devices." in Proceedings of IEEE PESC'06, 2006, pp. 1-7.
- [6] S. B. Kjaer, J. K. Pedersen, and F. Blaabjerg. "A review of single-phase grid-connected inverters for photovoltaic modules." *IEEE Transactions on Industry Applications*, Vol. 41, Issue 5, 2005, pp. 1292-1306.
- [7] Quan Li, P. Wolfs. "A review of the single phase photovoltaic module integrated converter topologies with three different DC link configurations." *IEEE Transactions on Power Electronics*, Vol. 23, Issue 3, 2008, pp. 1320-1333.
- [8] E. Ozdemir and F. Kavaslar. "A new multifunctional power converter for grid connected residential photovoltaic applications." in Proceedings of IEEE ECCE2009, 2009, pp. 2650-2656.
- [9] Lin Ma, Kai Sun, Remus Teodorescu, Josep M. Guerrero, Xinmin Jin. "An integrated multifunction DC/DC converter for PV generation systems" in Proceedings of IEEE ISIE2010, 2010.
- [10] Y. Gurkaynak and A. Khaligh. "Control and power management of a grid connected residential photovoltaic system with plug-in hybrid electric vehicle (PHEV) load." in Proceedings of IEEE APEC2009, 2009, pp.2086-2091.
- [11] G. M. Tina and F. Pappalardo. "Grid-connected photovoltaic system with battery storage system into market perspective." in Proceedings of IEEE PES/IAS Conference on Sustainable Alternative Energy (SAE), 2009, pp. 1-7.
- [12] T. Shimada, Y. Ueda and K. Kurokawa. "Look-ahead equalizing charge planning for grid-connected photovoltaic systems with battery storages." in Proceedings of IEEE PVSC'08, 2008, pp.1-3.
- [13] F. Giraud, Z. M. Salameh. "Steady-state performance of a grid-connected rooftop hybrid

- wind-photovoltaic power system with battery storage.” *IEEE Transactions on Energy Conversion*, Vol.16, Issue 1, 2001, pp.1-7.
- [14] R. Carbone. “Grid-connected photovoltaic systems with energy storage.” in Proceedings of ICCEP2009, 2009, pp. 760-767.
- [15] T. Kato, H. Yamawaki and Y. Suzuoki. “A study on dumping power flow fluctuation at grid-connection point of residential micro-grid with clustered photovoltaic power generation systems.” in Proceedings of IEEE PES/IAS Conference on Sustainable Alternative Energy (SAE), 2009, pp. 1-6.
- [16] H. Valderrama-Blavi, J. M. Bosque-Moncusí, L. Marroyo, F Guinjoan, J.A. Barrado and L. Martínez-Salamero. “Adapting a low voltage PEM fuel-cell to domestic grid-connected PV system.” in Proceedings of IEEE IECON’09, 2009, pp.160-165.
- [17] Zhenhua Jiang and R.A. Dougal. “Hierarchical microgrid paradigm for integration of distributed energy resources.” in IEEE Power and Energy Society General Meeting - Conversion and Delivery of Electrical Energy in the 21st Century, 2008, pp.1-8.
- [18] M.E. Glavin, P.K.W. Chan and W.G. Hurley. “Optimization of autonomous hybrid energy storage system for photovoltaic applications.” in Proceedings of IEEE ECCE2009, 2009, pp. 1417 - 1424.
- [19] Hiroaki Nakayama, Eiji Hiraki, Toshihiko Tanaka, Noriaki Koda, Nobuo Takahashi and Shuji Noda. “Stand-alone photovoltaic generation system with combined storage system using EDLC.” in Proceedings of IEEE IECON2009, 2009, pp. 883-888.
- [20] José Eduardo, M. S. Paiva Adriano and S. Carvalho. “An integrated hybrid power system based on renewable energy sources.” in Proceedings of IEEE IECON2009, 2009, pp. 4548-4554.
- [21] S. J. Chiang, Hsin-Jang Shieh and Ming-Chieh Chen. “Modeling and control of PV charger system with SEPIC converter.” *IEEE Transactions on Industrial Electronics*, Vol. 56, Issue 11, 2009, pp. 4344-4353.
- [22] D. D.-C. Lu, V.G. Agelidis. “Photovoltaic-battery-powered DC bus system for common portable electronic devices.” *IEEE Transactions on Power Electronics*, Vol.24, Issue 3, 2009, pp. 849-855
- [23] J. Bryan, R. Duke, and S. Round. “Decentralized generator scheduling in a nanogrid using DC bus signalling.” in IEEE Power Engineering Society Summer Meeting, Jun. 2004, pp. 977-982.
- [24] J. Schonberger, R. Duke, and S. D. Round. “DC bus signalling: a distributed control strategy for a hybrid renewable nanogrid.” *IEEE Transactions on Industrial Electronics*, Vol.53, Issue 5, 2006, pp.1453-1460.
- [25] Li Zhang, Kai Sun, Yan Xing, Lanlan Feng, and Hongjuan Ge. “A modular grid-connected photovoltaic generation system based on DC bus.” *IEEE Transactions on Power Electronics*, Vol.26, Issue 2, 2011, pp.523-531.