

An Overview of Grid-Forming Control for Wind Turbine Converters

Yu, Yun; Chaudhary, Sanjay K; Golestan, Saeed; Tinajero, Gibran David Agundis; Vasquez, Juan C.; Guerrero, Josep M.

Published in:

IECON 2021 – 47th Annual Conference of the IEEE Industrial Electronics Society

DOI (link to publication from Publisher):

[10.1109/IECON48115.2021.9589838](https://doi.org/10.1109/IECON48115.2021.9589838)

Publication date:

2021

Document Version

Accepted author manuscript, peer reviewed version

[Link to publication from Aalborg University](#)

Citation for published version (APA):

Yu, Y., Chaudhary, S. K., Golestan, S., Tinajero, G. D. A., Vasquez, J. C., & Guerrero, J. M. (2021). An Overview of Grid-Forming Control for Wind Turbine Converters. In IECON 2021 – 47th Annual Conference of the IEEE Industrial Electronics Society (pp. 1-6). Article 9589838 IEEE Communications Society. <https://doi.org/10.1109/IECON48115.2021.9589838>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

An Overview of Grid-Forming Control for Wind Turbine Converters

Yun Yu

AAU Energy
Aalborg University
Aalborg, Denmark
yyu@energy.aau.dk

Sanjay K Chaudhary

AAU Energy
Aalborg University
Aalborg, Denmark
skc@energy.aau.dk

Saeed Golestan

AAU Energy
Aalborg University
Aalborg, Denmark
sgd@energy.aau.dk

Gibran David Agundis Tinajero

AAU Energy
Aalborg University
Aalborg, Denmark
gdat@energy.aau.dk

Juan C. Vasquez

AAU Energy
Aalborg University
Aalborg, Denmark
juq@energy.aau.dk

Josep M. Guerrero

AAU Energy
Aalborg University
Aalborg, Denmark
joz@energy.aau.dk

Abstract—As the penetration level of renewable energy increases, the integration of large-scale wind power plants (WPPs) into the utility grid may pose a series of challenges in terms of voltage, frequency, and synchronization stability. One potential solution is applying grid forming (GFM) control to wind turbine converters (WTCs) to maintain voltage and frequency in power systems, emulating synchronous machine (SM) dynamics, provided that there are sufficient energy buffers. Over the past few years, several control algorithms have already been developed for the GFM operation of WTCs. This article investigates the state-of-the-art in the field of GFM control for WTCs, where the principle of each control algorithm is discussed in detail, and corresponding characteristics are summarized. Comparisons are given in tables, which leads to the conclusion and the suggestion for the future research.

Index Terms—Wind power plants (WPPs), wind turbine converters (WTCs), grid-forming (GFM) control.

I. INTRODUCTION

Nowadays, increasing efforts have been devoted into using sustainable energy sources for the electric power generation. Among all the renewable electricity generation technologies, wind power generation has already become a mainstream, and the integration of large-scale offshore wind power plants (OWPPs) is increasingly gaining more attention, especially in Europe. As shown in Fig. 1, at the end of 2030, new offshore wind installations in Europe are expected to reach almost 14.5 GW [1]. With a large-scale wind energy integrated into the grid, ensuring system stability is becoming a challenge.

One major problem that arises from a high penetration level of electronic-based wind generation is the reduction of overall system inertia, since there will be less synchronous machines (SMs) in the system to contribute to the inertia response. Thus, the rate of change of frequency (RoCoF) will increase in the case of transient events like a large load variation or

a loss of generation, which may in turn trigger cascading disconnections [2]. Apart from this, under grid disturbances, inadequate power management limits the fault-ride-through capability and then increases the risk of voltage collapse [3]. Regarding the transient stability, less margins are available when conventional SMs are replaced by electronic-based sources [3]. Facing those integration challenges, conventional grid-following (GFL) control methods applied to wind turbine converters (WTCs) can be insufficient to ensure a reliable integration of large-scale WPPs. Currently, a shifting from conventional GFL to GFM control has been taken as a potential solution to deal with aforementioned challenges, since GFM converters can be taken as controllable voltage sources with coupling impedance, which shares more similarities with conventional SMs [4]. Moreover, in the case that WPPs are disconnected from the main grid, GFM converters may work with energy storage systems to maintain WPP voltage and frequency, avoiding a complete collapse and being prepared for the reconnection. Another benefit of applying GFM control to WTCs is the possibility of being used for early stages of system restoration after the black out, with the condition that




Fig. 1 Global offshore wind growth to 2030 [1].




Fig. 4 The scheme of DPLLBC.

B. Fixed Reference Frame Control

In order to handle instability issues in operating weak WPP AC grids with conventional synchronization technologies, i.e., using the phase-locked loop (PLL), FRFC concept was initially proposed in [8] as an alternative solution which can be easily applied to both type-III and type-VI wind energy conversion systems [9]. By replacing commonly used distributed PLLs with the centralized reference system (e.g., GPS signals), the phase angle and the frequency for the control of each WTC can be accurately coordinated, and preservation of conventional WTC control blocks can be largely attained. As indicated in Fig. 3, reactive current sharing is achieved by the traditional droop controller, while traditional dc-link voltage and inner current control loops are preserved without additional modifications.

C. Distributed PLL-Based Control

Fig. 4 shows the overall scheme of the DPLLBC solution proposed in [11], where all the control loops are arranged in a conventional cascaded frame. This method uses conventional PI controllers as inner current regulators for a fast current response together with a easy implementation of current limitations during transient events. Each WTC is equipped with a LC filter, and the voltage on filter's terminal is measured and regulated for controlling WPP voltage. As indicated in Fig. 4, the active power transmitted by converters is adjusted by the conventional PI controller to follow the set points (e.g., obtained from maximum power point tracking curves), and the reactive-frequency droop controller is applied as well to share reactive currents among WTCs by modifying the individual frequency reference. Additionally, distributed frequency control loops which use frequency error to adjust q-axis voltage V_{fq} is embedded following the PLL synchronization principle, i.e., driving q-axis voltage V_{fq} to zero. It worth noting that the frequency regulator K_f in Fig. 4 differs from the contribution factor K_q of DVFC, even though they appears in similar control loops, the former is mainly designed to synchronize the voltage angle of each WTC by reducing q-axis voltage V_{fq} , and the latter is set according to WT capacities for an appropriate reactive current sharing.




Fig. 5 The scheme of VIC. (a) Overall control structure. (b) Inner voltage injection control loops.

D. Voltage Injection Control

Different from other GFM control solutions developed for WTCs, the VIC strategy was initially proposed in [10] to tackle transient overvoltage issues in the case of a sudden islanding operation. One distinct feature of VIC is that conventional inner PI current regulators are replaced by high-pass washout filters, as shown in Fig. 5(b). By doing this, adequate damping for transient processes can be carefully designed without integration functions, and the current regulator windup which results in the overvoltage can be avoided since voltage references are directly generated without integrating current errors. WTCs can be then controlled to behave more like voltage sources when WPPs are disconnected from the main grid. Moreover, reactive power controller with droop characteristics, conventional DC-link voltage regulator and over-frequency emergency control can be applied in outer loops respectively, as shown in Fig. 5(a), a detailed description can be found in [10], [26]

E. Two-Sequential-Loops-Based Control

In the aforementioned GFM control algorithms for WTCs, either synchronous (dq) frame voltages or currents of each WTC are independently regulated to control the grid voltage and adjust power flows among GFM WTCs. However, in the case of many parallel-connected GFM units, the risk of interaction-triggered oscillations may increase, especially when individual converter's terminal voltage responses to power-flow changes with different transients. Considering the risk of interactions among WTCs, voltage angle and amplitude at each converter's terminal have been selected as the variables to be controlled and coordinated in [13], and the classical power-angle control is applied with an additional frequency PI regulator to construct the outer control layers of TSLBC,

TABLE I: A general comparison of GFM control for WTCs

GFM control methods	Grid integration in the study	Initial voltage build-up	Synchronization method	Interaction mitigation	Inertia emulation	Controller complexity
DVFC	DR-HVDC	WTCs	Centralized calculation	No	No	Complex
FRFC	DR-HVDC	External grid	GPS signals	No	No	Simple
DPLLBC	DR-HVDC	WTCs	Distributed PLL	No	No	Simple
VIC	VSC-HVDC	Not addressed	Distributed PLL	No	No	Complex
TSLBC	DR-HVDC	Not addressed	Distributed PLL	Yes	No	Simple
VSG-Basd (for type-III)	LCC-HVDC HVAC	Not addressed	Switching equation	No	Yes	Simple
VSG-Basd (for type-VI)	HVAC	Not addressed	Switching equation	No	Yes	Simple




Fig. 6 The scheme of TSLBC.




Fig. 7 The scheme of VSG-based control for type-III WTCs.

as indicated in Fig. 6. Since terminal voltage magnitude is synchronously corrected by utilizing the same frequency deviation, more stable operations with less risk of oscillations can be anticipated. In the inner control loops, conventional vector current regulators are applied, and the references can be calculated based on the steady-state analysis in [13].

F. VSG-Based Control

1) *For Type-III WTCs:* A simplified diagram of VSG-based control for type-3 WTCs is indicated in Fig. 7 [22], [23]. When the concept of VSG is applied to type-III WTCs, the control of grid-side converter can remain the same, which means the normally used vector control can be still used for the grid-side converter. Regarding the control for generator-side converter, the swing equation will be applied to regulate both phase angle of terminal voltages and transmitted active power. By adjusting the inertia coefficient J_P and damping factor D_P , desired inertia responses and damping effect can be attained. The voltage amplitude reference is calculated through the feedback control of stator reactive power, where a voltage droop control is also included to generate the reactive power reference. Compared with the traditional GFL control for type-III WTCs, the VSG-based GFM control is able to provide improved stability, especially in the case of weak grids [18]–[20], [22], [23].

2) *For Type-VI WTCs:* In the case that the VSG control is applied to type-VI WTCs, generator-side converter is re-




Fig. 8 The scheme of VSG-based control for type-VI WTCs.

sponsible for regulating the DC-link voltage, and the grid-side converter actively controls the phase angle and amplitude of terminal voltages. As shown in Fig. 8, similar to the VSG-based control for type-III WTCs, swing equation is used for both phase angle and active power control, and reactive power feedback control together with voltage droop control are used for generating the voltage amplitude reference. Different for the type-III wind generation system, the generator is fully decoupled from the grid in type-VI system. Thus, for GFM control, LC filter is installed, and inner voltage control loops is applied to regulate terminal voltages.

III. COMPARISON OF GFM CONTROL FOR WTCs

A general comparison of aforementioned GFM control algorithms is presented in TABLE I, where the initial voltage build-up, the grid integration, the synchronization, the mitigation of interactions, the inertia emulation and the controller complexity are included. Regarding the initial voltage built up, DVFC and DPLLBC approaches are able to provide effective solutions which only use WTCs and the DC-link energy, while FRFC still needs the help of external grid or additional energy storage systems. Compared with centralized synchronization technologies used in DVFC and FRFC methods, the distributed PLL used in DPLLBC, VIC and TSLBC does not rely on communication links and is easy to be implemented. However, when the distributed PLL is applied, special attention need to be paid to the stability in the case of weak grids. On the other hand, VSG-based control is able provide improved stability in the case of weak grids and involves the emulation of inertia for frequency support, which is an advantage in interconnecting with the grid with a high renewable penetration level [27], [28]. Furthermore, the risk of interactions among parallel GFM WTCs has only been considered in TSLBC.

IV. POTENTIAL REQUIREMENTS FOR FUTURE GFM WTCs

With less conventional power plants in the system, large-scale WPPs play an important role in maintaining system stability and contributing to the system restoration. Considering the ongoing structural changes, potential requirements for future GFM WTCs can be listed as follows [29]:

- Build and maintain the AC voltage, where voltage amplitude and phase angle are actively controlled;
- Actively utilize reserves to support frequency and voltage in the case of transient events;
- Contribute to the overall inertia of power systems with a high penetration level of electronic-based generation;
- Actively mitigate oscillations and harmonic resonances;
- Enable islanding operations after a disconnection;
- Enable black start for early stages of system restoration.

V. CONCLUSION

This article reviews the research on GFM control applied to WTCs firstly, where comparisons have been conducted in terms of the initial voltage build-up, the grid integration, the synchronization, the mitigation of interactions, the inertia emulation and the controller complexity. Subsequently, for the improvement of existing GFM control for WTCs, potential requirements for future GFM WTCs are presented. Base on the review, the suggestion for the future work are summarized from authors' point of view as follows:

- 1) Interactions in the form of low-frequency oscillations or harmonic resonances are likely to be more complex when GFM WTCs are applied in the system. The risk of such interactions among GFM WTCs and other sources (e.g., GFL units and SMs) cloud be studied.
- 2) GFM WTCs will attempt to adjust the output active power automatically according to the instantaneous frequency deviation. The resulting power ripples can be

passed to turbine side when the DC-link capacitance is not large enough. Thus, the assessment of those power ripples on generators and wind turbines could be included in the future work.

- 3) In the case of a large frequency event, the frequency-support characteristics of GFM WTCs will slow down the wind turbine speed. The worst case would be that the event happens when the wind speed is low, and the wind turbine may be tripped because of the low rotation speed. To avoid the unnecessary tripping of wind turbines, the soft switching between GFM and GFL modes or the adaptive GFM control algorithm could be investigated in the future work.
- 4) To provide grid-support functions or even black-start services, the energy buffer provided by wind turbine itself may not be sufficient, considering the inherent variability of the wind speed. Thus, additional energy storage may be required, either distributed or aggregated storage systems. The coordination control of GFM WTCs and energy storage systems could be investigated in the future work.
- 5) In order to have a better understanding of GFM WTCs' contribution to the overall inertia, adequate inertia assessment approaches could be studied in the future work, where available wind power, energy buffers form the storage and applied WTCs control algorithms could be simultaneously included.

REFERENCES

- [1] GWEC. Global offshore wind report 2020. Aug. 2020. [Online]. Available: <https://gvec.net/global-offshore-wind-report-2020/>
- [2] F. Milano, F. Dörfler, G. Hug, D. J. Hill, and G. Verbič, "Foundations and challenges of low-inertia systems (invited paper)," in *Power Syst. Comput. Conf.*, 2018, pp. 1–25.
- [3] MIGRATE. Deliverable d1.1: Report on systemic issues. Dec. 2016. [Online]. Available: https://www.h2020-migrate.eu/_Resources/Persistent/9bf78fc978e534f6393afb1f8510db86e56a1177/MIGRATE_D1.1_final_TenneT.pdf
- [4] Y. Li, Y. Gu, Y. Zhu, A. Junyent-Ferré, X. Xiang, and T. C. Green, "Impedance circuit model of grid-forming inverter: Visualizing control algorithms as circuit elements," *IEEE Trans. Power Electron.*, vol. 36, no. 3, pp. 3377–3395, Mar. 2019.
- [5] R. Blasco-Gimenez, S. Añó-Villalba, J. Rodríguez-D'Herlée, F. Morant, and S. Bernal-Perez, "Distributed voltage and frequency control of offshore wind farms connected with a diode-based HVdc link," *IEEE Trans. Power Electron.*, vol. 25, no. 12, pp. 3095–3105, Dec. 2010.
- [6] S. Bernal-Perez, S. Añó-Villalba, R. Blasco-Gimenez, and J. Rodríguez-D'Herlée, "Efficiency and fault ride-through performance of a diode-rectifier- and VSC-inverter-based HVDC link for offshore wind farms," *IEEE Trans. Ind. Electron.*, vol. 60, no. 6, pp. 2401–2409, Jun. 2013.
- [7] R. Blasco-Gimenez, N. Aparicio, S. Añó-Villalba, and S. Bernal-Perez, "LCC-HVDC connection of offshore wind farms with reduced filter banks," *IEEE Trans. Ind. Electron.*, vol. 60, no. 6, pp. 2372–2380, Jun. 2013.
- [8] M. Gierschner, H. Knaak, and H. Eckel, "Fixed-reference-frame-control: A novel robust control concept for grid side inverters in HVDC connected weak offshore grids," in *Proc. 16th Eur. Conf. Power Electron. Appl. (EPE)*, Lappeenranta, Finland, Aug. 2014, pp. 1–7.
- [9] C. Prignitz, H. Eckel, S. Achenbach, F. Augsburg, and A. Schön, "FixReF: A control strategy for offshore wind farms with different wind turbine types and diode rectifier HVDC transmission," in *Proc. IEEE 7th Int. Symp. Power Electron. Distrib. Gener. Syst. (PEDG)*, Vancouver, BC, Canada, Jun. 2016, pp. 1–7.

- [10] I. Erlich, A. Korai, T. Neumann, M. Koochack Zadeh, S. Vogt, C. Buchhagen, C. Rauscher, A. Menze, and J. Jung, "New control of wind turbines ensuring stable and secure operation following islanding of wind farms," *IEEE Trans. Energy Convers.*, vol. 32, no. 3, pp. 1263–1271, Sept. 2017.
- [11] L. Yu, R. Li, and L. Xu, "Distributed PLL-based control of offshore wind turbines connected with diode-rectifier-based HVDC systems," *IEEE Trans. Power Del.*, vol. 33, no. 3, pp. 1328–1336, Jun. 2018.
- [12] O. Saborio-Romano, A. Bidadfar, J. N. Sakamuri, L. Zeni, . Göksu, and N. A. Cutululis, "Communication-less frequency support from offshore wind farms connected to HVdc via diode rectifiers," *IEEE Trans. Sustain. Energy*, vol. 12, no. 1, pp. 441–450, Jan. 2021.
- [13] A. Bidadfar, O. Saborio-Romano, N. A. Cutululis, and P. E. Sorensen, "Control of offshore wind turbines connected to diode-rectifier-based HVdc systems," *IEEE Trans. Sustain. Energy*, vol. 12, no. 1, pp. 514–523, Jan. 2021.
- [14] J. Driesen and K. Visscher, "Virtual synchronous generators," in *Proc. IEEE Power Energy Soc. General Meeting-Convers. Del. Elect. Energy 21st Century*, Pittsburgh, PA, USA, Jul. 2008, pp. 1–3.
- [15] Q. Zhong and G. Weiss, "Synchronverters: Inverters that mimic synchronous generators," *IEEE Trans. Ind. Electron.*, vol. 58, no. 4, pp. 1259–1267, Apr. 2011.
- [16] T. Shintai, Y. Miura, and T. Ise, "Oscillation damping of a distributed generator using a virtual synchronous generator," *IEEE Trans. Power Del.*, vol. 29, no. 2, pp. 668–676, Apr. 2014.
- [17] Q. Zhong, Z. Ma, W. Ming, and G. C. Konstantopoulos, "Grid-friendly wind power systems based on the synchronverter technology," *Energy Conversion and Management*, vol. 89, pp. 719–726, 2015.
- [18] S. Wang, J. Hu, and X. Yuan, "Virtual synchronous control for grid-connected DFIG-based wind turbines," *IEEE J. Emerg. Sel. Topics Power Electron.*, vol. 3, no. 4, p. 932–944, Dec. 2015.
- [19] S. Wang, J. Hu, X. Yuan, and L. Sun, "On inertial dynamics of virtual-synchronous-controlled DFIG-based wind turbines," *IEEE Trans. Energy Convers.*, vol. 30, no. 4, p. 1691–1702, Dec. 2015.
- [20] L. Huang, H. Xin, L. Zhang, Z. Wang, K. Wu, and H. Wang, "Synchronization and frequency regulation of DFIG-based wind turbine generators with synchronized control," *IEEE Trans. Energy Convers.*, vol. 32, no. 3, p. 1251–1262, Sept. 2017.
- [21] J. Xi, H. Geng, S. Ma, Y. Chi, and G. Yang, "Inertial response characteristics analysis and optimisation of PMSG-based VSG-controlled WECS," *IET Renewable Power Generation*, vol. 12, no. 15, pp. 1741–1747, 2018.
- [22] Y. Jiao and H. Nian, "Grid-forming control for DFIG based wind farms to enhance the stability of LCC-HVDC," *IEEE Access*, vol. 8, pp. 156 752–156 762, Aug. 2020.
- [23] H. Nian and Y. Jiao, "Improved virtual synchronous generator control of DFIG to ride-through symmetrical voltage fault," *IEEE Trans. Energy Convers.*, vol. 35, no. 2, pp. 672–683, Nov. 2020.
- [24] W. Yan, L. Cheng, S. Yan, W. Gao, and D. W. Gao, "Enabling and evaluation of inertial control for PMSG-WTG using synchronverter with multiple virtual rotating masses in microgrid," *IEEE Trans. Sustainable Energy*, vol. 11, no. 2, pp. 1078–1088, Apr. 2020.
- [25] Y. Xu, H. Nian, B. Hu, and D. Sun, "Impedance modeling and stability analysis of VSG controlled Type-IV wind turbine system," *IEEE Trans. Energy Convers.*, vol. 0, no. 0, p. 0, Feb. 2021.
- [26] I. Erlich, F. Shewarega, and W. Winter, "A method for incorporating VSC-HVDC into the overall grid voltage-reactive power control task," in *Proc. 19th Power Syst. Comput. Conf.*, Genoa, Italy, Jun. 2016.
- [27] J. Fang, H. Li, Y. Tang, and F. Blaabjerg, "Distributed power system virtual inertia implemented by grid-connected power converters," *IEEE Trans. Power Electron.*, vol. 33, no. 10, pp. 8488–8499, Oct. 2018.
- [28] J. Fang, P. Lin, H. Li, Y. Yang, and Y. Tang, "An improved virtual inertia control for three-phase voltage source converters connected to a weak grid," *IEEE Trans. Power Electron.*, vol. 34, no. 9, pp. 8660–8670, Sept. 2019.
- [29] P. Christensen and M. Seidel and S. Engelken and et al. High penetration of power electronic interfaced power sources and the potential contribution of grid forming converters. [Online]. Available: https://eepublicdownloads.entsoe.eu/clean-documents/Publications/SOC/High_Penetration_of_Power_Electronic_Interfaced_Power_Sources_and_the_Potential_Contribution_of_Grid_Forming_Converters.pdf