

Economic Predictive Control with Periodic Horizon for Water Distribution Networks

Ürkmez, Mirhan; Kallesøe, Carsten; Bendtsen, Jan Dimon; Leth, John-Josef

Published in:
IFAC-PapersOnLine

DOI (link to publication from Publisher):
[10.1016/j.ifacol.2023.10.982](https://doi.org/10.1016/j.ifacol.2023.10.982)

Creative Commons License
CC BY-NC-ND 4.0

Publication date:
2023

Document Version
Publisher's PDF, also known as Version of record

[Link to publication from Aalborg University](#)

Citation for published version (APA):
Ürkmez, M., Kallesøe, C., Bendtsen, J. D., & Leth, J.-J. (2023). Economic Predictive Control with Periodic Horizon for Water Distribution Networks. *IFAC-PapersOnLine*, 56(2), 4669-4674.
<https://doi.org/10.1016/j.ifacol.2023.10.982>

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
- You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Economic Predictive Control with Periodic Horizon for Water Distribution Networks

Mirhan Ürkmez* Carsten Kallesøe* Jan Dimon Bendtsen*
John Leth*

* Aalborg University, Fredrik Bajers Vej 7c, DK-9220 Aalborg,
Denmark

(e-mail: {mu, csk, dimon, jjl}@es.aau.dk)

Abstract: This paper deals with control of pumps in large-scale water distribution networks with the aim of minimizing economic costs while satisfying operational constraints. Finding a control algorithm in combination with a model that can be applied in real-time is a challenging problem due to the nonlinearities presented by the pipes and the network sizes. We propose a predictive control algorithm with a periodic horizon. The method provides a way for the economic operation of large water networks with a low-complexity linear model. Economic Predictive control with a periodic horizon and a terminal state constraint is constructed to keep the state trajectories close to an optimal periodic trajectory. Barrier terms are also included in the cost function to prevent constraint violations. The proposed method is tested on a state-of-the-art EPANET model of the water network of a medium size Danish town (Randers) and shown to perform as intended under varying conditions.

Copyright © 2023 The Authors. This is an open access article under the CC BY-NC-ND license (<https://creativecommons.org/licenses/by-nc-nd/4.0/>)

Keywords: Water distribution networks, Pump Scheduling, Predictive control, Periodic horizon, Economic model predictive control

1. INTRODUCTION

Water distribution networks (WDNs) deliver drinkable water from water sources to consumers using elements such as pumps, pipes, tanks etc. About 7% – 8% of the world's energy is used for water production and distribution (Sharif et al., 2019). Water pumps account for a significant part of the energy required for water distribution with their percentage ranging from 90% to 95% of the total (Abdelsalam and Gabbar, 2021). There have been many works to schedule the operation of the pumps in WDNs with proper methods so as to reduce energy costs. However, pump scheduling is not an easy task because of the nonlinearities governing the network elements. The problem gets complicated with increasing network size. Also, there are constraints to be satisfied such as limits on tank levels.

In the literature, WDNs with both constant and variable speed pumps are studied extensively. The control input is turning on and off the pump for constant speed pumps. In Lindell Ormsbee (2009), a constant-speed pump scheduling problem is posed as an optimization problem in which the decision variables are the operation times of the pumps and the objective is the energy cost. After observing that the optimal solution would be not running the pumps at all without the constraints, the authors try to find the solution closest to the origin that also complies with the constraints. The proposed way to find such a solution is

using a Genetic Algorithm (GA). In Bagirov et al. (2013), the Hooke-Jeeves method is used for finding optimal pump operating times for a similar problem. Then, network simulation algorithms are used to check if the constraints are satisfied. In Castro-Gama et al. (2017), binary decision variables are used to represent the opening and the closing of each pump. The feasibility of the solution found with GA is checked with EPANET, a WDN modeling software, and a high cost is assigned to the infeasible solutions. The number of open pumps is also taken as the input to the system in some works, e.g., Wang et al. (2021). The problem is then solved using mixed-integer nonlinear programming. In Berkel et al. (2018), a network in which pressure zones are connected via constant speed pumps is considered. Each pressure zone is treated as a subsystem and distributed model predictive control (DMPC) is applied.

The flow rate of the pumps should be determined for networks with variable speed pumps. In Pour et al. (2019), Linear Parameter Varying (LPV) system modeling is used to replace the nonlinear part of the network, and an Economic Model Predictive Control (EMPC) is applied on top of the LPV system to find the optimal flow rates. In Kallesøe et al. (2017), a network structure with an elevated reservoir is considered. Available data is used for the identification of a reduced system model. Then, EMPC is applied to the model. In the EMPC formulation, node pressures are not constrained. It is assumed that the pressures would be in the accepted range because there is an elevated reservoir. Relaxation of the original problem into a simpler one is commonly used because of the large network sizes. The relaxation is generally achieved by

* This work is funded by Independent Research Fund Denmark (DFF). We acknowledge Verdo company, Peter Nordahn, and Steffen Schmidt for providing us with the EPANET model and the network information.

approximating the nonlinear pipe equations with some sort of linear equations or inequalities. In Baunsgaard et al. (2016), pipe equations are linearized around an operating point, and model predictive control (MPC) is applied. In Wang et al. (2018), an EMPC is applied to a network where the nonlinear pipe equations are relaxed into a set of linear inequalities. Before simplifying the system model, the network structure is also simplified in Fiedler et al. (2020). A hierarchical clustering method is used to represent the original network with a smaller one which originally had 378 junctions. A system model is derived from the simplified structure using a Deep Neural Network (DNN) structure. Lagrangian relaxation is used to approximate the original problem in Ghaddar et al. (2015).

In this paper, a way for optimal pump scheduling of large-scale WDNs is presented. To control the pumps, a linear model of the system is derived. Then, a predictive control method is constructed that employs a periodic horizon, in contrast to classical MPC approaches that typically use a receding horizon. Barrier functions are utilized to prevent constraint violation due to the model-plant mismatch. With the introduction of the periodic horizon and the terminal state constraint, the chance of finding a feasible solution is increased by keeping trajectories close to an optimal periodic trajectory. The method is applied to a medium-sized Danish town's network (Randers).

The outline of the rest of the paper is as follows. The network model is given in Section 2. The proposed control method is explained in Section 3. The experimental results are presented in Section 4. The paper is concluded with final remarks in Section 5.

2. NETWORK MODEL

A typical water distribution network consists of pipes, pumps, tanks, junction nodes and reservoirs. Water in the network flows from high hydraulic head to low head. Hydraulic head is a measure of the fluid pressure and is equal to the height of a fluid in a static column at a point.

Hydraulic head loss occurring in a pipe can be approximated by the Hazen-Williams Equation as

$$\Delta h = h_1 - h_2 = Kq|q|^{0.852} \quad (1)$$

where K is the pipe resistance that depends on the physical features of a pipe such as diameter and length, q is the flow rate, and h_1 and h_2 are the heads at the two ends of the pipe.

At each node j , the mass conservation law is satisfied. It can be expressed as

$$\sum_{i \in \mathcal{N}_j} q_{ij} = d_j \quad (2)$$

where q_{ij} is the flow entering the node j from node i and d_j is the demand at node j , which is the water requested by the user at node j . The symbol \mathcal{N}_j denotes the set of neighbor nodes of node j . Note that q_{ij} is positive if the flow is from node i to the neighbor node j and negative vice versa.

Tanks are storage elements that provide water to the users. In the network, tanks are elevated so that water can be

pressurized enough to be delivered to the consumers. The change in the water level of a tank is dependent on the flow coming from neighbor nodes and can be written for the tank j as

$$A_j \dot{h}_j = \sum_{i \in \mathcal{N}_j} q_{ij} \quad (3)$$

where A_j is the cross-sectional area, h_j is the level of the tank. Tank levels change according to the flow passing through the pipes connected to the tanks. Those flows are determined by a set of pipe head loss equations (1), and mass balance equations (2) throughout the whole network. As Equation (1) is nonlinear, flow through pipes connected to the tanks are nonlinear functions f_i of the demand at each node, tank levels, and the amount of water coming from the pumps. Explicit forms of those nonlinear functions could be derived if the vector $d = [d_1, d_2, \dots]^T$ containing the demands of all the nodes is known, which is not possible unless demand data for all nodes are available. In our work, we assume that the total demand of the zones that are supplied by the pumps can be estimated through available data with time series analysis methods, but not require d vector to be known. Since f_i functions can not be found without d vector, we approximate them using linear models and write tank level change equations as

$$\dot{h}(t) = Ah(t) + B_1 u(t) + B_2 d_a(t) \quad (4)$$

where $h(t) \in \mathbb{R}^n$ includes tank levels, $A \in \mathbb{R}^{n \times n}$, $B_1 \in \mathbb{R}^{n \times m}$, $B_2 \in \mathbb{R}^{n \times 1}$ are constant system matrices and $d_a(t)$ is the aggregated demand of controlled zone at time t , $u(t) \in \mathbb{R}^m$ is the input containing pump flows. The reason we chose a linear model is to increase the chance of finding a feasible solution for the controller which is posed as an optimization problem in the next section. Although capturing the full dynamics of a large-scale network is not possible with a linear model, the proposed control method is designed to compensate for model inaccuracies and we have observed that it was enough to control the system while satisfying the constraints.

3. PERIODIC HORIZON CONTROL

In this section, a predictive control algorithm for pump scheduling is presented to minimize the economical costs. The aim is to run the pumps when the electricity price is low and let tanks deliver water when the price is high while also satisfying input and output constraints. The problem at time t is posed as

$$\min_{u_0^t, u_1^t, \dots, u_{N(t)-1}^t} \sum_{j=0}^{N(t)-1} J(h_j^t, u_j^t) \quad (5a)$$

$$h_j^t = A_d h_{j-1}^t + B_{d1} u_{j-1}^t + B_{d2} d_a(j-1) \quad (5b)$$

$$h_0^t = h(t) \quad (5c)$$

$$u_j^t \in \mathcal{U} \subseteq \mathbb{R}^m \quad (5d)$$

$$h_j^t \in \mathcal{H} \subseteq \mathbb{R}^n \quad (5e)$$

$$h_{N(t)}^t \in \mathcal{H}_{tf} \subseteq \mathbb{R}^n \quad (5f)$$

where $J(h_j^t, u_j^t)$ is the economic cost function, $h^t = [h_1^t \dots h_{N(t)}^t] \in \mathbb{R}^{n \times N(t)}$ is the predicted future states, u_j^t is the input vector, $N(t)$ is the prediction horizon, $\mathcal{U} \subseteq \mathbb{R}^m$ and $\mathcal{H} \subseteq \mathbb{R}^n$ denotes the input and state constraints respectively and $\mathcal{H}_{tf} \subseteq \mathbb{R}^n$ is the terminal state set. The

continuous system (4) is discretized and (5b) is obtained. The optimization problem (5) is solved at every time step separated by Δ_t and the first term u_0^t of the optimal input sequence $\mathbf{u}^t = [u_0^t \cdots u_{N(t)-1}^t] \in \mathbb{R}^{m \times N(t)}$ is applied to the system.

Input constraints come from the physical limitations and working principles of the pumps. A pump cannot provide water in the opposite direction, and it can deliver a maximum amount of water per unit of time. These conditions are expressed as

$$\mathcal{U} = \{[u_1, \dots, u_m] \in \mathbb{R}^m \mid 0 \leq u_1 \leq \bar{u}_1, \dots, 0 \leq u_m \leq \bar{u}_m\} \quad (6)$$

where $\bar{u}_1 \cdots \bar{u}_m$ are upper flow limits. Tank levels are also constrained so that there is always enough water in the tanks in case of an emergency and there is no overflow of water. The set \mathcal{H} can be defined as

$$\mathcal{H} = \{[h_1, \dots, h_n] \in \mathbb{R}^n \mid \tilde{h}_1 \leq h_1 \leq \bar{h}_1, \dots, \tilde{h}_n \leq h_n \leq \bar{h}_n\} \quad (7)$$

The cost function includes the electricity costs of the pumps. The power provided to the network by the pump i is equal to $q_{pi}(p_i^{out} - p_i^{in})$, where q_{pi} is the pump flow, p_i^{out} and p_i^{in} are the outlet and inlet pressures of the pump i . The inlet pressures $p^{in} = [p_1^{in}, p_2^{in}]$ are the pressures of the related reservoirs and are assumed to be constant. The outlet pressures $p^{out} = [p_1^{out}, p_2^{out}]$ are given as the output of the linear model

$$p^{out}(t) = A_p h(t) + B_p u(t) \quad (8)$$

where A_p and B_p are found using system identification on data generated by the EPANET model. Electricity cost at time t is then found by multiplying total power consumption $u(t)^T(p^{out}(t) - p^{in}(t))$ with the electricity price $c(t)$.

We acknowledge a certain degree of model-plant mismatch by using a linear model (4) to represent the whole network. This causes actual states $h(t)$ to be different than the predicted states h^t . We know that the predicted states satisfy the state constraints (7) since they are the solution to the optimization problem (5), but due to the model-plant mismatch the actual states might violate them when the predicted states are close to the state constraint boundaries. To ensure the satisfaction of the state constraints, we introduce new terms to the cost function. First, we rewrite state constraints (7) as

$$C_i(h) \leq 0, \quad i = 0, 1, \dots, 2 \times n - 1 \quad (9)$$

where $C_0(h) = \tilde{h}_1 - h_1$ and the rest of the C_i functions are chosen in a similar manner. The cost function terms are then defined as

$$J_{hi}(h) = e^{a_i(C_i(h) + b_i)} \quad i = 0, 1, \dots, 2 \times n - 1 \quad (10)$$

where $a_i, b_i \in \mathbb{R}_{>0}$ are positive real numbers. This can be seen as an exponential barrier function. The parameters a_i, b_i determine a dangerous region close to the boundaries of the state constraints where cost function J_{hi} attains high values. The predicted optimal state trajectories h^t do not enter the dangerous region if possible because of the high cost in the dangerous region. Then, the actual states $h(t)$ do not violate the state constraints (7) as the predicted states stay away from the constraint boundaries. If the state trajectory enters one of the dangerous regions at any step due to the model-plant mismatch, then the




Fig. 1. Predicted state trajectories $h^t, h^{t+\Delta_t}$ at times $t, t + \Delta_t$. Sampling time Δ_t , prediction horizons $N(t), N(t + \Delta_t)$ and the applied inputs $u_0^t, u_0^{t+\Delta_t}$ are shown. The true state $h(t + \Delta_t)$ and the predicted state h_1^t are indicated to emphasize the deviation from the prediction. The terminal set $\mathcal{B}_r(h_{T_{day}/\Delta_t}^*)$ is also illustrated.

cost function will try to drive the trajectory out of the region.

The overall cost function includes both the electricity expense term and the constraint barrier functions and it can be expressed as

$$J(h, u) = c(t)u^T(p^{out} - p^{in}) + \sum_{i=0}^{2 \times n - 1} J_{hi}(h) \quad (11)$$

Both electricity price $c(t)$ and total water demand $d_a(t)$ signals can be viewed as consisting of a periodic signal with a period of 1 day and a relatively small deviation signal. This can be leveraged to find a feasible controller. Suppose a sequence of inputs can be found for some initial tank levels such that levels after 1 day are equal to initial levels. In that case, the problem after 1 day is the same as in the beginning assuming deviation signals of the electricity price and the demand are zero, hence they are periodic. Then, the input sequence from the previous day could be applied and produce the same path for tank levels. Taking into account the deviation signals and supposing that a solution exists such that levels after 1 day are close to initial levels, the input sequence from the previous day could be a good point of start to search for a feasible solution if the map from the initial conditions and the demand profile to the optimal input sequences is continuous. Therefore, we choose a terminal state constraint for the end of each day to increase the chance of finding a feasible solution. Now, the remaining problem is to decide which tank levels should the trajectories turn back to at the end of each day. We define the optimal periodic trajectory of the system as the solution of

$$(\mathbf{u}^*, \mathbf{h}^*) = \arg \min_{u_i, h_i} \sum_{i=0}^{(T_{day}/\Delta_t)-1} J(h_i, u_i) \quad (12a)$$

$$h_i = A_d h_{i-1} + B_{d1} u_{i-1} + B_{d2} d_a^*(i-1) \quad (12b)$$

$$u_i \in \mathcal{U} \subseteq \mathbb{R}^m \quad (12c)$$

$$h_i \in \mathcal{H} \subseteq \mathbb{R}^n \quad (12d)$$

$$h_0 = h_{T_{day}/\Delta_t} \quad (12e)$$

where T_{day} is the duration of a whole day, d_a^* is the average daily demand profile obtained from the past measurements. The resulting state trajectory $\mathbf{h}^* = [h_0^* \cdots h_{T_{day}/\Delta_t}^*] \in \mathbb{R}^{n \times (T_{day}/\Delta_t + 1)}$ is the optimal periodic trajectory because of the constraint (12e). The terminal




Fig. 2. Water Distribution Network of Randers. The pumping stations to be controlled are shown in red. Tanks are shown with a 'T' shaped symbol in yellow.

set \mathcal{H}_{tf} and the prediction horizon $N(t)$ is chosen to make tank levels at the end of each day close to h_{T_{day}/Δ_t}^* . At any time t , $t + N(t)\Delta_t$ should be equal to the end of the day. \mathcal{H}_{tf} and $N(t)$ could be written as

$$\mathcal{H}_{tf} = \mathcal{B}_r(h_{T_{day}/\Delta_t}^*) \quad (13a)$$

$$N(t) = (T_{day} - t \bmod T_{day})/\Delta_t \quad (13b)$$

where $\mathcal{B}_r(h_{T_{day}/\Delta_t}^*)$ is the open ball centered at h_{T_{day}/Δ_t}^* with radius r . Note that $N(t)$ changes so that $t + N(t)\Delta_t$ is the end of the day for all t . With these definitions, the condition (13a) will translate to tank levels at the end of the day being close to the final point in optimal periodic trajectory h_{T_{day}/Δ_t}^* as shown in Figure 1. As a result, imposing a terminal state constraint at the end of each day not only increases the likelihood of finding a feasible solution but also ensures that the state trajectories remain close to the optimal periodic trajectory \mathbf{h}^* , provided that the deviation of the total demand is sufficiently small. If the problem (5) becomes infeasible at any time step t , we apply the second term of the input sequence from the previous step $u_1^{t-\Delta_t}$. The reason behind this choice is as follows: If we apply the optimal control input $u_0^{t-\Delta_t}$ to the network model (4) at time $t - \Delta_t$, then the optimal sequence in the next time step will be $\mathbf{u}^t = [u_1^{t-\Delta_t} \dots u_{N(t-\Delta_t)-1}^{t-\Delta_t}]$ following Bellman's principle of optimality. Then, at time t , $u_1^{t-\Delta_t}$ will be applied to the system as calculated at $t - \Delta_t$. Assuming the model-plant mismatch is small enough, $u_1^{t-\Delta_t}$ is still a good input candidate if the problem is infeasible at time t .

4. APPLICATION

The presented method is applied to EPANET implementation of the WDN of Randers, a Danish city, which is shown in Figure 2. The network consists of 4549 nodes and 4905 links connecting them. There are 8 pumping stations in the network, 6 of which are shown in the figure whereas the other 2 are stationed where tanks are placed. The goal is to derive the schedules for 2 of the pumping stations while other pumps are already working according to some predetermined strategies. The stations to be controlled are shown in red in the figure. Their task is to deliver water mostly to regions known as the High Zone (HZ) and Low Zone (LZ), which are characterized by high and low elevations, respectively. However, connections exist between HZ-LZ and the rest of the city, so we can not think




Fig. 3. Structure of the WDN.

of the system as composed of isolated networks entirely. There are also 3 tanks in the HZ. While 2 of them are directly connected via pipes, the third one stands alone as shown in the figure.

The overall structure of the Randers WDN with tanks and pumps to be controlled are given in Figure 3. There are 3 water tanks in the network, 2 of which have been connected with a pipe directly. The tank level changes can be written by applying the mass conservation law (3) to the tanks in Figure 3 as

$$A_1 \dot{h}_1 = q_{1down} + q_{1up} + q_{inter} \quad (14a)$$

$$= f_1(h_1, h_2, h_3, q_{p1}, q_{p2}, d),$$

$$A_2 \dot{h}_2 = q_{2down} + q_{2up} - q_{inter} \quad (14b)$$

$$= f_2(h_1, h_2, h_3, q_{p1}, q_{p2}, d),$$

$$A_3 \dot{h}_3 = q_3 = f_3(h_1, h_2, h_3, q_{p1}, q_{p2}, d), \quad (14c)$$

where d is the vector containing the demands of all the nodes, q_{p1}, q_{p2} are the pump flows, A_1, A_2, A_3 are the cross sectional areas of the tanks and f_1, f_2, f_3 are nonlinear flow functions. Water levels at the two connected tanks are almost equal $h_1 \approx h_2$ all the time since the pipe connecting respective tanks is big enough to oppose the water flows coming from neighbor nodes. That enables us to consider h_1, h_2 together as

$$(A_1 + A_2) \dot{h}_{1,2} \approx q_{1down} + q_{2down} + q_{up} = f_1 + f_2. \quad (15)$$

We have used the EPANET model of the network to generate the data required for approximating $f_1 + f_2$ and f_3 . The model is simulated with various tank level initial conditions and flow rates of 2 pumping stations to be controlled. The control laws for the remaining pumping stations are already defined in the EPANET model. Then, the linear model (4) is fitted to simulation data using least squares. The state variables for the model are $h(t) = [h_{1,2}(t), h_3(t)] \in \mathbb{R}^2$ and the inputs are $u(t) = [q_{p1}(t), q_{p2}(t)] \in \mathbb{R}^2$. The total demand of High and Low Zone is used as aggregated demand d_a in the model since mainly those areas are supplied by the controlled pumps.

4.1 Simulation Results

The proposed control method is tested on EPANET model of Randers water network. Epanet-Matlab toolkit Eliades et al. (2016) is used to set the flow of the 2 pumps at each time step and simulate the network. The remaining pumps are controlled with rule-based control laws that are previously defined on EPANET.

The parameters of exponential barrier functions J_{hi} are chosen as $a_i = 80$, $b_i = 0.3$ for all i . It is assumed that the electricity prices are known in advance during the test.

Tank levels h_1, h_2 have a maximum value of 3m while h_3 has 2.8m. Tanks are required to be at least half full. Maximum pump flows are set to 100. Sampling time Δ_t is set to 1 hour in the experiments since the electricity prices remain constant during that period, so the control input is recalculated at each hour. We assume that total demand $d_a(t)$ of HZ and LZ can be estimated up to 1 day from available data. Although we do not have historical data on the demand, we imitate this behaviour by using a slightly perturbed version of the real demand used in EPANET simulation during MPC calculations. The perturbations are adapted from a real demand data set of a small Danish facility. Normalized difference between the average demand and the demand of a random day in data set is added to EPANET demand to replicate estimated demand. In each experiment a different day from the data set is used, so the assumed estimated demand is different each time.

The simulation results when the presented method is applied to the EPANET model are given in Figure 4. The initial tank levels are equal to h_{T_{day}/Δ_t}^* in the simulation. The top plot shows the evolution of tank levels along with the upper and lower thresholds. It is seen that the thresholds are not violated and moreover tank levels are not getting too close to them, which was the idea behind exponential barrier functions. Both the real demand and the assumed estimated demand of HZ and LZ are in the figure below. Total applied pump flows and electricity prices are in the following figures. The expected result is pump flows being higher when electricity prices are low, and lower when they are high, which seems to be the case as can be seen in the plot. Pump flows drop significantly when prices are at the peak and they reach their highest value at the end of the day when prices are low. A more aggressive controller can be obtained by picking a smaller b_i value for barrier functions at the expense of risking constraint violation. In Figure 5, the tank level simulation results and control inputs for different initial conditions and different assumed estimated demands are given. The electricity price profile is the same as before. It is seen that the algorithm is able to control the network on various cases while satisfying the constraints. Regardless of initial tank levels, the pumping profiles have a similar profile: high pump flows close to midnight and in the middle of the day. The only exception is the bottom plot. In the beginning, prices are low but pump flows are not high. This can be attributed to water levels h_1, h_2 being close to the upper thresholds and water demand being low in the beginning.

The assumption that the optimal input sequences $U(t)$ would not diverge a lot from the one found in previous step $U(t - \Delta_t)$ is the reason we apply $u_1^{t-\Delta_t}$ at time t if the problem (5) is infeasible at time t . This assumption is tested with initial conditions $h_{1,2,3} = h_{T_{day}/\Delta_t}^*$. In figure 6, total pump flow $[1, 1]^T u_i^t, i = 0 \dots N(t) - 1$ of the found optimal input sequences $U(t), t = 0, \Delta_t \dots T_{day} - \Delta_t$, except when the problem were infeasible, are given. It can be seen that $u_1^{t-\Delta_t}$ is close to the u_0^t for all t , which shows that our assumption is valid at least for this experiment.

Finally, the ability of the algorithm to decrease economic costs is tested with various initial conditions. For each




Fig. 4. Sample simulation. (a) evolution of tank levels through 1 day with upper and lower level thresholds; (b) real total demand of HZ and LZ used in EPANET simulation and the demand used in MPC calculations; (c) total flow provided by the 2 pumps; (d) electricity price.




Fig. 5. Tank levels and pump flows for different initial conditions.




Fig. 6. Evolution of found input sequences $U(t)$ through 1 day. It can be seen that the solutions remain close to the initial optimal sequence $U(0)$.

Proposed Method	Demand Follower
0.5967	1
0.5745	1
0.5826	1
0.5558	1

Table 1. Relative economic costs of the proposed method and demand follower strategy for various demand profiles

case, a demand follower pumping strategy is used as a benchmark. The flow of the 2 pumps is adjusted with trial and error for each demand follower such that the total flow of the 2 pumps is equal to water demand at each time step and tank levels satisfy the terminal constraint (13a). The demand follower is a natural candidate to be a benchmark method since providing as much water as demand is an intuitive idea and the constraints in (5) can be satisfied with manual adjustments of pump flows. The economic costs are presented relatively in Table 1. As it is seen, the proposed algorithm saves between 40% and 45% of the cost with different demand profiles.

5. CONCLUSION

We have presented a predictive control algorithm with a periodic horizon for WDNs. The aim is to minimize the economic cost and satisfy the operational constraints. A linear model is used to represent Randers WDN to increase the chance of finding a solution to the problem (5) at expense of a model-plant mismatch. Periodic horizon is introduced to the predictive control formulation to keep the resulting state trajectories around the optimal periodic trajectory. Barrier functions are used to prevent constraint violation since there is a model-plant mismatch.

The presented algorithm is tested on Randers WDN using EPANET. It is shown in various situations that the method is able to find an economic solution where pump flows are adjusted according to electricity prices. Also, it is shown that the system trajectories do not enter dangerous zones introduced by barrier functions as long as the predicted demand and the actual demand are somewhat close.

As future work, we plan to work on theoretical guarantees of the existence of solutions to the proposed method. Also,

the robustness of periodic horizon control of periodical systems with barrier functions will be investigated.

REFERENCES

- Abdelsalam, A.A. and Gabbar, H.A. (2021). Energy saving and management of water pumping networks. *Heliyon*, 7(8), e07820. doi:<https://doi.org/10.1016/j.heliyon.2021.e07820>.
- Bagirov, A.M., Barton, A., Mala-Jetmarova, H., Nuaimat, A.A., Ahmed, S.T., Sultanova, N., and Yearwood, J. (2013). An algorithm for minimization of pumping costs in water distribution systems using a novel approach to pump scheduling. *Math. Comput. Model.*, 57, 873–886.
- Baunsgaard, K.M.H., Ravn, O., Kallesøe, C.S., and Poulsen, N.K. (2016). Mpc control of water supply networks. *2016 European Control Conference (ECC)*, 1770–1775.
- Berkel, F., Caba, S., Bleich, J., and Liu, S. (2018). A modeling and distributed mpc approach for water distribution networks. *Control Engineering Practice*.
- Castro-Gama, M.E., Pan, Q., Lanfranchi, E.A., Jonoski, A., and Solomatine, D.P. (2017). Pump scheduling for a large water distribution network. milan, italy. *Procedia Engineering*, 186, 436–443.
- Eliades, D.G., Kyriakou, M., Vrachimis, S., and Polycarpou, M.M. (2016). Epanet-matlab toolkit: An open-source software for interfacing epanet with matlab. In *Proc. 14th International Conference on Computing and Control for the Water Industry (CCWI)*, 8. The Netherlands. doi:10.5281/zenodo.831493.
- Fiedler, F., Cominola, A., and Lucia, S. (2020). Economic nonlinear predictive control of water distribution networks based on surrogate modeling and automatic clustering. *IFAC-PapersOnLine*, 53, 16636–16643.
- Ghaddar, B., Naoum-Sawaya, J., Kishimoto, A., Taheri, N., and Eck, B. (2015). A lagrangian decomposition approach for the pump scheduling problem in water networks. *Eur. J. Oper. Res.*, 241, 490–501.
- Kallesøe, C.S., Jensen, T.N., and Bendtsen, J.D. (2017). Plug-and-play model predictive control for water supply networks with storage. *IFAC-PapersOnLine*, 50, 6582–6587.
- Lindell Ormsbee, Srini Lingireddy, D.C. (2009). Optimal pump scheduling for water distribution systems. URL [http://www.uky.edu/WDST/PDFs/\[73.3\]%20Ormsbee%20Optimal%20Pump%20Scheduling%20Paper.pdf](http://www.uky.edu/WDST/PDFs/[73.3]%20Ormsbee%20Optimal%20Pump%20Scheduling%20Paper.pdf).
- Pour, F.K., Puig, V., and Cembrano, G. (2019). Economic mpc-lpv control for the operational management of water distribution networks. *IFAC-PapersOnLine*.
- Sharif, N., Haider, H., Farahat, A., Hewage, K., and Sadiq, R. (2019). Water energy nexus for water distribution systems: A literature review. *Environmental Reviews*, 27. doi:10.1139/er-2018-0106.
- Wang, Y., Alamo, T., Puig, V., and Cembrano, G. (2018). Economic model predictive control with nonlinear constraint relaxation for the operational management of water distribution networks. *Energies*, 11, 991.
- Wang, Y., Yok, K.T., Wu, W., Simpson, A.R., Weyer, E., and Manzie, C. (2021). Minimizing pumping energy cost in real-time operations of water distribution systems using economic model predictive control. *ArXiv*, abs/2010.07477.