Aalborg Universitet



Renewable Microgrids for Resilience Enhancement of Different Loads with Diverse Usage Patterns under Natural Disaster

Ali, Majid: Vasquez, Juan C.: Guerrero, Josep M.: Bazmohammadi, Naimeh: Guan, Yajuan: Ali, Mazhar

Creative Commons License CC BY 4.0

Publication date: 2024

Document Version Publisher's PDF, also known as Version of record

Link to publication from Aalborg University

Citation for published version (APA):

Ali, M., Vasquez, J. C., Guerrero, J. M., Bazmohammadi, N., Guan, Y., & Ali, M. (2024). Renewable Microgrids for Resilience Enhancement of Different Loads with Diverse Usage Patterns under Natural Disaster. 175. Poster presented at 2024 IEEE Power & Energy Society General Meeting Seattle, Washington, USA, Seattle, Washington, Washington, United States.

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain
 You may freely distribute the URL identifying the publication in the public portal -

Take down policy If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.



PROJECT DESCRIPTION AND OBJECTIVES

This study explores, develops, and assesses viable microgrid solutions for isolated islands, using Indonesia as an example. Initially, we assessed the probability of a photovoltaic (PV) and battery system surviving random outages of varying lengths. Subsequently, we utilized Homer Grid software to simulate multiple configurations, including PV, wind, battery storage, and generators and analyzed both economic and resilience outcomes. Our findings indicate that the resilience of a hospital, due to its daytime peaking load which aligns well with PV generation, is 35% higher than that of a hotel. Diverse usage patterns-wise, PV+WT MG showed only a 5% improvement in resilience compared to PV+BES MG.
 TABLE I: DIFFERENT SCENARIO FOR ISLAND MICROGRID

S. #	Key Scenario	Description						
1	DG	An independent diesel generator might be the solution.						
2	DG+BES	Might be improved economically by including a battery.						
3	PV+BES	Battery capacity in conjunction with a relatively big PV capacity is required.						PV a
4	DG+BES+PV	Adding a diesel generator, reduced the number of batteries and solar panels.						BES
5	WT+BES	A huge battery and relatively large capacity of wind turbines are required.						Gene
6	DG+BES+WT	A diesel generator generates the required electricity when there is no wind or battery charge.						Wind
• •	METHODOLOGYThe Homer Grid offered the best technology, system size, and smallest net present cost (NPC) possible.The project life of 25 years is considered. The 10% increase in electricity cost and operation and maintenance cost per year is considered for $SP = \sum_{t=1}^{N} sp(surviving an outage of t hours).(1 h) (1)$ $SP = \sum_{t=1}^{N} sp(surviving an outage of t hours).(1 h) (2)$							
•	An 8% discount rate and 2.8% inflation rate is used by Homer Pro for simulation. TABLE III: SURVIVING PROBABILITY OF AN OUTAGE %							
•	Value of Lost Load (VoLL) \$100/kWh. For this calculation, we used a renewable-only MG consisting of a 75% PV array, a 12 h battery, and the critical load (50% of the total load) assuming the battery state of charge (SoC) is 100% and 3-day (72 h) outage			Load	Prob = 90 % (h) Prob =	= 50 % (h) Prob	= 10 % (h)	(2
•				Hospital Medical Clinic	22 21	127 85	2223 285	
				Hotel Hospital Medical Clinic	16 16 16	45 65 61	135 251 189	
The surviving probability of an Outage for a renewable only Microgrid: where N is the length of the outage under consideration. For our case study N = 72 h,			B	Hotel Hospital	14 19	35 55	99 216	
				Medical Clinic Hotel	18 16	57 39	235 79	







DIVERSE USAGE PATTERNS UNDER NATURAL DISASTER

Majid Ali, Juan C. Vasquez, Josep M. Guerrero, Yajuan Guan, Najmeh Bazmohammadi, Mazhar Ali Center for Research on Microgrids (CROM), AAU Energy, Aalborg University, 9220 Aalborg, Denmark Department of Electrical and Computer Engineering, University of Central Florida, Central Florida, United States

https://www.crom.et.aau.dk/phd-industrial-projects/activities/tech-in/

21-25 July 2024 Seattle, Washington

RENEWABLE MICROGRIDS FOR RESILIENCE ENHANCEMENT OF DIFFERENT LOADS WITH



Fig. 1. System architecture

RESULTS

The resilience analysis of renewable microgrids hows:

- Resilience varies with load patterns and local resources, e.g., a hospital in Location A can sustain a 127-hour outage with 75% PV and 12-hour BES, while a hotel in Location C can only manage 39 hours.
- (2) Survival probability is 35% higher for hospitals than hotels for 72-hour outages, and 5% higher in Location B than C.
- Hotels have lower resilience, with less than a 25% chance of surviving a 72-hour outage, compared to over 45% for hospitals and offices.
- A 50% PV, 50% wind, and 6-hour BES system can sustain 3-day outages effectively.

Supported by the Ministry of Foreign Affairs of Denmark (MFA) – DANIDA Fellowship Centre - under grant # 20-M06-AAU.

Danish

International

Development

Agency



Fig.2. MG architecture



Contact us at maal@energy.aau.dk