



**AALBORG UNIVERSITY**  
DENMARK

**Aalborg Universitet**

## **Optimal Design of Modern Transformerless PV Inverter Topologies**

Saridakis, Stefanos ; Koutroulis, Eftichios ; Blaabjerg, Frede

*Published in:*  
I E E E Transactions on Energy Conversion

*DOI (link to publication from Publisher):*  
[10.1109/TEC.2013.2252013](https://doi.org/10.1109/TEC.2013.2252013)

*Publication date:*  
2013

*Document Version*  
Early version, also known as pre-print

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*  
Saridakis, S., Koutroulis, E., & Blaabjerg, F. (2013). Optimal Design of Modern Transformerless PV Inverter Topologies. *I E E E Transactions on Energy Conversion*, 28(2), 394-404 .  
<https://doi.org/10.1109/TEC.2013.2252013>

### **General rights**

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- ? Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- ? You may not further distribute the material or use it for any profit-making activity or commercial gain
- ? You may freely distribute the URL identifying the publication in the public portal ?

### **Take down policy**

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# Optimal Design of Modern Transformerless PV Inverter Topologies

Stefanos Saridakis, Eftichios Koutroulis, *Member, IEEE*, and Frede Blaabjerg, *Fellow, IEEE*

**Abstract**—The design optimization of H5, H6, Neutral Point Clamped, Active-Neutral Point Clamped and Conergy-NPC transformerless Photovoltaic inverters is presented in this paper. The components reliability in terms of the corresponding malfunctions, affecting the Photovoltaic inverter maintenance cost during the operational lifetime period of the Photovoltaic installation, is also considered in the optimization process. According to the results of the proposed design method, different optimal values of the Photovoltaic inverter design variables are derived for each Photovoltaic inverter topology and installation site. The H5, H6, Neutral Point Clamped, Active-Neutral Point Clamped and Conergy-NPC Photovoltaic inverters designed using the proposed optimization process feature lower Levelized Cost Of generated Electricity and lifetime cost, longer Mean Time Between Failures and inject more Photovoltaic-generated energy into the electric grid than their non-optimized counterparts, thus maximizing the total economic benefit obtained during the operational time of the Photovoltaic system.

**Index Terms**—Photovoltaic system, Optimization, DC/AC inverter, Transformerless, Reliability.

## I. INTRODUCTION

The modern grid-connected PV energy production systems widely employ transformerless PhotoVoltaic (PV) DC/AC converters (inverters), since compared to the inverters using galvanic isolation they exhibit the advantages of lower cost, higher power density and higher efficiency [1-3]. The block diagram of a grid-connected transformerless PV inverter is illustrated in Fig. 1. The PV array consists of PV modules connected in series and/or parallel [4, 5]. Typically, the power switches (e.g. IGBTs, SiC-based JFETs etc.) of the power section of the PV inverter are controlled by a DSP- or FPGA-based microelectronic control unit according to Pulse Width Modulation (PWM) techniques (e.g. Sinusoidal PWM, Space-vector PWM, hysteresis band control etc.) [6-8]. A sinusoidal current with low harmonic content is injected into the electric grid by filtering the high-frequency harmonics of the PWM waveform produced at the output of the PV inverter power section. The use of LCL-type output filters, instead of the L- or LC-type filters, aims to increase the power density of the PV inverter [9].

Many alternative topologies have been proposed during the




Fig. 1. A block diagram of a transformerless PV inverter.

last few years in order to build the power section of single- and three-phase transformerless PV inverters in grid-connected PV installations [10-19]. Among them, the H5, H6 and Conergy-Neutral Point Clamped (Conergy-NPC) topologies have been integrated in commercially available grid-connected PV inverters. Also, the Neutral Point Clamped (NPC) and Active-Neutral Point Clamped (ANPC) transformerless structures are widely used to build the power stage of PV inverters used in Distributed Generation systems, due to their low-leakage-current and high-efficiency features [20]. The H5, H6, NPC, ANPC and Conergy-NPC topologies are illustrated in Fig. 2. Compared to the H5 and H6 transformerless PV inverters, a higher DC input voltage is required for the operation of the NPC, ANPC and Conergy-NPC inverters.

In order to maximize the amount of energy injected into the electric grid and the total economic benefit achieved by a grid-connected PV installation during its operational lifetime period it is indispensable to maximize the reliability of the individual components and devices comprising the PV system [21-22]. The reliability features are expressed in terms of indices such as the failure rate or the Mean Time Between Failures (MTBF) [23]. The design and production of PV power processing systems with high efficiency, high reliability and low cost features has been indicated in [24] as a major challenge. The PV inverters are typically designed according to iterative trial-and-error methods, which target to maximize the power conversion efficiency at nominal operating conditions or the “European Efficiency” of the PV inverter [19, 25-27]. The design optimization of transformerless PV inverters employing full-bridge, NPC or ANPC topologies, has been analyzed in [20, 28], without, however, considering the reliability characteristics of the PV inverter. Also, various methods have been presented for the exploration and improvement of the PV inverters reliability performance, which are reviewed in [22]. However, these methods have the disadvantage that the concurrent impact of

S. Saridakis and E. Koutroulis are with the Department of Electronic and Computer Engineering, Technical University of Crete, Chania, GR-73100, Greece (e-mail: ssaridakis@isc.tuc.gr, efkout@electronics.tuc.gr).

F. Blaabjerg is with the Department of Energy Technology, Aalborg University, Aalborg, DK-9220, Denmark (e-mail: fbl@et.aau.dk).




Fig. 2. Topologies of the power section in transformerless single-phase PV inverters: (a) H5-inverter, (b) H6-inverter, (c) NPC, (d) ANPC and (e) Conergy-NPC.

different critical design parameters, such as the PV inverter topology, component values, operational characteristics (e.g. maximum switching frequency) and reliability performance, on the trade-off between the PV inverter manufacturing cost, maintenance cost and total power losses, which affect the amount of energy injected into the electric grid by the PV inverter, is not considered during the PV inverter design process.

In this paper, the design technique including reliability, which was suited to full-bridge PV inverters in [22], is advanced in terms of the power-section topology, thus resulting in a new methodology for the optimal design of transformerless PV inverters based on the H5, H6, NPC, ANPC and Conergy-NPC structures. Using the proposed design process, the optimal values of components comprising the H5, H6, NPC, ANPC and Conergy-NPC PV inverters are calculated such that the PV inverter Levelized Cost Of generated Electricity (LCOE) is minimized. The components reliability in terms of the corresponding malfunctions, which affect the PV inverter maintenance cost during the PV system operational lifetime period, as well as the limitations imposed by the electrical grid interconnection regulations and international standards, are also considered in the LCOE calculation. In contrast to the past-proposed approaches applied to design H5, H6, NPC, ANPC and Conergy-NPC PV

inverters, the optimal design process presented in this paper has the advantage of taking into account the concurrent influences of the meteorological conditions prevailing at the installation site, the PV inverter topology, as well as the cost, operational characteristics and reliability features of the components comprising the PV inverter, on both the PV inverter lifetime cost and total energy injected into the electric grid. The proposed design tool accommodates a systematic design flow based on conventional models and circuit-analysis techniques, which enables to calculate the optimal structure of H5, H6, NPC, ANPC and Conergy-NPC PV inverters among computationally complex alternatives, with minimum effort from the designer of the PV inverter.

This paper is organized as follows: the methodology for optimal design of transformerless PV inverters considering reliability is outlined in § II; the modeling for optimization of H5, H6, NPC, ANPC and Conergy-NPC transformerless PV inverter topologies is analyzed in § III and the design optimization results are presented in § IV. Finally, the topologies are compared in terms of their performance in various installation sites and conclusions are drawn.

## II. OPTIMAL DESIGN METHODOLOGY INCLUDING RELIABILITY

The proposed design optimization method calculates, for each of the H5, H6, NPC, ANPC and Conergy-NPC transformerless PV inverters, the optimal values of the switching frequency,  $f_s$  (Hz), and the values of the components comprising the output filter, i.e.  $L$ ,  $L_g$ ,  $C_f$  and  $R_{dr}$  in Fig. 1, such that the PV-inverter Levelized Cost Of the generated Electricity [29],  $LCOE$  (€/Wh), is minimized, while simultaneously the PV inverter specifications and the constraints imposed by the grid codes and international standards are satisfied like:

$$\begin{aligned} & \underset{\mathbf{X}}{\text{minimize}} \{LCOE(\mathbf{X})\} \\ & \text{subject to: } \text{design specifications \& } \\ & \text{constraints are met} \end{aligned} \quad (1)$$

where:

$$LCOE(\mathbf{X}) = \frac{C_{inv}(\mathbf{X})}{E_i(\mathbf{X})} \quad (2)$$

and  $C_{inv}(\mathbf{X})$  (€) is the present value of the PV inverter total cost during its operational lifetime period,  $E_i(\mathbf{X})$  (Wh) is the total energy injected into the electric grid by the PV inverter




Fig. 3. A flowchart of the proposed optimization process.

during its operational lifetime period and  $\mathbf{X} = [f_s | L | L_g | C_f]$  is the vector of the design variables.

The value of the LCL-filter damping resistor,  $R_{dr}$ , is calculated using the values of  $\mathbf{X}$ , as analyzed in [30]. The optimal value of the decision variables vector,  $\mathbf{X}$ , is calculated using Genetic Algorithms (GAs), since they are capable to solve complex optimization problems with computational efficiency. A flow-chart of the proposed design procedure, which is executed for each PV inverter topology, is illustrated in Fig. 3. Initially, the PV inverter designer provides as inputs the specifications of the PV inverter (e.g. nominal power, output voltage etc.), the technical and economical characteristics of the components comprising the PV inverter, the operational characteristics of the PV array connected to the DC input of the PV inverter and the 1-hour average values of the solar irradiation and ambient temperature conditions during the year at the PV inverter installation site. During the optimization process, multiple design vectors,  $\mathbf{X}$ , composing the population of the GA process chromosomes, are progressively modified for a predefined number of generations. The LCOE objective function in (2) is calculated for each chromosome. The design vector  $\mathbf{X}$  providing the lowest value of LCOE is comprised of the optimal values of the PV inverter design parameters.

In (1), the LCOE minimization is performed subject to the following constraints: (i) the ripple of the PV inverter output current is less than the maximum permissible limit, which is defined in the grid-interconnection regulations and/or standards (e.g. the IEEE-1547 standard), (ii) the resonance-frequency, capacitance and total inductance of the LCL-filter are constrained within the limits described in [30] and (iii) the value of the switching frequency,  $f_s$ , is limited by the maximum possible operating switching speed of the power switches and diodes composing the power section of the PV inverter,  $f_{s,max}$  (Hz), specified by their manufacturer, such that  $f_s \leq f_{s,max}$ .

The present value of the PV inverter total cost,  $C_{inv}(\mathbf{X})$  in (2), is calculated as the sum of the PV inverter manufacturing cost,  $C_t(\mathbf{X})$  (€) and the present value of the total cost for maintaining the PV inverter during its operational lifetime period,  $M_t(\mathbf{X})$  (€):

$$C_{inv}(\mathbf{X}) = C_t(\mathbf{X}) + M_t(\mathbf{X}) \quad (3)$$

The manufacturing cost,  $C_t$ , is equal to the sum of the costs of the individual components comprising the H5, H6, NPC, ANPC and Conergy-NPC PV inverters:

$$C_t(\mathbf{X}) = c_{inv} P_n + c_{hs} + n_s c_s + n_d c_d + n_{cd} c_{cd} + c_i (L + L_g) \frac{P_n}{V_n} + c_c C_f + c_r R_{dr} \cdot SF \cdot P_{d,max} \quad (4)$$

where  $c_{inv}$  (€/W) is the manufacturing cost of the PV inverter without including the cost of the heat sink, power switches,

diodes and LCL-filter components (e.g. control unit, printed circuit boards, integration and housing etc.),  $c_{hs}$  (€) is the cost of the heat-sink,  $n_s$ ,  $n_d$ ,  $n_{cd}$  are the number of power switches, anti-parallel diodes and clamping diodes, respectively, contained in the PV inverter power section (for the H5, ANPC and Conergy-NPC topologies it holds that  $n_{cd} = 0$ ),  $c_s$ ,  $c_d$ ,  $c_{cd}$  (€) are the cost of each power switch, anti-parallel diode and clamping diode, respectively,  $c_i$  [€/ (H · A)] is the LCL-filter inductor cost per unit inductance and current,  $c_c$  (€/F) is the LCL-filter capacitor cost per unit capacitance,  $c_r$  [€/ (Ω · W)] is the LCL-filter damping resistor cost per unit resistance and power,  $SF$  (%) is the over-sizing factor of the damping resistor  $R_{dr}$  (see Fig. 1) and  $P_{d,max}$  (W) is the maximum power dissipated on the damping resistor during operation.

The type and values of the individual components comprising the PV inverter determine the reliability performance of the PV inverter during its operational lifetime period, which, in turn, defines the present value of the PV inverter total maintenance cost,  $M_t(\mathbf{X})$  in (3). In the proposed methodology, the value of  $M_t$  is calculated by reducing the PV inverter repair expenses occurring during each future year of operation, to the corresponding present value, as follows:

$$M_t(\mathbf{X}) = \sum_{j=1}^n N_j(\mathbf{X}) \cdot M_{inv} \cdot \frac{(1+g)^j}{(1+d)^j} \quad (5)$$

where  $n$  is the number of years of PV system operational lifetime period,  $N_j(\mathbf{X})$  is the average number of PV inverter failures which are expected to occur during the  $j$ -th year of operation ( $1 \leq j \leq n$ ),  $M_{inv}$  (€) is the present value of the PV inverter repair cost,  $g$  (%) is the annual inflation rate and  $d$  (%) is the annual discount rate.

The values of  $N_j(\mathbf{X})$  in (5) are determined by the failure rate of the PV inverter, which in turn depends on the values of the individual components comprising the PV inverter and the stress factor applied to them (e.g. DC input voltage, ambient temperature etc.) [31], as analyzed next. The total failure rate of the PV inverter,  $\lambda_{inv}(\mathbf{X})$  (number of failures/10<sup>6</sup> hours) is a function of the design variables values,  $\mathbf{X}$ , and it is calculated using the following equation:

$$\lambda_{inv}(\mathbf{X}) = \frac{1}{MTBF} = \lambda_{Cin}(C_{in}, \overline{V_{pv}}, \overline{T_A}) + \sum_{i=1}^{n_s} \lambda_{ps,i}(\overline{T_{jps,i}}) + \sum_{i=1}^{n_d} \lambda_{di}(\overline{T_{jdi}}) + \sum_{i=1}^{n_{cd}} \lambda_{cd,i}(\overline{T_{jcd,i}}) + \lambda_L(\overline{T_L}) + \lambda_{Lg}(\overline{T_{Lg}}) + \lambda_{Cf}(C_f, \overline{V_{Cf}}, \overline{T_A}) + \lambda_{Rdr}(\overline{P_{Rdr}}, \overline{T_{Rdr}}) + \lambda_c \quad (6)$$

where  $MTBF$  (h) is the Mean Time Between Failures of the

PV inverter,  $\lambda_{ps,i}$ ,  $\lambda_{d,i}$ ,  $\lambda_{cd,i}$ ,  $\lambda_L$ ,  $\lambda_{Lg}$ ,  $\lambda_{Cf}$  and  $\lambda_{Rdr}$  (number of failures/10<sup>6</sup> hours) are the failure rates of the PV inverter power switches, free-wheeling diodes, clamping diodes, LCL-type output filter inductors ( $L$  and  $L_g$ ), capacitor ( $C_f$ ) and damping resistor ( $R_{dr}$ ), respectively,  $\lambda_{Cin}$  is the total failure rate of the DC-link capacitor(s),  $\lambda_c$  is the total failure rate of the remaining components and subsystems comprising the PV inverter (e.g. digital circuits of the control unit, monitoring sensors etc.),  $\overline{T_A}$  is the weighted-average value of ambient temperature,  $\overline{T_{jps,i}}$ ,  $\overline{T_{jd,i}}$ ,  $\overline{T_{jcd,i}}$  are the weighted-average values of the junction temperature of the power switches, free-wheeling diodes and clamping diodes, respectively and  $\overline{V_{pv}}$ ,  $\overline{V_{Cf}}$ ,  $\overline{P_{Rdr}}$ ,  $\overline{T_L}$ ,  $\overline{T_{Lg}}$  and  $\overline{T_{Rdr}}$  are the weighted-average values of the PV inverter DC input voltage (i.e. PV array output voltage), LCL-filter capacitor voltage, damping resistor power consumption and operating temperature levels of the LCL-filter components (i.e.  $L$ ,  $L_g$  and  $R_{dr}$ ), respectively.

The values of  $\lambda_{ps,i}$ ,  $\lambda_{d,i}$ ,  $\lambda_{cd,i}$ ,  $\lambda_L$ ,  $\lambda_{Lg}$ ,  $\lambda_{Cf}$ ,  $\lambda_{Rdr}$  and  $\lambda_{Cin}$  in (6) are calculated using the mathematical model of the PV inverter, the electrical specifications of the components used to build the PV inverter and the 1-hour average solar irradiance and ambient temperature time-series during the year, according to the failure-rate models described in [31, 32]. The value of  $\lambda_{inv}(\mathbf{X})$  in (6) is calculated for each set of design variables values (i.e. vector  $\mathbf{X}$ ), which are produced during the evolution of the GA-based optimization process. The total failure rate,  $\lambda_{inv}(\mathbf{X})$ , determines the probability that the PV inverter will not operate properly, according to the exponential distribution [32]. Thus, the total number of failures that the PV inverter encounters during each year of operation is statistically variable. In the proposed methodology, in order to calculate the present value of the PV inverter total maintenance cost in (2) and (5), the average number of failures during each year of operation,  $N_j(\mathbf{X})$  in (5), is calculated using the resulting value of  $\lambda_{inv}(\mathbf{X})$  and executing a Monte Carlo simulation with 10000 samples.

The total energy production of the PV inverter,  $E_i$  in (2), is calculated using the time-series of the PV inverter power production during the PV system operational lifetime period, as follows:

$$E_i(\mathbf{X}) = \sum_{y=1}^n \sum_{t=1}^{8760} P_o(t,y) \cdot \Delta t \quad (7)$$

where  $P_o(t,y)$  is the power injected into the electric grid by the PV inverter at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) and  $\Delta t = 1$  hour is the simulation time-step.

The values of  $P_o(t,y)$  in (7) are calculated according to the

transformerless PV inverter modeling analyzed next.

### III. MODELING OF TRANSFORMERLESS PV INVERTER TOPOLOGIES FOR OPTIMIZATION

With reference to the block diagram of transformerless PV inverters, which is illustrated in Fig. 1, the power injected into the electric grid by the PV inverter is calculated in the proposed methodology from a power-balance equation as follows:

$$P_o(t,y) = P_{pv}(t,y) - P_{tot}(t,y) \quad (8)$$

where  $P_{pv}$  and  $P_{tot}$  (W) are the PV array output power and the PV inverter total power loss, respectively, at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ).

Typically, the control unit of the PV inverter executes a Maximum Power Point Tracking (MPPT) process, such that the maximum possible power is produced by the PV array [33, 34]. The deterioration of the PV modules output power capacity during the operational lifetime period of the PV inverter affects the values of the stress factors applied to the PV inverter components and the values of the resulting failure rates in (6). Considering these parameters, the PV array output power,  $P_{pv}$  (W) in (8), is calculated in the proposed methodology as follows:

$$P_{pv}(t,y) = [1 - y \times r(y)] \cdot n_{mppt} \cdot P_M(t) \quad (9)$$

where  $y$  is the number of year of PV system operation ( $1 \leq y \leq n$ ),  $r(\cdot)$  (%/year) is the annual reduction coefficient of the PV modules output power [if  $y=1$  then  $r(y)=0$ , while for  $1 < y \leq n$  its value is specified by the manufacturer of the PV modules],  $n_{mppt}$  (%) is the MPPT efficiency, which expresses the accuracy of the MPPT process executed by the control unit of the PV inverter (typically  $n_{mppt} > 99.7\%$ ) [35] and  $P_M(t)$  (W) is the power production at the maximum power point of the PV array during hour  $t$  ( $1 \leq t \leq 8760$ ).

The value of  $P_M$  in (9) is calculated according to the PV modules model analyzed in [36], using the time-series of hourly values of solar irradiation and ambient temperature during the year, the electrical specifications of the PV modules and their configuration within the PV array (i.e. connection in series and parallel), that the designer of the PV inverter inputs in the proposed optimization procedure.

The total power loss of the PV inverter,  $P_{tot}$  in (8), is equal to the sum of the conduction and switching losses of the power semiconductors (i.e. power switches, free-wheeling diodes and clamping diodes) comprising the power section of the PV inverter,  $P_{cond}$  (W) and  $P_{sw}$  (W), respectively, the power loss on the LCL-filter damping resistor,  $P_d$  (W), the core and winding losses of the LCL-filter inductors,  $P_{L,c}$  (W) and  $P_{L,r}$  (W), respectively, and the power consumption of the




Fig. 4. Conducting devices in relation to the waveforms of  $V_{s,1}$  and  $I_o$  for the H5, H6, NPC, ANPC and Conergy-NPC inverters.

control unit (due to the circuits of the SPWM modulator, sensors etc.),  $P_{cu}$  (W):

$$P_{tot} = P_{cond} + P_{sw} + P_d + P_{L,c} + P_{L,r} + P_{cu} \quad (10)$$

The values of  $P_d$ ,  $P_{L,c}$  and  $P_{L,r}$  are calculated using the power loss models presented in [28], while the designer of the PV inverter provides the value of  $P_{cu}$ .

Initially, the PV inverter output current,  $I_o(t, y)$  (A), at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) is calculated by solving numerically the following power-balance equation:

$$P_{pv}(t, y) = P_{tot}(t, y) + V_n \cdot I_o(t, y) \quad (11)$$

where  $V_n$  (V) is the nominal RMS value of the PV inverter output voltage.

In the proposed methodology, the power switches and diodes, which constitute the power section of the PV inverter, are modeled as voltage sources connected in series with resistors. Thus, the conduction power losses of each power switch and diode (either clamping or free-wheeling),  $P_{cond}$  (W), are given by:

$$P_{cond}(t, y) = V_d \cdot I_{avg} + R_d \cdot I_{rms}^2 \quad (12)$$

where  $V_d$  (V),  $R_d$  ( $\Omega$ ) are the power switch or diode forward voltage and resistance, respectively and  $I_{avg}$ ,  $I_{rms}$  (A) are the average and RMS values, respectively, of the power switch or diode current.

The average and RMS values of the current of each power switch or diode are calculated as follows:

TABLE I  
CONDUCTION INTERVALS AND MODULATION FUNCTIONS OF THE H5 PV INVERTER

| Power semiconductor | Conduction interval    | Modulation function, $f(\omega t)$ |
|---------------------|------------------------|------------------------------------|
| $S_1, S_4$          | $[\theta, \pi]$        | $[1 + m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi, \pi + \theta]$  | $[1 - m_a \cdot \sin(\omega t)]/2$ |
| $D_2, D_3$          | $[\theta, \pi]$        | $[1 - m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi, \pi + \theta]$  | $[1 + m_a \cdot \sin(\omega t)]/2$ |
| $S_5$               | $[\theta, \pi]$        | $[1 + m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi + \theta, 2\pi]$ | $[1 - m_a \cdot \sin(\omega t)]/2$ |
| $D_5$               | $[0, \theta]$          | $[1 + m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi, \pi + \theta]$  | $[1 - m_a \cdot \sin(\omega t)]/2$ |

$$I_{avg} = \frac{1}{2\pi} \int_0^{2\pi} \sqrt{2} \cdot I_o(t, y) \cdot \sin(\omega t - \theta) \cdot f(\omega t) \cdot d\omega t \quad (13)$$

$$I_{rms} = \sqrt{\frac{1}{2\pi} \int_0^{2\pi} (\sqrt{2} \cdot I_o(t, y) \cdot \sin(\omega t - \theta))^2 \cdot f(\omega t) \cdot d\omega t} \quad (14)$$

where  $f(\omega t)$  is the modulation function [37] of the corresponding power semiconductor,  $I_o(t, y)$  (A) is the RMS output current of the PV inverter at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) and  $\theta$  ( $^\circ$ ) is the phase difference between the PV inverter output current (i.e.  $I_o$  in Figs. 1 and 4) and the fundamental (i.e.  $V_{s,1}$  in Fig. 4) of the SPWM voltage generated at the output terminals of the power section (i.e.  $V_{spwm}$  in Fig. 1).

The power semiconductors which conduct during each time interval of the output-current period of the H5, H6, NPC, ANPC and Conergy-NPC PV inverters, respectively, are also presented in Fig. 4. During the time intervals that a power semiconductor is not conducting, then the corresponding modulation function in (13) and (14) is set equal to zero [i.e.  $f(\omega t) = 0$ ]. In the proposed methodology, the values of  $P_{cond}$  and  $P_{sw}$  in (10) are calculated by applying equations (11)-(14), which have been presented above, for each of the H5, H6, NPC, ANPC and Conergy-NPC topologies, as analyzed in the following paragraphs.

#### A. H5 PV inverter

The modulation functions of the H5-inverter power semiconductors, during each conduction interval presented in Fig. 4, are summarized in Table I as a function of the modulation index,  $m_a$ , of the PV inverter SPWM output voltage (i.e.  $V_{spwm}$  in Fig. 1). Considering the symmetrical operation of the H5 inverter topology and applying the modulation functions displayed in Table I in (13) and (14), it is derived that:

$$\begin{aligned} I_{S_i, avg} = I_{S_j, avg} = I_{S, avg} \quad , \quad I_{S_i, rms} = I_{S_j, rms} = I_{S, rms} \\ I_{D_i, avg} = I_{D_j, avg} = I_{D, avg} \quad , \quad I_{D_i, rms} = I_{D_j, rms} = I_{D, rms} \end{aligned} \quad (15)$$

where  $i, j = 1 \dots 4$ .

Then, the total conduction loss,  $P_{cond}(t, y)$ , at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) of the H5-inverter is calculated as the sum of the conduction losses of the power switches and diodes comprising of the H5 inverter, using (12) and (15), as follows:

$$P_{cond}(t, y) = 4 \cdot (V_{s,on} I_{S,avg} + I_{S,rms}^2 R_{s,on}) + V_{s,on} I_{S5,avg} + I_{S5,rms}^2 R_{s,on} + 4 \cdot (V_d I_{D,avg} + I_{D,rms}^2 R_d) + V_d I_{D5,avg} + I_{D5,rms}^2 R_d \quad (16)$$

The total switching energy,  $E$  (Joule), of the semiconductor devices in the H5 power section which switch during the  $0 \leq \omega t \leq \pi$  time interval depicted in Fig. 4 is calculated as the sum of the energy consumed by the power semiconductors during the corresponding turn-on and turn-off switching actions:

$$E = \frac{V_{pv}(t, y) \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{V_t \cdot I_t \cdot 2\pi f} \cdot 2 \cdot (E_{onS1} + E_{onS4} + E_{onS5} + E_{offD1} + E_{offD4} + E_{offD5} + E_{onD1} + E_{onD4} + E_{onD5} + E_{offS1} + E_{offS4} + E_{offS5}) \quad (17)$$

where  $f_s$  (Hz) is the switching frequency,  $V_t$  (V),  $I_t$  (A) are the test voltage and current values, respectively and  $E_{onx_i}$ ,  $E_{offx_i}$  (Joule) are the turn-on and turn-off energy, respectively, of the power switch or free-wheeling diode  $x_i$ .

Since practically, power switches and diodes of the same operational characteristics are used to build the PV inverter, it holds that:

$$E_{onS_i} = E_{onS_j} = E_{onT} \quad , \quad E_{offS_i} = E_{offS_j} = E_{offT} \quad (18)$$

$$E_{onD_i} = E_{onD_j} = E_{onDT} \quad , \quad E_{offD_i} = E_{offD_j} = E_{offDT}$$

where  $i, j = 1 \dots 5$ ,  $E_{onT}$ ,  $E_{offT}$  (Joule) are the power switch turn-on and turn-off energy and  $E_{onDT}$ ,  $E_{offDT}$  (Joule) are the free-wheeling diode turn-on and turn-off energy.

Due to the symmetrical operation of the H5-inverter topology, the total switching loss during the negative half-cycle of the output voltage period (i.e. during  $[\pi - 2\pi]$ ) is equal to  $E$  in (17). Thus, the total switching losses of the H5-inverter,  $P_{sw}(t, y)$ , at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) are calculated using (17) and (18), as follows:

$$P_{sw}(t, y) = 2 \cdot f \cdot E = \frac{V_{pv}(t, y) \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{\pi \cdot V_t \cdot I_t} \cdot [6 \cdot (E_{onT} + E_{onDT}) + 6 \cdot (E_{offT} + E_{offDT})] \quad (19)$$

where  $f$  (Hz) is the frequency of the PV inverter output voltage.

### B. H6 PV inverter

Due the symmetrical operation of the H6-inverter [Fig. 2(b)] and applying the modulation functions displayed in Table II in (13) and (14), it results in that:

TABLE II  
CONDUCTION INTERVALS AND MODULATION FUNCTIONS  
OF THE H6 PV INVERTER

| Power semiconductor | Conduction interval    | Modulation function, $f(\omega t)$ |
|---------------------|------------------------|------------------------------------|
| $S_1, S_4$          | $[\theta, \pi]$        | $[1 + m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi, \pi + \theta]$  | $[1 - m_a \cdot \sin(\omega t)]/2$ |
| $D_2, D_3$          | $[\theta, \pi]$        | $[1 - m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi, \pi + \theta]$  | $[1 + m_a \cdot \sin(\omega t)]/2$ |
| $S_5, S_6$          | $[\theta, \pi]$        | $[1 + m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi + \theta, 2\pi]$ | $[1 - m_a \cdot \sin(\omega t)]/2$ |
| $D_5, D_6$          | $[0, \theta]$          | $[1 - m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi, \pi + \theta]$  | $[1 + m_a \cdot \sin(\omega t)]/2$ |
| $D+, D-$            | $[\theta, \pi]$        | $[1 + m_a \cdot \sin(\omega t)]/2$ |
|                     | $[\pi + \theta, 2\pi]$ | $[1 - m_a \cdot \sin(\omega t)]/2$ |

$$I_{S_i,avg} = I_{S_j,avg} = I_{S,avg} \quad , \quad I_{S_i,rms} = I_{S_j,rms} = I_{S,rms}$$

$$I_{D_i,avg} = I_{D_j,avg} = I_{D,avg} \quad , \quad I_{D_i,rms} = I_{D_j,rms} = I_{D,rms} \quad (20)$$

$$I_{S5,avg} = I_{S6,avg} \quad , \quad I_{S5,rms} = I_{S6,rms} \quad , \quad I_{D5,avg} = I_{D6,avg}$$

$$I_{D5,rms} = I_{D6,rms} \quad , \quad I_{D+,avg} = I_{D-,avg} \quad , \quad I_{D+,rms} = I_{D-,rms}$$

where  $i, j = 1 \dots 4$ .

The total conduction losses,  $P_{cond}(t, y)$ , at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) of the power semiconductors used to build the H6 inverter are calculated using (12) and (20):

$$P_{cond}(t, y) = 4 \cdot (V_{s,on} I_{S,avg} + I_{S,rms}^2 R_{s,on}) + 2 \cdot (V_{s,on} I_{S5,avg} + I_{S5,rms}^2 R_{s,on}) + 4 \cdot (V_d I_{D,avg} + I_{D,rms}^2 R_d) + 2 \cdot (V_d I_{D5,avg} + I_{D5,rms}^2 R_d) + 2 \cdot (V_d I_{D+,avg} + I_{D+,rms}^2 R_d) \quad (21)$$

Due to the symmetrical operation of the H6 inverter topology, the total switching losses for an H6 PV inverter,  $P_{sw}(t, y)$  in (10), are calculated by applying a similar procedure as that for the H5 topology described above, resulting in:

$$P_{sw}(t, y) = 2 \cdot f \cdot E = \frac{V_{pv}(t, y) \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{\pi \cdot V_t \cdot I_t} \cdot [8 \cdot (E_{onT} + E_{onDT}) + 8 \cdot (E_{offT} + E_{offDT}) + 4 \cdot (E_{onD} + E_{offD})] \quad (22)$$

where  $E_{onD}$ ,  $E_{offD}$  (Joule) are the clamping diode turn-on and turn-off energy, respectively.

### C. NPC and ANPC PV inverters

The values of  $P_{cond}$  and  $P_{sw}$  in (8) for the NPC and ANPC PV inverters [Fig. 2(c) and 2(d), respectively] are calculated using the power-loss models analyzed in detail in [20]:

- For the NPC PV inverter:

$$P_{cond}(t, y) = 2 \cdot (V_{s,on} I_{S1,avg} + I_{S1,rms}^2 R_{s,on} + V_{s,on} I_{S2,avg} + I_{S2,rms}^2 R_{s,on}) + 4 \cdot (V_d I_{D1,avg} + I_{D1,rms}^2 R_d) + 2 \cdot (V_d I_{D+,avg} + I_{D+,rms}^2 R_d) \quad (23)$$

$$P_{sw}(t, y) = \frac{V_{pv}(t, y) \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{2\pi \cdot V_t \cdot I_t} \cdot [4 \cdot (E_{onT} + E_{offT}) + 2 \cdot (E_{onD} + E_{offD}) + 2 \cdot (E_{onDT} + E_{offDT}) + 2 \cdot (E_{onT} + E_{offT} - E_{onDT} - E_{offDT}) \cdot \cos\theta] \quad (24)$$

• For the ANPC PV inverter:

$$P_{cond}(t, y) = 2 \cdot (V_{s,on} I_{S1,avg} + I_{S1,rms}^2 R_{s,on} + V_{s,on} I_{S2,avg} + I_{S2,rms}^2 R_{s,on} + V_{s,on} I_{S5,avg} + I_{S5,rms}^2 R_{s,on}) + 2 \cdot (V_d I_{D1,avg} + I_{D1,rms}^2 R_d + V_d I_{D2,avg} + I_{D2,rms}^2 R_d + V_d I_{D3,avg} + I_{D3,rms}^2 R_d) \quad (25)$$

$$P_{sw}(t, y) = \frac{V_{pv}(t, y) \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{2\pi \cdot V_t \cdot I_t} \cdot [6 \cdot (E_{onT} + E_{onDT}) + 12 \cdot (E_{offT} + E_{offDT}) + 2 \cdot (E_{onT} + 2 \cdot E_{offT} - E_{onDT} - 2 \cdot E_{offDT}) \cdot \cos\theta] \quad (26)$$

#### D. Conergy-NPC PV inverter

The modulation functions of the power semiconductors comprising a Conergy-NPC inverter [Fig. 2(e)] are summarized in Table III. They have been derived by applying the on-state ratios of power semiconductors in SPWM 3-level inverters, which have been calculated in [38], for each of the power semiconductors in the corresponding conduction intervals depicted in Fig. 4. Considering the symmetrical operation of the Conergy-NPC topology and applying the modulation functions displayed in Table III in (13) and (14), it results that:

$$\begin{aligned} I_{S1,avg} &= I_{S2,avg} = I_{S,avg} & , & \quad I_{S1,rms} = I_{S2,rms} = I_{S4,rms} \\ I_{D1,rms} &= I_{D2,rms} = I_{D,rms} & , & \quad I_{D1,avg} = I_{D2,avg} = I_{D,avg} \\ I_{S+,avg} &= I_{S-,avg} & , & \quad I_{S+,rms} = I_{S-,rms} \\ I_{D+,avg} &= I_{D-,avg} & , & \quad I_{D+,rms} = I_{D-,rms} \end{aligned} \quad (27)$$

The total conduction losses,  $P_{cond}(t, y)$ , at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) of the power semiconductors employed in the Conergy-NPC inverter are calculated using (12) and (27):

$$P_{cond}(t, y) = 2 \cdot (V_{s,on} I_{S,avg} + I_{S,rms}^2 R_{s,on}) + 2 \cdot (V_{s,on} I_{S+,avg} + I_{S+,rms}^2 R_{s,on}) + 2 \cdot (V_d I_{D,avg} + I_{D,rms}^2 R_d) + 2 \cdot (V_d I_{D+,avg} + I_{D+,rms}^2 R_d) \quad (28)$$

The total switching energy,  $E_1$  and  $E_2$  (Joule), respectively, of the power semiconductor devices, which switch during the  $0 \leq \omega t \leq \theta$  and  $\theta \leq \omega t \leq \pi$  time intervals depicted in Fig. 4, are calculated as the sum of the energy consumed during the corresponding turn-on and turn-off switching actions, as follows:

$$E_1 = \frac{V_{pv}(t, y)/2 \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{V_t \cdot I_t} \cdot (E_{onD1} + E_{offS-} + E_{offD-} + E_{onS-} + E_{onD-} + E_{offD1}) \cdot \frac{1}{2\pi} \cdot \int_0^\theta \sin \lambda d\lambda \quad (29)$$

TABLE III  
CONDUCTION INTERVALS AND MODULATION FUNCTIONS  
OF THE CONERGY-NPC PV INVERTER

| Power semiconductor | Conduction interval   | Modulation function, $f(\omega t)$ |
|---------------------|-----------------------|------------------------------------|
| $S_1$               | $[\theta, \pi]$       | $m_a \cdot \sin(\omega t)$         |
| $D_1$               | $[0, \theta]$         | $m_a \cdot \sin(\omega t)$         |
| $S+$                | $[\theta, \pi]$       | $1 - m_a \cdot \sin(\omega t)$     |
|                     | $[\pi, \pi + \theta]$ | $1 + m_a \cdot \sin(\omega t)$     |
| $D+$                | $[\theta, \pi]$       | $1 - m_a \cdot \sin(\omega t)$     |
|                     | $[\pi, \pi + \theta]$ | $1 + m_a \cdot \sin(\omega t)$     |

$$E_2 = \frac{V_{pv}(t, y)/2 \cdot I_o(t, y) \cdot \sqrt{2} \cdot f_s}{V_t \cdot I_t} \cdot \frac{f_s}{f} \cdot (E_{onS1} + E_{offS+} + E_{offD+} + E_{offS1} + E_{onS+} + E_{onD+}) \cdot \frac{1}{2\pi} \cdot \int_\theta^\pi \sin \lambda d\lambda \quad (30)$$

The total switching losses of the Conergy-NPC inverter,  $P_{sw}(t, y)$ , at hour  $t$  ( $1 \leq t \leq 8760$ ) of year  $y$  ( $1 \leq y \leq n$ ) are calculated using (29) and (30), while simultaneously considering the symmetrical operation of the Conergy-NPC inverter topology and that practically power switches and diodes of the same operational characteristics are used to build the PV inverter:

$$P_{sw}(t, y) = 2 \cdot f \cdot (E_1 + E_2) = \frac{V_{pv}(t, y) \cdot \sqrt{2} \cdot I_o(t, y)}{2\pi \cdot V_t \cdot I_t} \cdot f_s \cdot [3(E_{onT} + E_{onDT}) + 3(E_{offT} + E_{offDT}) + (E_{onT} + E_{offT} - E_{onDT} - E_{offDT}) \cdot \cos\theta] \quad (31)$$

#### IV. OPTIMAL SIZING RESULTS

The optimal design of single-phase, grid-connected PV inverters, which are based on the H5, H6, NPC, ANPC and Conergy-NPC transformerless topologies (Fig. 2) with  $P_n = 2 \text{ kW}$ ,  $V_n = 220 \text{ V}$  and  $f = 50 \text{ Hz}$ , has been performed according to the optimization procedure described in § II and using the models in § III. The PV inverters under study comprise an LCL-type output filter and are connected to a PV array composed of PV modules with MPP power and voltage ratings, under Standard Test Conditions (STC), equal to 175 W and 35.4 V, respectively. The service lifetime of the PV system is  $n = 25$  years. During that time interval, the PV modules exhibit an annual reduction coefficient of their output power rating equal to  $r(y) = 0.6\%$  in (9), as specified by their manufacturer.

The power section of all PV inverters consists of commercially available IGBT-type power switches with integrated free-wheeling diodes. Discrete clamping diodes have been used in the H6- and NPC-based PV-inverters. The technical characteristics of the PV inverter components are based on the datasheet information provided by their manufacturers and they are presented in Table IV. According to the selling prices of the corresponding components in the international market, the economical characteristics of the PV inverter components are summarized in Table V. As discussed



in § II, the cost of integrating and housing the PV inverter subsystems has been included in the manufacturing cost,  $c_{inv}$ , which is displayed in Table V.

A heat-sink with convection cooling and a  $\theta_{ca} = 0.65$  °C/W thermal resistance has been selected such that the maximum junction temperature developed at the power semiconductors during the year is less than the 175 °C limit set by their manufacturer. The total failure rate of the PV inverter components, which are not included in the set of the PV inverter design variables,  $\lambda_c$  in

(6), has been set equal to 17.2 failures/10<sup>6</sup> hours [32, 39]. The maximum permissible output current ripple is limited to  $RF = 2\%$  in order to conform to the IEEE-1547 standard. The damping resistor over-sizing factor has been set equal to  $SF = 110\%$ . The control unit power consumption is  $P_{cu} = 5W$ . The global minimum of the PV inverter  $LCOE$  (objective) function is calculated using a software program developed under the MATLAB platform. In this program, the GA optimization process has been implemented using the built-in genetic algorithm functions of the MATLAB global optimization toolbox and it is executed for 1000 generations, where each generation is comprised of a population of 40 chromosomes.

The optimal values of the PV inverter design variables (i.e.  $L$ ,  $L_g$ ,  $C_f$ ,  $R_{dr}$  and  $f_s$ ) and Levelized Cost Of the generated Electricity,  $LCOE_{opt}$ , which have been calculated using the proposed optimization process for the H5, H6, NPC,

TABLE IV  
THE TECHNICAL CHARACTERISTICS OF THE PV INVERTER COMPONENTS

| power switches    |                    | power diodes |               | $E_{onT} + E_{onDT}$<br>(mJ) | $E_{offT} + E_{offDT}$<br>(mJ) | $E_{onD}$<br>(mJ)                 | $E_{offD}$<br>(mJ) | $f_{s,max}$<br>(kHz) | $V_t$<br>(V) | $I_t$<br>(A) |
|-------------------|--------------------|--------------|---------------|------------------------------|--------------------------------|-----------------------------------|--------------------|----------------------|--------------|--------------|
| $V_{s,on}$<br>(V) | $R_{s,on}$<br>(mΩ) | $V_d$<br>(V) | $R_d$<br>(mΩ) |                              |                                |                                   |                    |                      |              |              |
| 0.75              | 83.3               | 0.87         | 120           | 0.09                         | 0.11                           | $47.5 \cdot 10^{-9} \cdot V_{rr}$ | 0                  | 30                   | 400          | 6            |

TABLE V  
THE ECONOMICAL CHARACTERISTICS OF THE PV INVERTER COMPONENTS

| $c_{inv}$<br>(€/kW) | $c_{hs}$<br>(€) | $c_s + c_d$<br>(€) | $c_{cd}$<br>(€) | $c_i$<br>(€/H·A) | $c_c$<br>(€/F)   | $c_r$<br>(€/Ω·W)    | $M_{inv}$<br>(€) | $g$<br>(%) | $d$<br>(%) |
|---------------------|-----------------|--------------------|-----------------|------------------|------------------|---------------------|------------------|------------|------------|
| 327.8               | 27.2            | 1.5                | 0.91            | 832              | $134 \cdot 10^3$ | $3.6 \cdot 10^{-3}$ | 100.0            | 3.0        | 5.0        |

ANPC and Conergy-NPC PV inverters installed in Athens (Greece), Oslo (Norway), Murcia (Spain) and Freiburg (Germany), respectively, are presented in Table VI. Different set of optimal values has been derived in each case, due to the different structure of the power semiconductors comprising each PV inverter topology and the different solar irradiation and ambient temperature conditions prevailing at each installation site, which affect the input voltage and power operating conditions of the PV inverters during their lifetime period. For the specific operational and economical characteristics of the components used to build the optimized PV inverters (Tables IV and V) and depending on the PV inverter topology and installation location, the optimal value of the switching frequency,  $f_s$  in Table VI, has been calculated to be equal or close to the 30 kHz maximum limit of the power semiconductors considered, in order to minimize the contribution of the LCL-filter cost to the overall cost of the PV inverter [i.e.  $C_{inv}(X)$  in (2) and (3)].

The LCOE values of the non-optimized H5, H6, NPC,

TABLE VI  
THE OPTIMAL VALUES OF THE DESIGN VARIABLES OF THE H5, H6, NPC, ANPC AND CONERGY-NPC PV INVERTERS AND THE LCOE OF THE OPTIMIZED AND NON-OPTIMIZED PV INVERTERS FOR VARIOUS INSTALLATION SITES IN EUROPE

|                       |             | $L$ (mH)     | $L_g$ (μH)    | $C_f$ (μF)   | $R_{dr}$ (Ω) | $f_s$ (kHz)  | $LCOE_{opt}$<br>(€/MWh) | $LCOE_{n-o}$<br>(€/MWh) |
|-----------------------|-------------|--------------|---------------|--------------|--------------|--------------|-------------------------|-------------------------|
| Athens<br>(Greece)    | H5          | 2.825        | 43.232        | 5.919        | 2.682        | 30.00        | 17.692                  | 19.159                  |
|                       | H6          | 2.825        | 51.907        | 4.920        | 3.219        | 30.00        | 17.810                  | 19.313                  |
|                       | NPC         | 2.818        | 39.339        | 6.366        | 2.469        | 30.00        | 17.656                  | 19.074                  |
|                       | ANPC        | 2.818        | 40.982        | 6.098        | 2.574        | 30.00        | 17.703                  | 19.177                  |
|                       | Conergy-NPC | <b>2.852</b> | <b>42.270</b> | <b>5.876</b> | <b>2.662</b> | <b>30.00</b> | <b>17.597</b>           | 18.991                  |
| Oslo<br>(Norway)      | H5          | 3.119        | 39.439        | 6.216        | 2.503        | 29.95        | 26.633                  | 29.133                  |
|                       | H6          | 3.214        | 36.592        | 6.455        | 2.368        | 29.95        | 26.870                  | 29.371                  |
|                       | NPC         | 3.363        | 47.531        | 4.786        | 3.130        | 29.95        | 26.789                  | 28.996                  |
|                       | ANPC        | 3.150        | 37.577        | 6.455        | 2.399        | 29.95        | 26.678                  | 29.162                  |
|                       | Conergy-NPC | <b>3.091</b> | <b>46.174</b> | <b>5.978</b> | <b>2.759</b> | <b>29.95</b> | <b>26.478</b>           | 28.866                  |
| Murcia<br>(Spain)     | H5          | 2.825        | 37.680        | 6.577        | 2.378        | 30.00        | 15.586                  | 16.820                  |
|                       | H6          | 2.825        | 42.945        | 5.755        | 2.711        | 30.00        | 15.685                  | 16.954                  |
|                       | NPC         | 2.813        | 45.333        | 5.456        | 2.860        | 29.95        | 15.559                  | 16.745                  |
|                       | ANPC        | 2.795        | 37.729        | 6.574        | 2.380        | 30.00        | 15.589                  | 16.836                  |
|                       | Conergy-NPC | <b>2.825</b> | <b>38.189</b> | <b>6.470</b> | <b>2.413</b> | <b>30.00</b> | <b>15.502</b>           | 16.672                  |
| Freiburg<br>(Germany) | H5          | 2.997        | 37.963        | 6.380        | 2.424        | 29.95        | 26.165                  | 28.719                  |
|                       | H6          | 2.997        | 39.662        | 6.455        | 2.463        | 29.95        | 26.332                  | 28.951                  |
|                       | NPC         | 2.997        | 37.546        | 6.455        | 2.397        | 29.95        | 26.117                  | 28.586                  |
|                       | ANPC        | 3.180        | 37.606        | 6.455        | 2.400        | 29.95        | 26.330                  | 28.747                  |
|                       | Conergy-NPC | <b>3.002</b> | <b>38.886</b> | <b>6.452</b> | <b>2.401</b> | <b>29.95</b> | <b>26.028</b>           | 28.458                  |




Fig. 5. The total cost of the optimized and non-optimized H5, H6, NPC, ANPC and Conergy-NPC PV inverters for various installation sites in Europe.

ANPC and Conergy-NPC PV inverters in each site,  $LCOE_{n-o}$ , are also presented in Table VI. The non-optimized PV inverters are composed of the same semiconductors as the optimized PV inverters. The LCL output filter of the non-optimized PV inverters has been designed according to the methodology presented in [30] and it consists of:  $L = 5.65$  mH,  $L_g = 1.09$  mH,  $C_f = 3.29$   $\mu$ F and  $R_{dr} = 5.6$   $\Omega$ . The non-optimized PV inverters operate with a switching frequency equal to  $f_s = 8$  kHz, which is within the typical range of switching frequency values applied at power and voltage levels of this order [10, 19, 25]. Thus, in contrast to the procedure followed in the proposed methodology, the non-optimized PV inverters have been designed using conventional techniques, without considering the manufacturing cost, energy production and number of failures in each installation site. The LCOE of the optimized PV inverters based on the H5, H6, NPC, ANPC and Conergy-NPC topologies is lower by 7.02-9.05 % compared to that of the corresponding non-optimized PV inverter structures. In all installation sites the best performance in terms of LCOE is achieved by the optimized Conergy-NPC PV inverters. The optimal LCOE of the Conergy-NPC inverters installed in Athens, Oslo, Murcia and Freiburg, respectively, is lower than the optimal LCOE of the rest PV inverter topologies in the same installation sites by 0.44-1.67 %, 0.45-1.72 %, 0.44-1.66 % and 0.45-1.70 %, respectively.

The lifetime cost,  $C_{inv}(X)$  in (2) and (3), of the optimized and non-optimized H5, H6, NPC, ANPC and Conergy-NPC PV inverters for various installation sites in Europe is depicted in Fig. 5. Compared to the non-optimized PV inverters, the cost of the optimized H5, H6, NPC, ANPC and Conergy-NPC topologies is lower by 2.98-3.47 %. In all installation sites, the minimum cost is achieved by the optimized Conergy-NPC inverter and it is lower by 0.16-0.70 % compared to that of the optimized PV inverters based on H5, H6, NPC and ANPC topologies.

The total energy injected into the electric grid,  $E_i(X)$  in (2) and (7), by the non-optimized and optimized PV inverters in various installation sites in Europe is illustrated in Fig. 6(a) and (b), respectively. The energy injected into the electric grid by the optimized H5, H6, NPC, ANPC and Conergy-NPC PV inverters is higher compared to that of the corresponding non-optimized structures in each installation site, by 3.83-6.35 %. Among the optimized PV inverters, the Conergy-NPC PV




Fig. 6. The lifetime energy injected into the electric grid by the H5, H6, NPC, ANPC and Conergy-NPC PV inverters for various installation sites in Europe: (a) non-optimized PV inverter and (b) optimized PV inverter.




Fig. 7. The Mean Time Between Failures (MTBF) of the H5, H6, NPC, ANPC and Conergy-NPC PV inverters for various installation sites in Europe: (a) non-optimized PV inverter and (b) optimized PV inverter.

inverters achieve the maximum energy production in all installation sites. The PV-generated energy injected into the electric grid by the optimized Conergy-NPC PV inverters is higher than that of the optimized PV inverters based on the H5, H6, NPC and ANPC topologies by 0.08-0.76 %.

The Mean Time Between Failures (MTBF) of the non-optimized and optimized H5, H6, NPC, ANPC and Conergy-NPC PV inverters for each installation site are presented in Fig. 7. It is observed that the H6 and ANPC topologies exhibit equivalent reliability performance. The same effect is observed for the NPC and Conergy-NPC inverters. The MTBF of the H5 PV-inverters is close to that of the NPC and Conergy-NPC inverters. Also, for all PV inverter topologies under study, the PV inverters optimized for Murcia exhibit the worst performance in terms of MTBF, although, as illustrated in Table VI, they exhibit the minimum optimal LCOE. This is

due to the increased values of the stress factors applied to the PV inverter components during operation, since the solar irradiation and ambient temperature are higher at this installation site. The MTBF values of the optimized H5, H6, NPC, ANPC and Conergy-NPC PV inverters are higher by 0.03-0.05 % compared to the MTBF of the corresponding non-optimized PV inverter topologies. Among the PV inverter topologies examined, the optimized H5 inverters exhibit the best performance in terms of reliability in Athens and Murcia, where their MTBF is higher by 0.04-1.66 % compared to that of the corresponding H6, NPC, ANPC and Conergy-NPC PV inverters which have been optimized for the same installation locations. Similarly, the MTBF of the optimized NPC and Conergy-NPC inverters in Oslo and Freiburg is higher by 0.04-1.60 % compared to the MTBF of the optimized H5, H6 and ANPC PV-inverters in these sites. As analyzed in § II, the MTBF depends on the values of the components comprising the PV inverter and the stress factors applied at these components, which are determined by the meteorological conditions prevailing in each installation area. However, since the MTBF is calculated in (6) by weighting the values of the stress factors by the percentage of operating hours at each stress level, the impact of extreme individual values of the stress factors on the resulting MTBF is smoothed. Thus, depending on the installation location, the maximum deviation of the MTBF among the optimized PV inverters is 1.62-1.66 %. In all installation sites, the H6 and ANPC PV inverters exhibit the lowest MTBF due to the larger number of components they consist of.

The optimal values of  $L$ ,  $L_g$ ,  $C_f$  and  $f_s$  of optimized H5, H6, NPC, ANPC and Conergy-NPC PV inverters with  $P_n = 10 \text{ kW}$  differ by 16.87-51.51 %, 90.79-94.93 %, 14.05-100.02 % and 266.25-275.00 %, respectively, from the corresponding values of the non-optimized PV inverter (also with  $P_n = 10 \text{ kW}$ ). In case that  $P_n = 10 \text{ kW}$ , the value of  $c_{inv}$  dominates in the PV inverter total cost [ $C_{inv}$  in (2) and (3)], thus reducing the sensitivity of LCOE with respect to the values of the design variables [i.e. vector  $X$  in (2)]. The resulting optimal LCOE values are lower than the LCOE of the non-optimized PV inverters by 0.03-0.74 %.

The convergence of the GA-based optimization procedure to the global minimum of the LCOE objective function has been verified by also applying an exhaustive-search method, which, however, requires more time in order to be completed than the GA process.

## V. CONCLUSIONS

Among the transformerless PV inverter structures, the H5, H6, NPC, ANPC and Conergy-NPC topologies are employed in commercially available grid-connected PV inverters and Distributed Generation systems. In this paper, a new methodology has been presented for calculating the optimal values of the components comprising the H5, H6, NPC, ANPC and Conergy-NPC PV inverters, such that the PV inverter Levelized Cost Of the generated Electricity (LCOE)

is minimized. The components reliability in terms of the corresponding malfunctions, which affect the PV inverter maintenance cost during the operational lifetime period of the PV installation, is also considered in the optimization process. The proposed design method has the advantage of taking into account the concurrent influences of the PV inverter topology, the meteorological conditions prevailing at the installation site, as well as the PV inverter component cost, operational characteristics and reliability features, on both the PV inverter lifetime cost and total energy production.

According to the design optimization results, the optimal values of the PV inverter design variables depend on the topology of the PV inverter power section (i.e. H5, H6, NPC, ANPC and Conergy-NPC) and the meteorological conditions at the installation site. Compared to the non-optimized PV inverters, all PV inverter structures, which have been optimally designed using the proposed methodology, feature lower LCOE and lifetime cost, longer Mean Time Between Failures (MTBF) and inject more energy into the electric grid. Thus, by using the optimized PV inverters, the total economic benefit obtained during the lifetime period of the PV system is maximized.

## REFERENCES

- [1] M.C. Cavalcanti, K.C. de Oliveira, A.M. de Farias, F.A.S. Neves, G.M.S. Azevedo, and F.C. Camboim, "Modulation Techniques to Eliminate Leakage Currents in Transformerless Three-Phase Photovoltaic Systems," *IEEE Transactions on Industrial Electronics*, vol. 57, no. 4, pp. 1360-1368, April 2010.
- [2] O. Lopez, F.D. Freijedo, A.G. Yepes, P. Fernandez-Comesaa, J. Malvar, R. Teodorescu, and J. Doval-Gandoy, "Eliminating Ground Current in a Transformerless Photovoltaic Application," *IEEE Transactions on Energy Conversion*, vol. 25, no. 1, March 2010.
- [3] H. Patel, V. Agarwal, "A Single-Stage Single-Phase Transformer-Less Doubly Grounded Grid-Connected PV Interface," *IEEE Transactions on Energy Conversion*, vol. 24, no. 1, pp. 93-101, 2009.
- [4] A. Mäki, S. Valkealahti, "Power Losses in Long String and Parallel-Connected Short Strings of Series-Connected Silicon-Based Photovoltaic Modules Due to Partial Shading Conditions," *IEEE Transactions on Energy Conversion*, vol. 27, no. 1, pp. 173-183, 2012.
- [5] M.E. Ropp, S. Gonzalez, "Development of a MATLAB/Simulink Model of a Single-Phase Grid-Connected Photovoltaic System," *IEEE Transactions on Energy Conversion*, vol. 24, no. 1, pp. 195-202, 2009.
- [6] R. Teodorescu, M. Liserre, and P. Rodríguez, *Grid converters for photovoltaic and wind power systems*, Wiley, 1<sup>st</sup> ed., 2011.
- [7] L. Ma, X. Jin, T. Kerekes, M. Liserre, R. Teodorescu, and P. Rodriguez, "The PWM strategies of grid-connected distributed generation active NPC inverters," in *IEEE Energy Conversion Congress and Exposition (ECCE)*, pp. 920-927, 2009.
- [8] H. Zang, X. Yang, "Simulation of Two-Level Photovoltaic Grid-Connected System Based on Current Control of Hysteresis Band," in *2011 Asia-Pacific Power and Energy Engineering Conference (APPEEC)*, pp. 1-4, 2011.
- [9] G. Zeng, T.W. Rasmussen, and R. Teodorescu, "A novel optimized LCL-filter designing method for grid connected converter," in *2<sup>nd</sup> IEEE International Symposium on Power Electronics for Distributed Generation Systems (PEDG)*, pp. 802-805, 2010.
- [10] T. Kerekes, R. Teodorescu, P. Rodríguez, G. Vázquez, and E. Aldabas, "A New High-Efficiency Single-Phase Transformerless PV Inverter Topology," *IEEE Transactions on Industrial Electronics*, vol. 58, no. 1, pp. 184-191, Jan. 2011.
- [11] T. Kerekes, M. Liserre, R. Teodorescu, C. Klumpner, and M. Sumner, "Evaluation of Three-Phase Transformerless Photovoltaic Inverter Topologies," *IEEE Transactions on Power Electronics*, vol. 24, no. 9, pp. 2202-2211, Sept. 2009.

- [12] S.V. Araujo, P. Zacharias, and R. Mallwitz, "Highly Efficient Single-Phase Transformerless Inverters for Grid-Connected Photovoltaic Systems," *IEEE Transactions on Industrial Electronics*, vol. 57, no. 9, pp. 3118-3128, Sept. 2010.
- [13] W. Yu, J.-S. Lai, H. Qian, and C. Hutchens, "High-Efficiency MOSFET Inverter with H6-Type Configuration for Photovoltaic Nonisolated AC-Module Applications," *IEEE Transactions on Power Electronics*, vol. 26, no. 4, pp. 1253-1260, April 2011.
- [14] B. Yang, W. Li, Y. Gu, W. Cui, and X. He, "Improved Transformerless Inverter With Common-Mode Leakage Current Elimination for a Photovoltaic Grid-Connected Power System," *IEEE Transactions on Power Electronics*, vol. 27, no. 2, pp. 752-762, Feb. 2012.
- [15] Z. Zhao, M. Xu, Q. Chen, J.-S. Lai, and Y. Cho, "Derivation, Analysis, and Implementation of a Boost-Buck Converter-Based High-Efficiency PV Inverter," *IEEE Transactions on Power Electronics*, vol. 27, no. 3, pp. 1304-1313, March 2012.
- [16] H. Xiao, S. Xie, "Transformerless Split-Inductor Neutral Point Clamped Three-Level PV Grid-Connected Inverter," *IEEE Transactions on Power Electronics*, vol. 27, no. 4, pp. 1799-1808, April 2012.
- [17] J.-M. Shen, H.-L. Jou, and J.-C. Wu, "Novel Transformerless Grid-Connected Power Converter With Negative Grounding for Photovoltaic Generation System," *IEEE Transactions on Power Electronics*, vol. 27, no. 4, pp. 1818-1829, April 2012.
- [18] A. Hasanzadeh, C.S. Edrington, and J. Leonard, "Reduced switch NPC-based transformerless PV inverter by developed switching pattern," in *27<sup>th</sup> Annual IEEE Applied Power Electronics Conference and Exposition (APEC)*, pp. 359-360, 2012.
- [19] H. Xiao, S. Xie, Y. Chen, and R. Huang, "An Optimized Transformerless Photovoltaic Grid-Connected Inverter," *IEEE Transactions on Industrial Electronics*, vol. 58, no. 5, pp. 1887-1895, May 2011.
- [20] S. Saridakis, E. Koutroulis, and F. Blaabjerg, "Optimal design of NPC and Active-NPC transformerless PV inverters," in *3<sup>rd</sup> IEEE International Symposium on Power Electronics for Distributed Generation Systems (PEDG)*, pp. 106-113, 2012.
- [21] P. Zhang, Y. Wang, W. Xiao, and W. Li, "Reliability Evaluation of Grid-Connected Photovoltaic Power Systems," *IEEE Transactions on Sustainable Energy*, vol. 3, no. 3, pp. 379-389, July 2012.
- [22] E. Koutroulis, F. Blaabjerg, "Design optimization of transformerless grid-connected PV inverters including reliability," *IEEE Transactions on Power Electronics*, vol. 28, no. 1, pp. 325-335, 2013.
- [23] F. Chan, H. Calleja, "Reliability estimation of three single-phase topologies in grid-connected PV systems," *IEEE Transactions on Industrial Electronics*, vol. 58, no. 7, pp. 2683-2689, 2011.
- [24] G. Petrone, G. Spagnuolo, R. Teodorescu, M. Veerachary, and M. Vitelli, "Reliability Issues in Photovoltaic Power Processing Systems," *IEEE Transactions on Industrial Electronics*, vol. 55, no. 7, pp. 2569-2580, July 2008.
- [25] R. Gonzalez, J. Lopez, P. Sanchis, and L. Marroyo, "Transformerless Inverter for Single-Phase Photovoltaic Systems," *IEEE Transactions on Power Electronics*, vol. 22, no. 2, pp. 693-697, March 2007.
- [26] A.C. Nanakos, E.C. Tatakis, and N.P. Papanikolaou, "A Weighted-Efficiency-Oriented Design Methodology of Flyback Inverter for AC Photovoltaic Modules," *IEEE Transactions on Power Electronics*, vol. 27, no. 7, pp. 3221-3233, July 2012.
- [27] T. Kerekes, R. Teodorescu, P. Rodríguez, G. Vázquez, and E. Aldabas, "A new high-efficiency single-phase transformerless PV inverter topology," *IEEE Transactions on Industrial Electronics*, vol. 58, no. 1, pp. 184-191, Jan. 2011.
- [28] E. Koutroulis, F. Blaabjerg, "Methodology for the optimal design of transformerless grid-connected PV inverters," *IET Power Electronics*, vol. 5, no. 8, pp. 1491-1499, 2012.
- [29] M. Campbell, J. Blunden, E. Smeloff, and P. Aschenbrenner, "Minimizing utility-scale PV power plant LCOE through the use of high capacity factor configurations," in *34<sup>th</sup> IEEE Photovoltaic Specialists Conference*, pp. 421-426, 2009.
- [30] M. Liserre, F. Blaabjerg, and S. Hansen, "Design and control of an LCL-filter-based three-phase active rectifier," *IEEE Transactions on Industry Applications*, vol. 41, no. 5, pp. 1281-1291, Sept. 2005.
- [31] Department of Defense, *Reliability Prediction of Electronic Equipment*, Military Handbook 217-F, USA, 1991.
- [32] A. Ristow, M. Begovic, A. Pregelj, and A. Rohatgi, "Development of a methodology for improving photovoltaic inverter reliability," *IEEE Transactions on Industrial Electronics*, vol. 55, no. 7, pp. 2581-2592, July 2008.
- [33] H. Patel, V. Agarwal, "MPPT Scheme for a PV-Fed Single-Phase Single-Stage Grid-Connected Inverter Operating in CCM With Only One Current Sensor," *IEEE Transactions on Energy Conversion*, vol. 24, no. 1, pp. 256-263, 2009.
- [34] E. Koutroulis, F. Blaabjerg, "A New Technique for Tracking the Global Maximum Power Point of PV Arrays Operating Under Partial-Shading Conditions," *IEEE Journal of Photovoltaics*, vol. 2, no. 2, pp. 184-190, April 2012.
- [35] S. Jiang, D. Cao, Y. Li, and F. Peng, "Grid-Connected Boost-Half-Bridge Photovoltaic Micro Inverter System Using Repetitive Current Control and Maximum Power Point Tracking," *IEEE Transactions on Power Electronics*, vol. 27, no. 11, pp. 4711-4722, Nov. 2012.
- [36] E. Lorenzo, *Solar electricity - Engineering of photovoltaic systems*, 1<sup>st</sup> Edition, Progensa, 1994, pp. 87-99.
- [37] D. Florica, G. Gateau, A. Leredde, and R. Teodorescu, "The efficiency of three-level Active NPC converter for different PWM strategies," in *13<sup>th</sup> European Conference on Power Electronics and Applications (EPE)*, pp. 1-9, 2009.
- [38] T.J. Kim, D.W. Kang, Y.H. Lee, and D.S. Hyun, "The analysis of conduction and switching losses in multi-level inverter system," in *IEEE 32<sup>nd</sup> Annual Power Electronics Specialists Conference*, vol. 3, pp. 1363-1368, 2001.
- [39] M. Aten, G. Towers, C. Whitley, P. Wheeler, J. Clare, and K. Bradley, "Reliability comparison of matrix and other converter topologies," *IEEE Transactions on Aerospace and Electronic Systems*, vol. 42, no. 3, pp. 867-875, July 2006.