Aalborg Universitet



Room Airflows with Low Reynolds Number Effects

Topp, Claus; Nielsen, Peter V.; Davidson, Lars

Publication date: 2000

Document Version Publisher's PDF, also known as Version of record

Link to publication from Aalborg University

Citation for published version (APA):

Topp, C., Nielsen, P. V., & Davidson, L. (2000). *Room Airflows with Low Reynolds Number Effects*. Dept. of Building Technology and Structural Engineering, Aalborg University. Indoor Environmental Engineering Vol. R0030 No. 107

General rights

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- You may not further distribute the material or use it for any profit-making activity or commercial gain You may freely distribute the URL identifying the publication in the public portal -

Take down policy

If you believe that this document breaches copyright please contact us at vbn@aub.aau.dk providing details, and we will remove access to the work immediately and investigate your claim.

Aalborg UNIVERSITY



Reynolds Number Effects

C. Topp, P. V. Nielsen, L. Davidson



Paper No 107

Indoor Environmental Engineering

In: Proceedings of ROOMVENT 2000, 7th International Conference on Air Distribution in Rooms, Reading, United Kingdom, 2000, pp. 541-546 The *Indoor Environmental Engineering* papers are issued for early dissemination of research results from the Indoor Environmental Engineering Group at the Department of Building Technology and Structural Engineering, Aalborg University. These papers are generally submitted to scientific meetings, conferences or journals and should therefore not be widely distributed. Whenever possible, reference should be given to the final publications (proceedings, journals, etc.) and not to the Indoor Environmental Engineering papers.

Room Airflows with Low Reynolds Number Effects

C. Topp, P. V. Nielsen, L. Davidson

..... -1 .

ROOM AIRFLOWS WITH LOW REYNOLDS NUMBER EFFECTS

C. Topp¹, P.V. Nielsen¹ and L. Davidson²

 ¹ Department of Building Technology and Structural Engineering, Aalborg University, Sohngaardsholmsvej 57, DK-9000 Aalborg, Denmark
² Department of Thermo and Fluid Dynamics, Chalmers University of Technology, S-412 96 Gothenburg, Sweden

ABSTRACT

The behaviour of room airflows under fully turbulent conditions is well known both in terms of experiments and numerical calculations by computational fluid dynamics (CFD). For room airflows where turbulence is not fully developed though, i.e. flows at low Reynolds numbers, the existing knowledge is limited.

It has been the objective to investigate the behaviour of a plane isothermal wall jet in a full-scale ventilated room at low Reynolds numbers, i.e. when the flow is not fully turbulent. The results are significantly different from known theory for fully turbulent flows. It was found that the jet constants are a strong function of the Reynolds number up to a level of $Re_h \approx 500$.

KEYWORDS

Room airflow, low Reynolds number effects, full-scale experiments, plane isothermal wall jet

INTRODUCTION

Supply flow rates for ventilation is often reduced due to more efficient ventilation or to reduce the energy consumption in mechanical ventilation. In natural ventilation where buoyancy and wind pressure are the driving forces there will be some periods during the year when the supply airflow rate is moderate.

Air for ventilation is often supplied as a jet above the occupied zone to achieve mixing with room air. When designing ventilation systems the jet and the entire room airflow is traditionally treated as turbulent flow although the airflow in some regions of a ventilated room is laminar or not fully turbulent.

The behaviour of turbulent jets is well known (Rajaratnam (1976) and Launder & Rodi (1983)) while little effort has been spend to investigate the behaviour of jets at low Reynolds numbers. It has been

the objective of this work to investigate the behaviour of a plane isothermal wall jet in a full-scale ventilated room at low Reynolds numbers, i.e. when the flow is not fully turbulent.

As the wall jet enters an open space a boundary layer builds up along the wall. In the boundary layer the velocity changes from zero at wall to its maximum value, u_x , at some distance from the wall, see Figure 1.



Figure 1: Outline of a typical velocity profile for a plane wall jet.

The velocity profile is generally represented by the maximum velocity, u_x , and the distance from the wall, $\delta_{1/2}$, at which the velocity has dropped to $u_x/2$.

For a plane fully turbulent wall jet the decay of the maximum velocity and the growth rate of the jet along the wall are given by

$$\frac{\mathbf{u}_{x}}{\mathbf{u}_{0}} = \mathbf{K}_{p} \sqrt{\frac{\mathbf{h}}{\mathbf{x} + \mathbf{x}_{0}}} \tag{1}$$

$$\delta_{1/2} = D_p(\mathbf{x} + \mathbf{x}_0) \tag{2}$$

where K_p is the velocity decay constant, D_p is the growth rate of the jet per unit distance from the inlet and x_0 is the virtual origin of the jet. K_p and D_p are both characteristic parameters for the diffuser.

At high Reynolds numbers (fully turbulent flow) K_p and D_p are constants and Eqn. 1 and 2 are valid. It has been chosen in the present work to apply Eqn. 1 and 2 to jets at low Reynolds numbers too, assuming D_p and K_p to be functions of the Reynolds number.

METHODS

A series of isothermal experiments were performed in a full-scale test room as shown in Figure 2 (left), corresponding to the room used in the IEA Annex 20 project but with full width slots (height h=0.02 m) as supply and exhaust openings. The supply opening was located at the top of the left end wall and thus generates a plane wall jet along the ceiling while the exhaust opening was located either at the top of the right end wall or at the foot of the left end wall, see Figure 2 (right).

The wall jet generated by the supply opening was considered plane due to the full width slot and velocity profiles were thus measured in the centreline of the jet. From smoke experiments similar

recirculating airflow patterns were observed for the two ventilation set-ups indicating no influence of exhaust location.



Figure 2: Outline of the full-scale test room (left) and the location of the full width supply and exhaust openings (right).

Velocity profiles were measured with hot-sphere probes in the centreline of the jet at different air change rates in the range from 0.4 h^{-1} to 4.0 h^{-1} , corresponding to supply Reynolds numbers, Re_h, ranging from 79 to 770.

RESULTS

In the following the Reynolds number refers to the diffuser and is based on the contracted slot height, h_0 . The Reynolds number is thus given by

$$\operatorname{Re}_{h} = \frac{u_{0}h_{0}}{v}$$
(3)

where v is the kinematic viscosity.

Velocity Profiles

For a plane wall jet the velocity profiles at different x-stations and different Reynolds numbers are expected to express similarity when plotted in terms of u/u_x and $y/\delta_{1/2}$. The measured profiles are shown in Figure 3. Also included in the figure are the empirical relation by Verhoff (1963) for a fully turbulent wall jet and a laminar relation established from experiments by Quintana et al. (1997).

It is seen from the figure that the profiles express similarity to some extend as a high degree of similarity is found for the highest Reynolds numbers, i.e. $Re_h \ge 477$ while for $Re_h < 477$ there is no obvious similarity within the jet.



Figure 3: Velocity profiles in the wall jet plotted in non-dimensional co-ordinates.

From the figure it should further be noticed that the profiles neither fit the turbulent or the laminar relation but lies somewhere in between indicating that the jet is transitional.

Characteristic Parameters, D_p and K_p

The jet growth rate along the ceiling, D_p , has been established from a best fit of the experimental data to the relation of $\delta_{1/2}$ and x given by Eqn. 2. Figure 4 shows D_p versus Re_h for both ventilation set-ups. Results obtained by Nielsen, Filholm, Topp & Davidson (2000) from model experiments are included for comparison.



Figure 4: The growth rate of the jet per unit distance from the inlet, D_p , as a function of Reynolds number, Re_h . Results from model scale experiments by Nielsen, Filholm, Topp & Davidson (2000) are included for comparison.

It is seen that the jet growth rate is a strong function of Reynolds number. As Re_h increases D_p drops rapidly and seems to reach a constant level at $Re_h \approx 400$. It should be observed that there is no significant difference in D_p between the two ventilation set-ups. In addition, the results agree well with the model scale experiments.

The velocity decay constant, K_p , has been established from a best fit of the experimental data to the relation of the maximum velocity, u_x , and the horizontal distance, x, given by Eqn. 1 with $h=h_0$ (the contracted slot height). Figure 5 shows K_p versus Re_h for both ventilation set-ups. Results obtained by Nielsen, Filholm, Topp & Davidson (2000) from model experiments are included in the figure.



Figure 5: The velocity decay constant, K_p , as a function of Reynolds number, Re_h. Results from model scale experiments by Nielsen, Filholm, Topp & Davidson (2000) are included for comparison.

In similar to the jet growth rate the results show that K_p is a strong function of Re_h as K_p drops rapidly with increasing Re_h up to Re_h~400 where K_p reaches a minimum. For Re_h>400 K_p takes on a slight increase. Again, it should be observed that there is no substantial difference between the two ventilation set-ups. The results agree well with the model scale experiments except for at Re_h~200.

DISCUSSION

A series of full-scale experiments were performed to investigate the behaviour of a plane isothermal wall jet at low Reynolds numbers, i.e. when the flow is not fully turbulent.

Designers of jets for ventilation purposes traditionally use turbulent relations that are independent of Reynolds number, Re_h . Care should be taken though, as the present work shows the jet to be a significant function of Re_h when the flow is laminar or transitional. The measured velocity profiles express similarity for $Re_h>400$ while the characteristic jet parameters D_p and K_p are strong functions of Re_h up to a critical Reynolds number of approximately 500.

Two different locations of the exhaust opening were investigated and no substantial difference was observed indicating that the exhaust has no significant influence on the jet.

ACKNOWLEDGEMENT

This research was funded by the Danish Technical Research Council as a part of the International Centre for Indoor Environment and Energy at the Technical University of Denmark.

REFERENCES

Launder, B.E. and Rodi, W. (1983). The turbulent wall jet - measurements and modelling. Annual Review of Fluid Mechanics 15, 429-459.

Nielsen, P.V., Filholm, C., Topp, C. and Davidson, L. (2000). Model experiments with low Reynolds number effects in a ventilated room (to appear). *Proceedings of ROOMVENT 2000*, Reading, UK.

Quintana, D.L., Amitay, M., Ortega, A. and Wygnanski, I.J. (1997). Heat transfer in the forced laminar wall jet. *Transactions of the ASME. Journal of Heat Transfer* **119:3**, 451-459.

Rajaratnam, N. (1976). Turbulent jets, Elsevier, Amsterdam, The Netherlands.

Verhoff, A. (1963). The two-dimensional turbulent wall jet with and without an external stream. Report No 626, Princeton University, Department of Aeronautical Engineering.

RECENT PAPERS ON INDOOR ENVIRONMENTAL ENGINEERING

PAPER NO. 107: C. Topp, P.V. Nielsen, L. Davidson: *Room Airflows with Low Reynolds Number Effects*. ISSN 1395-7953 R0030.

PAPER NO. 108: E. Bjørn, J. Jensen, J. Larsen, P.V. Nielsen, P. Heiselberg: Improvement of Thermal Comfort in a Naturally Ventilated Office. ISSN 1395-7953 R0032.

PAPER NO. 109: E. Bjørn: Simulation of Human Respiration with Breathing Thermal Manikin. ISSN 1395-7953 R0033.

PAPER NO. 110: P. Heiselberg: Hybrid Ventilation and the Consequences on the Development of the Facade. ISSN 1395-7953 R0033.

PAPER NO. 111: P. Heiselberg, M. Pedersen, T. Plath: *Local Exhaust Optimization and Worker Exposure*. ISSN 1395-7953 R0034.

PAPER NO. 112: K. Svidt, P. Heiselberg: *Push-Pull Ventilation in a Painting Shop for Large Steel Constructions*. ISSN 1395-7953 R0035.

PAPER NO. 113: P. Heiselberg: *Design Principles for Natural land Hybrid Ventilation*. ISSN 1395-7953 R0036

PAPER NO. 114: A. Andersen, M. Bjerre, Z.D. Chen, P. Heiselberg, Y. Lin: *Experimental* Study of Wind-Opposed Buoyancy-Driven Natural Ventilation. ISSN 1395-7953 R0037

PAPER NO. 115: P. Heiselberg, K. Svidt, P.V. Nielsen: Windows Measurements of Air Flow Capacity. ISSN 1395-7953 R0040

PAPER NO. 116: K. Svidt. P. Heiselberg, P.V. Nielsen: Characterization of the Airflow from a Bottom Hung Window under Natural Ventilation. ISSN 1395-7953 R0041

PAPER NO. 117: Z. Yue, P.V. Nielsen: Flow Pattern in Ventilated Rooms with Large Depth and Width. ISSN 1395-7953 R0042.

PAPER NO. 118: P.V. Nielsen, H. Dam, L.C. Sørensen, K. Svidt, P. Heiselberg: *Characteristics of Buoyant Flow from Open windows in Naturally Ventilated Rooms.* ISSN 1395-7953 R0043.

PAPER NO. 119: P.V. Nielsen, C. Filholm, C. Topp, L. Davidson: *Model Experiments with Low Reynolds Number Effects in a Ventilated Room*. ISSN 1395-7953 R0044.

PAPER NO. 120: P. Lengweiler, P.V. Nielsen, A. Moser, P. Heiselberg, H. Takai: *Experimental Method for Measuring the Dust Load on Surfaces in Rooms*. ISSN 1395-7953 R0045.

PAPER NO. 121: L. Davidson, P.V. Nielsen, C. Topp: Low-Reynolds Number Effects in Ventilated Rooms: A Numerical Study. 1395-7953 R0046.

PAPER NO. 122: F. Haghighat, H. Brohus, C. Frier, P. Heiselberg: Stochastic Prediction of Ventilation System Performance. ISSN 1395-7953 R0047.

Complete list of papers: http://iee.civil.auc.dk/i6/publ/iee.html

Room Air

ISSN 1395-7953 R0030 Dept. of Building Technology and Structural Engineering Aalborg University, December 2000 Sohngaardsholmsvej 57, DK-9000 Aalborg, Denmark Phone: +45 9635 8080 Fax: +45 9814 8243 http://iee.civil.auc.dk